

Environmental Standards

Emission

BAGASSE-FIRED BOILERS: EMISSION STANDARDS

Type	of	boilers	Pollutants	Concentration mg/Nm ³	in
Step grate			Particulate Matter	250	
Horse shoe/pulsating grate			Particulate Matter	500(12% CO ₂)	
Spreader stoker			Particulate Matter	800(12% CO ₂)	

Note: In the case of horse shoe and spreader stoker boilers, if more than one boiler is attached to a single stack, the standard shall be fixed based on added capacity of all the boilers connected with the stack.

Source: EPA Notification
[GSR 475(E), 5th May, 1992]