

I/169635/2023

## HARYANA STATE POLLUTION CONTROL BOARD

C-11, SECTOR-6, PANCHKULA  
Ph-2577870-73 E-mail: hspcbaircell@gmail.com

To

Director,  
Information, Public Relation & Languages Department, Haryana  
SCO-200-201, Sector -17-C, Chandigarh.

**Sub: Public Notice regarding Regulations for use of DG sets in NCR districts of Haryana.**

Kindly refer to the subject cited above.

In this connection, I have been directed to enclose herewith the public notice for publication as per DAVP rates in two leading Hindi and English newspapers published before 31 July, 2023 and between 1st August to 15th August 2023 circulated in NCR districts of Haryana, with a request to forward the bills for payment along with the original newspapers please.

**DA/public Notice**

Digitally Signed by Vinay  
Gautam  
Date: 24-07-2023 16:34:39  
Reason: Approved

**Env. Engineer (Aircell)**

**for Chairman**

CC to

1. All Branch Incharges in head office, HSPCB.
2. SEE (IT) with a request to upload the notice on website of Board.
3. Senior Accounts Officer, HSPCB.
4. All Regional Officers of NCR of HSPCB.
5. PS to ACS Env., Forests & Wildlife Department., Govt. of Haryana.
6. PS to DG Env. & Climate Change Department, Haryana.
7. PS to Chairman, HSPCB.

I/169635/2023

8. PA to Member Secretary, HSPCB.  
DA/public Notice

I/169636/2023

**HARYANA STATE POLLUTION CONTROL BOARD**  
**C-11, SECTOR-6, PANCHKULA**  
**Ph-2577870-73 E-mail: hspcbaircell@gmail.com**  
**Visit us at <https://www.hspcb.gov.in>**

**Kind Attention**

**Regulations for use of DG sets in NCR districts of Haryana.**

The Commission for Air Quality Management in NCR and Adjoining Areas (CAQM) issued Direction no. 73 regarding regulations for use of DG sets in the NCR.

The CAQM directed that new regulations of DG sets would come into force in the entire NCR strictly w.e.f. 01.10.2023 and retro-fitment of dual fuel kits or ECDs, wherever warranted, must be targeted to be completed latest by 30.09.2023, failing which the use of the diesel gen sets shall not be permitted under any circumstances, anywhere in the entire NCR.

Earlier DG sets were permitted for essential services (even without any emission control and pollution abatement measures) during period of restriction under the GRAP. Hospitals, residential/ office complexes, commercial entities etc., therefore, need to pay particular attention to the matter.

The above mentioned directions envisage the following compliances:-

<b>S. No.</b>	<b>Capacity Range of DG sets</b>	<b>System to be adopted for control of emissions</b>	<b>Regulations for use</b>
1.	Power generating sets of all capacities running on LPG / Natural Gas/ Biogas/Propane/ Butane	None	No restrictions (even during periods under GRAP)
2.	Portable DG sets (below 19 kW)	None	No restrictions during the periods, other than restrictions under GRAP. 19 kW to less than 125 kW not to be permitted during periods of restriction under GRAP
3.	19KW to less than 125 KW	Dual fuel mode (Natural Gas & Diesel)	No restrictions during periods other than under GRAP. To be permitted to run for maximum 2 hrs. in a day during restrictions under GRAP subject to methodical maintenance of log of operation of DG sets, preferably in a digital mode.

I/169636/2023

4.	125 KW to less than 800 KW	Dual fuel mode and retro-fitted ECDs through certified vendors / agencies	No restrictions (even during periods under GRAP)
5.	800 KW and above	Dual Fuel mode or any other emission control device/ system strictly subject to compliance for stack emissions as in the footnote.	No restrictions during periods other than under GRAP. To be permitted to run for maximum 2 hrs. in a day during restrictions under GRAP subject to methodical maintenance of log of operation of DG sets, preferably in a digital mode.
6.	New power generating sets of all capacities up to 800 kW procured to the standards as in MoEF&CC notification No.Q-15017/05/2012-CPW and GSR 804(E) dated 03.11.2022	None	No restrictions (even during periods under GRAP)

In view of the above, all stakeholder using DG sets in the NCR have to comply with the above said Direction of CAQM well before 30.09.2023, failing which action will be taken as per law.

**Chairman**