

Monitoring of STPs												
Yamuna Catchment												
Yamuna Nagar		Outlet of STP										
STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks	
Yamuna Nagar												
1 (YMN-STP-001) 25 MLD STP Radaur Road, Yamuna Nagar by PHED in 2020 (SBR)	20.01.2021	154 dt. 01.02.2021		6.4	28	7.43	11	2200	1.97	Complying	Complying	
	24.02.2021	468 dt. 05.03.2021		8	40	7.39	15	20	0.98	Complying	Complying	
	30.03.2021	751 dt. 09.04.2021	500 m3/h	7.2	40	7.25	10	Absent	0.41	Complying	Complying	
	28.04.2021	1000 dt. 12.05.2021		7.5	44	7.5	13	1100	1.06	Complying	Complying	
	27.05.2021	1210 dt. 09.06.2021		8.4	44	6.97	12	200	0.22	Complying	Complying	
	26.07.2021	29.06.2021	1460 dt. 12.07.2021	4.6	28	7.8	9	80	1.87	Complying	Complying	
	07.09.2021	30.07.2021	1882 dt. 19.08.2021	6.8	32	7.59	12	1100	3.27	Complying	Complying	
	30.09.2021	24.08.2021	2199 dt. 09.09.2021	700 m3	5.6	20	6.98	70	N.D.	Complying	Complying	
	25.10.2021	21.09.2021	2496 dt. 06.10.2021	200 m3/h	6.8	40	7.5	70	2.03	Complying	Complying	
	25.11.2021	22.10.2021	2810 dt. 03.11.2021	750 m3/h	7.5	48	7.68	14	Absent	0.68	Complying	Complying
	09.12.2021	10.11.2021	2930 dt. 23.11.2021	450m3/hr	7	36	7.2	12	200	1.82	Complying	Complying
	21.01.2022	16.12.2021	3394 dt. 29.12.2021	500 m3/h	4.5	48	7.07	12	Absent	1.03	Complying	Complying
	08.02.2022	18.01.2022	3828 dt. 31.01.2022	200 m3/hr	7.4	36	7.38	13	80	0.96	Complying	Complying
	06.04.2022	23.02.2022	4236 dt. 04.03.2022		8.5	48	7.37	16	60	1.04	Complying	Complying
	15.04.2022	24.03.2022	4673 dt. 31.03.2022		7.2	44	7.53	13	Absent	0.23	Complying	Complying
	20.05.2022	15.04.2022	5092 dt. 05.05.2022		7.5	36	6.9	15	40	0.64	Complying	Complying
	22.06.2022	24.05.2022	5544 dt. 07.06.2022		7.5	44	7.96	15	70	2.17	Complying	Complying
	18.07.2022	23.06.2022	5954 dt. 05.07.2022	524	6.8	32	7.62	13	80	1.67	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	06.09.2022	24.08.2022	6601 dt. 05.09.2022	423m3/h	8.5	48	7.39	18	80	ND	Complying	Complying
	13.10.2022	22.09.2022	6994 dt. 07.10.2022	4470m3/h	8	44	7.01	9	80	1.28	Complying	Complying
	16.11.2022	26.10.2022	7283 dt. 07.11.2022	460	5.6	20	7.75	11	70	0.34	Complying	Complying
	14.12.2022	28.11.2022	7601 dt. 12.12.2022	678m3	7.8	48	7.88	12	90	0.82	Complying	Complying
	13.01.2023	22.12.2022	7993 dt. 03.01.2023	410m3/h	5.5	20	7.34	8	70	ND	Complying	Complying
	09.02.2023	24.01.2023	229 dt. 02.02.2023	440m3/h	8	48	7.72	13	90	ND	Complying	Complying
	13.03.2023	24.02.2023	623 dt. 06.03.2023	441 m3/hr	7.2	32	7.79	13	80	ND	Complying	Complying
	17.04.2023	31.03.2023	1044 dt. 11.04.2023	513m3/hr	7.6	40	7.23	14	80	ND	Complying	Complying
	05.06.2023	10.05.2023	1451 dt. 23.05.2023	963m3/hr	8	48	7.12	15	90	ND	Complying	Complying
	12.07.2023	21.06.2023	1983 dt. 3.07.2023	517m3/hr	7.5	36	6.87	17	80	ND	Complying	Complying
	08.08.2023	24.07.2023	2309 dt. 01.08.2023	960 m3/hr	7.5	36	7.05	12	90	ND	Complying	Complying
	14.09.2023	31.08.2023	2718 dt. 11.09.2023	472m3/hr	7.2	40	7.32	13	80	ND	Complying	Complying
	19.10.2023	29.09.2023	3064 dt. 14.10.2023	578	6.4	32	7.38	14	60	ND	Complying	Complying
	03.11.2023	10.10.2023	3175 dt. 28.10.2023	588	6.2	32	6.89	10	80	ND	Complying	Complying
	18.01.2024	12.12.2023	3838 dt. 22.12.2023		5.8	28	6.95	10	50	ND	Complying	Complying
	Jan, 2024	11.01.2024	4234 dated 18.01.2024	6164	4.8	28	6.59	11	50	ND	Complying	Complying
	Feb, 2024	20.02.2024	4624 dated 12.03.2024	6749	6	32	7.03	10	90	ND	Complying	Complying
	Mar, 2024	15.03.2024	4976 dated 26.03.2024	7263	5.6	32	6.96	10	10	ND	Complying	Complying
		19.06.2024	429 dt. 02.07.2024		6.8	36	6.94	15		ND	Complying	Complying
		22.07.2024	715 dt. 30.07.2024		5.6	32	7.12	12		ND	Complying	Complying
		16.08.2024	883 dt. 23.08.2024		6.2	32	7	11		ND	Complying	Complying
		11.09.2024	1077 dt. 19.09.2024		5.6	40	7.8	15		ND	Complying	Complying
		21.10.2024	1317 dt. 29.10.2024		8.5	48	6.98	38		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		14.11.2024	1450 dt. 20.11.2024		6.2	28	6.39	12		ND	Complying	Complying
		19.12.2024	1730 dt. 30.12.2024		8	40	7.1	16		ND	Complying	Complying
2	(YMN-STP-002) 20 MLD STP,Radaur Road, Yamuna Nagar by PHED March dt. 30.09.2019	20.01.2021	155 dt. 01.02.2021		5.5	26	7.56	11	2600	2.26	Complying	Complying
		23.02.2021	435 dt. 04.03.2021		3.8	16	7.22	12	Absent	1.22	Complying	Complying
		30.03.2021	753 dt. 09.04.2021		6	36	7.56	12	Absent	0.54	Complying	Complying
		29.04.2021	1002 dt. 12.05.2021		6	40	7.82	12	330	1.17	Complying	Complying
		27.05.2021	1211 dt. 09.06.2021		9.5	44	7.65	14	260	0.16	Complying	Complying
	26.07.2021	29.06.2021	1461 dt. 12.07.2021		6.8	32	7.66	11	40	1.85	Complying	Complying
	07.09.2021	30.07.2021	1883 dt. 19.08.2021		6.6	36	7.28	13	700	3.93	Complying	Complying
	30.09.2021	24.08.2021	2198 dt. 09.09.2021	650 m3	7	32	7.08	14	50	N.D.	Complying	Complying
	25.10.2021	21.09.2021	2495 dt. 06.10.2021	170 m3/h	3.2	40	7.16	10	Absent	2.04	Complying	Complying
	30.11.2021	21.10.2021	2811 dt. 03.11.2021	580 m3/h	5.8	24	7.6	11	Absent	2.37	Complying	Complying
	09.12.2021	10.11.2021	2929 dt. 23.11.2021	400m3/hr	6.8	32	7.52	13	600	2.08	Complying	Complying
	21.01.2022	02.12.2021	3176 dt. 13.12.2021		7.6	44	7.34	15	200	1.29	Complying	Complying
	08.02.2022	18.01.2022	3827 dt. 31.01.2022	280 m3/hr	6.2	24	7.86	18	200		Complying	Complying
	06.04.2022	23.02.2022	4238 dt. 04.03.2022		6.8	40	7.44	12	Absent	0.77	Complying	Complying
	15.04.2022	24.03.2022	4674 dt. 31.03.2022		6.5	32	7.4	11	90	0.25	Complying	Complying
	17.05.2022	15.04.2022	5090 dt. 05.05.2022		7.8	44	7.47	13	90	0.77	Complying	Complying
	22.06.2022	24.05.2022	5542 dt. 07.05.2022		7	40	8.39	15	80	1.88	Complying	Complying
	18.07.2022	23.06.2022	5955 dt. 05.07.2022		7.5	44	7.85	15	60	1.47	Complying	Complying
	05.08.2022	13.07.2022	6253 dt. 25.07.2022	730 m3/h	8.2	36	7.98	14	90	1.67	Complying	Complying
	06.09.2022	24.08.2022	6604 dt. 05.09.2022	732m3/h	7.5	44	7.01	15	80	1.18	Complying	Complying
	13.10.2022	22.09.2022	6991 dt. 07.10.2022	460.49 m3	7.2	32	7.7	12	80	1.28	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
3	(YMN-STP-003) 3 MLD STP Chhachhrauli, Yamuna Nagar by PHED in 31.12.2015 (MBBR+TT, 2019)	27.01.2021	210 dt. 4.02.2021		15	72	7.14	41	1100	1.97	Complying	Complying
		24.02.2021	466 dt. 05.03.2021		7.4	44	7.51	18	20	1.06	Complying	Complying
		30.03.2021	755 dt. 09.04.2021		6.8	42	7.36	11	20	1.26	Complying	Complying
		29.04.2021	999 dt. 12.05.2021		4.8	16	8.1	8	270	0.63	Complying	Complying
		19.05.2021	1167 dt. 02.06.2021		5.8	28	7.12	8	11000	N.D.	Complying	Complying
	26.07.2021	28.06.2021	1463 dt. 12.07.2021		7.8	38	7.24	14	40	2.14	Complying	Complying
	07.09.2021	30.07.2021	1885 dt. 19.08.2021		6.8	28	7.62	11	840	1.84	Complying	Complying
	30.09.2021	25.08.2021	2195 dt. 09.09.2021	90 m3	6	28	7	10	5800	1.32	Complying	Complying
	25.10.2021	21.09.2021	2494 dt. 06.10.2021	160 m3/h	7.2	44	7.49	16	60	1.85	Complying	Complying
	30.11.2021	22.10.2021	2812 dt. 03.11.2021	60 m3/h	6.4	32	7.72	15	Absent	1.41	Complying	Complying
	24.12.2021	30.11.2021	3168 dt. 13.12.2021	170 m3/h	8	44	7.28	12	200	2.37	Complying	Complying
	21.01.2022	16.12.2021	3398 dt. 29.12.2021	110m3/hr	6.8	48	7.33	15	200	1.82	Complying	Complying
		31.01.2022	3981 dt. 09.02.2022	83 m3/hr	6.8	36	7.63	12	80	2.04	Complying	Complying
	06.04.2022	23.02.2022	4239 dt. 04.03.2022		7.5	48	7.49	14	50	2.37	Complying	Complying
	15.04.2022	24.03.2022	4674 dt. 31.03.2022		7	40	7.36	12	20	0.31	Complying	Complying
	20.05.2022	15.04.2022	5094 dt. 05.05.2022		7	32	7.09	13	90	1.08	Complying	Complying
	22.06.2022	24.05.2022	5545 dt. 07.06.2022		6.8	40	7.09	14	80	2.3	Complying	Complying
	20.07.2022	23.06.2022	5956 dt. 05.07.2022	0.15MLD	17	72	7.26	28	400	2.48	Complying	Complying
	05.08.2022	13.07.2022	6256 dt. 25.07.2022	0.41	7.8	48	7.56	16	90	3.38	Complying	Complying
	06.09.2022	24.08.2022	6600 dt. 05.09.2022	0.70 MLD	8	40	6.92	17	90	2.48	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	13.10.2022	22.09.2022	6995 dt. 07.10.2022	0.39 MLD	8.2	48	7.76	17	90	1.96	Complying	Complying
	16.11.2022	26.10.2022	7285 dt. 07.11.2022	1.34	8.2	48	7.98	34	400	0.21	Complying	Complying
	14.12.2022	28.11.2022	7598 dt. 12.12.2022	37.72	7.8	32	7.2	11	80	ND	Complying	Complying
	13.01.2023	22.12.2022	7991 dt. 03.01.2023	0.83 MLD	8.5	44	7.56	16	90	1.14	Complying	Complying
	09.02.2023	23.01.2023	225 dt. 02.02.2023		6.8	28	7.83	14	90	ND	Complying	Complying
	13.03.2023	24.02.2023	621 dt. 06.03.2023	0.39	7.8	36	7.3	12	80	ND	Complying	Complying
	13.04.2023	28.03.2023	1000 dt. 07.04.2023	26.59	7	24	7.13	14	90	ND	Complying	Complying
	05.06.2023	10.05.2023	1456 dt. 23.05.2023	1.10 mld	7.5	36	7.45	11	80	ND	Complying	Complying
	12.07.2023	21.06.2023	1985 dt. 3.07.2023	35.3m3/hr	6.8	24	7	12	90	ND	Complying	Complying
	08.08.2023	24.07.2023	2308 dt. 01.08.2023	60.97	7.6	48	7.76	14	90	ND	Complying	Complying
	14.09.2023	31.08.2023	2716 dt. 11.09.2023	0.28	7.2	40	7.22	13	80	ND	Complying	Complying
	19.10.2023	29.09.2023	3066 dt. 14.10.2023		9.4	48	7.33	15	80	ND	Complying	Complying
	03.11.2023	10.10.2023	3177 dt. 28.10.2023	27.52	8.6	44	6.98	13	90	ND	Complying	Complying
	05.12.2023	15.11.2023	3497 dt. 28.11.2023		6.2	32	7.13	11	60	ND	Complying	Complying
	18.01.2024	12.12.2023	3840 dt. 22.12.2023		8	44	6.95	13	80	ND	Complying	Complying
	Jan, 2024	11.01.2024	4235 dated 18.01.2024	6166	6.4	36	7.35	13	70	ND	Complying	Complying
	Feb, 2024	20.02.2024	4625 dated 12.03.2024	6751	8	44	6.95	13	90	ND	Complying	Complying
	Mar, 2024	15.03.2024	4977 dated 26.03.2024	7265	6.8	36	7.15	12	60	ND	Complying	Complying
		19.06.2024	431 dt. 02.07.2024		7.2	32	7.04	14		1.13	Complying	Complying
		22.07.2024	719 dt. 30.07.2024		5.6	28	7.23	12			Complying	Complying
		16.08.2024	885 dt. 23.08.2024		7.5	40	7.05	13		1.06	Complying	Complying
		21.10.2024	1321 dt. 29.10.2024		8.5	48	6.84	14		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		14.11.2024	1451 dt. 20.11.2024		14	72	6.18	28		ND	Complying	Complying
		19.12.2024	1735 dt. 30.12.2024		7.5	44	6.98	15		ND	Complying	Complying
4	(YMN-STP-004) 24 MLD STP Parwalo, Yamuna Nagar by PHED in 31.12.2018 (SBR)	27.01.2021	208 dt. 04.02.2021		4.5	28	7.15	7	700	1.22	Complying	Complying
		22.02.2021	436 dt. 04.03.2021		6.8	36	7.52	15	40	1.24	Complying	Complying
		30.03.2021	754 dt. 09.04.2021	698m3/hr	7.4	44	7.89	17	70	0.91	Complying	Complying
		29.04.2021	1005 dt. 12.05.2021		7.8	44	7.1	10	1100	1.88	Complying	Complying
		24.05.2021	1194 dt. 04.06.2021	1501 m3/h	4.6	20	7.93	9	70	1.97	Complying	Complying
	26.07.2021	28.06.2021	1458 dt. 12.07.2021	870 m3/hr	4.2	24	6.96	6	50	2.16	Complying	Complying
	07.09.2021	30.07.2021	1880 dt. 19.08.2021	1612 m3	7.2	32	7.33	12	900	0.2	Complying	Complying
	30.09.2021	25.08.2021	2194 dt. 09.09.2021	1910 m3	5.6	20	6.43	7	3900	0.68	Complying	Complying
	25.10.2021	21.09.2021	2504 dt. 08.10.2021	1096 m3/h	6.8	36	7.46	8	80	2.14	Complying	Complying
	30.11.2021	22.10.2021	2813 dt. 03.11.2021	1527m3/h	5.8	24	7.53	11	40	0.77	Complying	Complying
	24.12.2021	11.11.2021	3012 dt. 24.11.2021	590 m3/hr	8.5	46	7.45	7.45	70	2.14	Complying	Complying
	21.01.2022	16.12.2021	3397 dt. 29.12.2021	722.32m3/hr	6	36	7.44	14	80	2.47	Complying	Complying
		27.01.2022	3922 dt. 08.02.2022	958m3/hr	7.2	44	7.56	14	80	1.85	Complying	Complying
	06.04.2022	24.02.2022	4250 dt. 07.03.2022	727m3/hr	5.6	28	7.87	9	40	0.34	Complying	Complying
	15.04.2022	29.03.2022	4748 dt. 07.04.2022	1070m3/hr	5.2	24	6.99	8	50	N.D.	Complying	Complying
	24.05.2022	22.04.2022	5149 dt. 06.05.2022	850m3/hr	6.6	28	7.12	18	80	0.36	Complying	Complying
	22.06.2022	24.05.2022	5543 dt. 07.06.2022	1337222m3	7.4	44	7.8	16	60	2.88	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	18.07.2022	23.06.2022	5952 dt. 05.07.2022	1850m3/hr	6.2	20	7.75	12	90	1.84	Complying	Complying
	05.08.2022	13.07.2022	6254 dt. 25.07.2022	1538m3/hr	6.5	28	7.46	12	50	1.18	Complying	Complying
	06.09.2022	24.08.2022	6599 dt. 05.09.2022	980.5m3/h	7.5	36	7.18	14	50	1.42	Complying	Complying
	13.10.2022	22.09.2022	6922 dt. 07.10.2022	680m3/h	7.5	40	7.52	13	80	1.24	Complying	Complying
	16.11.2022	26.10.2022	7286 dt. 07.11.2022	4975157m3	5.2	16	7.4	9	50	ND	Complying	Complying
	06.12.2022	10.11.2022	7431-32 dt. 23.11.2022	780m3/hr	6.8	39.6	7.07	14	90	ND	Complying	Complying
	13.01.2023	22.12.2022	7995 dt. 03.01.2023		8.2	40	7.89	17	90	ND	Complying	Complying
	09.02.2023	24.01.2023	226 dt. 02.02.2023	4096977m3	7.5	36	7.89	36	70	ND	Complying	Complying
	13.03.2023	24.02.2023	622 dt. 06.03.2023	750m3/hr	6.5	28	7.52	14	70	ND	Complying	Complying
	13.04.2023	28.03.2023	999 dt. 07.04.2023	4726084m3	7.5	32	7.63	13	70	1.12	Complying	Complying
	05.06.2023	10.05.2023	1450 dt. 23.05.2023		7.2	36	7.18	12	50	1.32	Complying	Complying
	12.07.2023	21.06.2023	1979 dt. 3.07.2023	800m3/hr	6.8	24	6.82	11	80	ND	Complying	Complying
	08.08.2023	24.07.2023	2307 dt. 01.08.2023		8	44	7.17	13	70	ND	Complying	Complying
	14.09.2023	31.08.2023	2719 dt. 11.09.2023		6.2	28	7.28	13	80	ND	Complying	Complying
	19.10.2023	29.09.2023	3067 dt. 14.10.2023	840	5.4	28	7.6	10	50	ND	Complying	Complying
	03.11.2023	11.10.2023	3178 dt. 28.10.2023	792.2	4.8	24	7.24	9	50	ND	Complying	Complying
	18.01.2024	12.12.2023	3841 dt. 22.12.2023		5.8	32	7	11	50	ND	Complying	Complying
	Jan, 2024	11.01.2024	4237 dated 18.01.2024	6170	8.8	48	7.07	13	90	ND	Complying	Complying
	Feb, 2024	21.02.2024	4623 dated 12.03.2024	6747	7	40	6.76	11	80	ND	Complying	Complying
	Mar, 2024	15.03.2024	4978 dated 26.03.2024	7267	8.8	48	6.98	10	90	ND	Complying	Complying
		19.06.2024	432 dt. 02.07.2024		5.8	28	7.18	11		1.32	Complying	Complying
		22.07.2024	720 dt. 30.07.2024		7.6	32	7.12	11		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		16.08.2024	886 dt. 23.08.2024		6.5	36	6.89	11		ND	Complying	Complying
		11.09.2024	1080 dt. 19.09.2024		6.5	36	7.09	17		ND	Complying	Complying
		21.10.2024	1322 dt. 29.10.2024		8	44	7.31	57		ND	Complying	Complying
		14.11.2024	1452 dt. 20.11.2024		8	48	7.86	17		ND	Complying	Complying
		19.12.2024	1736 dt. 30.12.2024		5.8	24	6.85	10		ND	Complying	Complying
5	(YMN-STP-005) 3.5 MLD STP Radaur, Yamuna Nagar by PHED 31.12.2015 (MBBR+TT, 2019)	27.01.2021	209 dt. 04.02.2021		8	44	7.6	11	290	0.22	Complying	Complying
		23.02.2021	434 dt. 04.03.2021		6.4	36	7.48	17	40	1.59	Complying	Complying
		31.03.2021	756 dt. 09.04.2021		7.2	44	7.45	14	20	1.11	Complying	Complying
		29.04.2021	1001 dt. 12.05.2021		5.2	28	7.75	9	400	N.D.	Complying	Complying
		19.05.2021	1168 dt. 02.06.2021		5.2	20	7.26	9	14000	N.D.	Complying	Complying
	26.07.2021	29.06.2021	1462 dt. 12.07.2021		2.6	24	7.64	10	40	2.03	Complying	Complying
	07.09.2021	30.07.2021	1884 dt. 19.08.2021		7	36	7.12	10	940	0.64	Complying	Complying
	30.09.2021	24.08.2021	2196 dt. 09.09.2021		6.8	24	7.16	12	22100	0.77	Complying	Complying
	25.10.2021	21.09.2021	2498 dt. 06.10.2021	90 m3/h	7.2	36	7.23	16	50	2.14	Complying	Complying
	25.11.2021	22.10.2021	2808 dt. 03.11.2021	40.2 m3/h	8	56	7.48	16	20	1.04	Complying	Complying
	24.12.2021	30.11.2021	3166 dt. 13.12.2021	150 m3/h	7.6	44	7.28	9	20	N.D.	Complying	Complying
	21.01.2022	16.12.2021	3396 dt. 29.12.2021	51.15m3/h	6.5	40	7.43	17	400	0.34	Complying	Complying
	08.02.2022	14.01.2022	3705 dt. 25.01.2022	100 m3/hr	6.5	32	7.04	14	400	0.96	Complying	Complying
	06.04.2022	23.02.2022	4237 dt. 04.03.2022		7	44	7.51	13	90	0.12	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	15.04.2022	24.03.2022	4676 dt. 31.03.2022		7.8	48	7.93	15	90	0.64	Complying	Complying
	20.05.2022	15.04.2022	5093 dt. 05.05.2022		8	44	6.8	16	70	1.95	Complying	Complying
	20.06.2022	24.05.2022	5540 dt. 07.06.2022		7.2	48	6.98	16	80	2.42	Complying	Complying
	18.07.2022	23.06.2022	5953 dt. 05.07.2022	1 MLD	16	68	7.35	26	200	1.84	Non-complying	Non-complying
	05.08.2022	13.07.2022	6257 dt. 25.07.2022	1.8	7.2	44	7.68	14	80	2.04	Complying	Complying
	06.09.2022	24.08.2022	6602 dt. 05.09.2022	72.84 M3/	8.2	44	6.85	16	70	ND	Complying	Complying
	13.10.2022	22.09.2022	6996 dt. 07.10.2022	2.10 MLD	8	40	7.26	15	80	2.62	Complying	Complying
	16.11.2022	26.10.2022	7287 dt. 07.11.2022	0.95 MLD	7.5	32	7.89	12	200	0.25	Complying	Complying
	14.12.2022	28.11.2022	7599 dt. 12.12.2022	1.85 MLD	7.2	32	7.54	12	70	ND	Complying	Complying
	16.01.2023	30.12.2022	8094 dt. 11.01.2023	1.90m3/hr	7.5	24	7.26	11	70	ND	Complying	Complying
	09.02.2023	24.01.2023	227 dt. 02.02.2023	140m3/h	7.6	32	7.26	11	80	ND	Complying	Complying
	13.03.2023	24.02.2023	625 dt. 06.03.2023	102m3/hr	8.2	40	7.25	15	90	0.63	Complying	Complying
	17.04.2023	28.03.2023	1002 dt. 17.04.2023	160m3/h	7.8	36	7.29	14.28	-	ND	Complying	Complying
	05.06.2023	10.05.2023	1453 dt. 23.05.2023	146m3/hr	6.5	40	7.11	15	90	ND	Complying	Complying
	12.07.2023	21.06.2023	1986 dt. 3.07.2023	145m3/hr	7.4	28	6.98	13	80	ND	Complying	Complying
	08.08.2023	24.07.2023	2311 dt. 01.08.2023	140 m3/hr	7.8	40	7.07	16	80	ND	Complying	Complying
	14.09.2023	31.08.2023	2719 dt. 11.09.2023		6.5	36	7.3	12	70	ND	Complying	Complying
	19.10.2023	29.09.2023	3068 dt. 14.10.2023	140	6.4	32	7.27	11	70	ND	Complying	Complying
	03.11.2023	11.10.2023	3179 dt. 28.10.2023	140	7.2	36	7.18	11	60	ND	Complying	Complying
	05.12.2023	15.11.2023	3496 dt. 28.11.2023		5.4	28	7.07	10	50	ND	Complying	Complying
	18.01.2024	12.12.2023	3842 dt. 22.12.2023		6.8	36	6.96	12	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	Jan, 2024	11.01.2024	4236 dated 18.01.2024	6168	7.6	40	7.16	14	80	ND	Complying	Complying
	Feb, 2024	21.02.2024	4621 dated 12.03.2024	6743	5.8	32	6.38	10	60	ND	Complying	Complying
	Mar, 2024	15.03.2024	4980 dated 26.03.2024	7271	7	40	7.01	13	80	ND	Complying	Complying
		19.06.2024	433 dt. 02.07.2024		7.6	44	7.2	13		ND	Complying	Complying
		16.08.2024	887 dt. 23.08.2024		7.5	32	7.13	14		ND	Complying	Complying
		11.09.2024	1081 dt. 19.09.2024		6.8	36	6.9	14		ND	Complying	Complying
		21.10.2024	1320 dt. 29.10.2024		8	40	7.01	11		ND	Complying	Complying
		14.11.2024	1453 dt. 20.11.2024		13	68	6.56	31		ND	Complying	Complying
6	(YMN-STP-006) 10 MLD STP Baddimajra , Yamuna Nagar, Unit-I by PHED 30.07.2019 (SBR)	27.01.2021	207 dt. 04.02.2021		6.8	36	7.18	27	1100	1.88	Complying	Complying
		22.02.2021	467 dt. 05.03.2021		6.8	28	7.57	12	Absent	1.24	Complying	Complying
		30.03.2021	752 dt. 09.04.2021	2710 m3	8	46	7.41	9	Absent	1.06	Complying	Complying
		28.04.2021	1003 dt. 12.05.2021		5.4	24	7.46	11	210	0.51	Complying	Complying
		27.05.2021	1209 dt. 08.06.2021		8.2	40	7.28	11	700	1.97	Complying	Complying
	22.07.2021	29.06.2021	1459 dt. 12.07.2021		3.5	20	7.14	7	80	2.04	Complying	Complying
	07.09.2021	30.07.2021	1881 dt. 19.08.2021		4.8	20	7.17	10	700	N.D.	Complying	Complying
	30.09.2021	24.08.2021	2197 dt. 09.09.2021	340 m3	6.4	28	7.14	8	70	0.64	Complying	Complying
	25.10.2021	21.09.2021	2497 dt. 06.10.2021	90 m3/h	3.2	40	7.15	14	70	2.16	Complying	Complying
	25.11.2021	22.10.2021	2809 dt. 03.11.2021	280 m3/h	6.2	28	7.82	15	20	2.83	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	09.12.2021	10.11.2021	2931 dt. 23.11.2021	220m3/hr	7.2	36	7.55	11	300	2.06	Complying	Complying
	21.01.2022	16.12.2021	3395 dt. 29.12.2021	250 m3/h	5.6	44	7.5	14	20	0.57	Complying	Complying
	08.02.2022	18.01.2022	3826 dt. 31.01.2022	100 m3/hr	7	40	7.73	11	200	2.04	Complying	Complying
	06.04.2022	23.02.2022	4240 dt. 04.03.2022		7.5	40	7.33	15	Absent	1.29	Complying	Complying
	15.04.2022	24.03.2022	4675 dt. 31.03.2022		8	48	7.32	17	50	0.77	Complying	Complying
	17.05.2022	15.04.2022	5091 dt. 05.05.2022		8.2	48	6.7	18	70	1.84	Complying	Complying
	20.06.2022	24.05.2022	5541 dt. 07.06.2022		7.6	44	6.7	15	90	2.11	Complying	Complying
	20.07.2022	23.06.2022	5957 dt. 05.07.2022	4.24MLD	6.5	28	7.56	10	90	2.39	Complying	Complying
	08.08.2022	13.07.2022	6255 dt. 25.07.2022	2119m3	6.8	32	8.06	13	80	1.38	Complying	Complying
	06.09.2022	24.08.2022	6603 dt. 05.09.2022	1440 LPM	7.8	36	7	17	50	ND	Complying	Complying
	13.10.2022	22.09.2022	6993 dt. 07.10.2022	4470m3/h	15	92	7.62	88	500	2.72	Non-complying	Non-complying
	16.11.2022	26.10.2022	7288 dt. 07.11.2022	1040 m3	7.5	40	7.95	14	70	0.19	Complying	Complying
	14.12.2022	28.11.2022	7600 dt. 12.12.2022	93.3 LPM	7	28	7.72	10	80	0.74	Complying	Complying
	13.01.2023	22.12.2022	7992 dt. 03.01.2023	458.5m3/h	7.8	40	7.4	15	90	1.22	Complying	Complying
	09.02.2023	24.01.2023	230 dt. 02.02.2023	5729m3/h	7.6	40	8.24	14	90	ND	Complying	Complying
	13.03.2023	24.02.2023	626 dt. 06.03.2023	4060m3/hr	7.8	40	7.56	16	80	ND	Complying	Complying
	17.04.2023	28.03.2023	1004 dt. 7.04.2023	3254m3/h	8	40	7.37	16	80	ND	Complying	Complying
	05.06.2023	10.05.2023	1454 dt. 23.05.2023	3602m3/hr	8	44	7.1	16	80	ND	Complying	Complying
	12.07.2023	21.06.2023	1981 dt. 3.07.2023	27271321m	6.2	32	7	13	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	08.08.2023	24.07.2023	2312 dt. 01.08.2023	15437491	7.5	44	7.25	13	80	ND	Complying	Complying
	14.09.2023	31.08.2023	2720 dt. 11.09.2023	20247034	5.8	24	7.28	11	70	0.36	Complying	Complying
	19.10.2023	29.09.2023	3069 dt. 14.10.2023		7.6	40	7.5	13	80	ND	Complying	Complying
	03.11.2023	11.10.2023	3180 dt. 28.10.2023		6.4	32	7.25	10	50	ND	Complying	Complying
	18.01.2024	12.12.2023	3844 dt. 22.12.2023		7.2	40	6.9	13	80	ND	Complying	Complying
	Jan, 2024	11.01.2024	4233 dated 18.01.2024	6162	5.8	32	7.28	10	60	ND	Complying	Complying
	Feb, 2024	21.02.2024	4626 dated 12.03.2024	6753	5.8	32	6.65	11	50	ND	Complying	Complying
	Mar, 2024	15.03.2024	4982 dated 26.03.2024	7276	5.8	32	6.92	12	60	ND	Complying	Complying
		19.06.2024	435 dt. 02.07.2024		5	28	6.89	10		ND	Complying	Complying
		22.07.2024	718 dt. 30.07.2024		5.2	24	6.97	11		ND	Complying	Complying
		16.08.2024	888 dt. 23.08.2024		6.8	44	7.19	15		1.06	Complying	Complying
		11.09.2024	1083 dt. 19.09.2024		7.6	44	7.06	15		ND	Complying	Complying
		21.10.2024	1318 dt. 29.10.2024		7.2	44	7.12	17		ND	Complying	Complying
		14.11.2024	1447 dt. 20.11.2024		6.8	32	6.84	14		ND	Complying	Complying
		19.12.2024	1733 dt. 30.12.2024		7.5	48	6.45	14		ND	Complying	Complying
7	(YMN-STP-007) 10 MLD STP at Baddimajra, Unit-II, Yamuna Nagar by PHED dt. 31.07.2021	24.01.2023 (Uploaded dt. 09.02.2023)	231 dt. 02.02.2023		8.2	44	7.28	15	50	ND	Complying	Complying
	13.03.2023	24.02.2023	627 dt. 06.03.2023		7.6	48	7.32	14	90	ND	Complying	Complying
	28.04.2023	28.03.2023	1001 dt. 17.04.2023		7.2	28	7.24	15	90	ND	Complying	Complying
	05.06.2023	10.05.2023	1455 dt. 23.05.2023		6.8	32	7.05	12	90	ND	Complying	Complying
	12.07.2023	21.06.2023	1982 dt. 3.07.2023		6	24	6.7	12	80	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	08.08.2023	24.07.2023	2313 dt. 01.08.2023		7.2	48	7.46	14	80	ND	Complying	Complying
	14.09.2023	31.08.2023	2721 dt. 11.09.2023	49203m3/h	7.5	48	7.62	13	90	0.36	Complying	Complying
	19.10.2023	29.09.2023	3070 dt. 14.10.2023	4872	6.2	32	7.37	13	60	ND	Complying	Complying
	03.11.2023	11.10.2023	3181 dt. 28.10.2023		5.4	28	7.34	10	50	ND	Complying	Complying
	18.01.2024	12.12.2023	3845 dt. 22.12.2023		6.4	36	7	13	60	ND	Complying	Complying
	Jan, 2024	11.01.2024	4240 dated 18.01.2024	6176	5.6	32	7.54	10	60	ND	Complying	Complying
	Feb, 2024	21.02.2024	4627 dated 12.03.2024	6755	5	28	6.69	10	50	ND	Complying	Complying
	Mar, 2024	15.03.2024	4983 dated 26.03.2024	7278	8	44	6.8	10	80	ND	Complying	Complying
		19.06.2024	436 dt. 02.07.2024		6.5	32	7.01	14		1.34	Complying	Complying
		22.07.2024	717 dt. 30.07.2024		7.2	28	7	12		ND	Complying	Complying
		16.08.2024	889 dt. 23.08.2024		6.5	32	7.27	13		ND	Complying	Complying
		11.09.2024	1084 dt. 19.09.2024		7	40	6.65	13		ND	Complying	Complying
		21.10.2024	1319 dt. 29.10.2024		6.8	40	7.12	11		ND	Complying	Complying
		14.11.2024	1448 dt. 20.11.2024		5.6	28	6.68	12		ND	Complying	Complying
		19.12.2024	1734 dt. 30.12.2024		7.2	40	6.87	13		ND	Complying	Complying
8	(YMN-STP-008) 2.5 MLD, Saraswati Nagar (Mustafabad) by PHED, Yamunavnagar		273 dated 23.05.2024		4	24	6.89	10		ND	Complying	Complying
		19.06.2024	428 dt. 02.07.2024		5.8	28	7.35	13		ND	Complying	Complying
		16.08.2024	890 dt. 23.08.2024		7	44	7.06	16		0.92	Complying	Complying
		11.09.2024	1082 dt. 19.09.2024		5.8	40	7.38	14		ND	Complying	Complying
		21.10.2024	1315 dt. 29.10.2024		7	44	6.98	16		ND	Complying	Complying
		14.11.2024	1446 dt. 20.11.2024		6.8	32	6.47	12		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		19.12.2024	1732 dt. 30.12.2024		7.8	44	6.84	15		ND	Complying	Complying
	Karnal											
9	(KRN-STP-11) 50 MLD STP, Transport Nagar, Karnal by ULBD in 31.08.2020 (SBR)		W-10/2020-21/10 and W-9/2020-21/09 dt. 22.01.2021		95.0	290.0	6.35	110.0			Non-complying	Non-complying
		04.02.2021	297 dt. 12.02.2021		7.0	40.0	7.8	16.0	430.0	5.5	Complying	Complying
		02.03.2021	502 dt. 12.03.2021		6.8	44.0	8.0	11.0	490.0	0.2	Complying	Complying
		09.04.2021	904 dt. 23.04.2021		5.2	28.0	7.2	12.0	490.0	0.8	Complying	Complying
		18.05.2021	1147 dt. 01.06.2021	2365 m3/h	7.8	44.0	7.4	7.0	2100.0	N.D.	Complying	Complying
		10.06.2021	1325 dt. 21.06.2021		6.5	28.0	8.5	8.0	330.0	0.6	Complying	Complying
	07.09.2021	08.07.2021	1588 dt. 19.07.2021	42742 m3	7.8	40.0	7.6	10.0	1100.0	2.0	Complying	Complying
	30.09.2021	19.08.2021	2176 dt. 06.09.2021	40.8	9.0	48.0	7.4	13.0	4600.0	1.9	Complying	Complying
	25.10.2021	15.09.2021	2445 dt. 04.10.2021	17830 m3	6.5	28.0	8.5	12.0	10900.0	2.0	Complying	Complying
	25.11.2021	08.10.2021	2680 dt. 22.10.2021	48690 m2	7.4	40.0	7.1	11.0	700.0	1.0	Complying	Complying
	09.12.2021	15.11.2021	3039 dt. 26.11.2021	2943.55m3	7.4	44.0	7.8	11.0	90.0	0.2	Complying	Complying
	19.12.2022	17.12.2021	3405 dt. 29.12.2021	16687m3/h	4.2	40.0	7.6	12.0	Absent	N.D.	Complying	Complying
	09.02.2022	13.01.2022	3694 dt. 25.01.2022	23252m3	6.8	32.0	8.5	10.0	Absent	N.D.	Complying	Complying
	05.04.2022	14.02.2022	4166 dt. 24.02.2022	3.076 MLD	2.6	16.0	8.0	8.0	90.0	N.D.	Complying	Complying
	13.04.2022	10.03.2022	4542 dt. 25.03.2022	2275m3/hr	6.2	36.0	8.3	16.0	30.0	N.D.	Complying	Complying
	17.05.2022	11.04.2022	4988 dt. 28.04.2022	39338 m^3	5.8	28.0	8.0	12.0	80.0	0.3	Complying	Complying
	07.06.2022	13.05.2022	5443 dt. 27.05.2022	1579m^3/h	7.0	32.0	7.3	9.0	90.0	1.0	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	05.07.2022	07.06.2022	5693 dt. 20.06.2022	2533m3/h	4.6	28.0	6.4	9.0	Absent	1.6	Complying	Complying
	05.08.2022	13.07.2022	6225 dt. 21.07.2022	3388 m3/h	7.0	32.0	7.4	11.0	90.0	0.1	Complying	Complying
	05.09.2022	16.08.2022	6554 dt. 25.08.2022	1717.63m3	7.2	32.0	7.2	12.0	200.0	3.2	Complying	Complying
	28.09.2022	07.09.2022	6726 dt. 16.09.2022	3407m3/hr	8.5	48.0	5.2	17.0	90.0	1.1	Complying	Complying
	09.11.2022	11.10.2022	7221 dt. 21.10.2022	3048m3/h	7.2	32.0	7.0	13.0	50.0	ND	Complying	Complying
	29.11.2022	15.11.2022	7461 dt. 28.11.2022	1203m3/h	6.2	27.0	7.8	9.0	80.0	0.5	Complying	Complying
	05.01.2023	14.12.2022	7896 dt. 23.12.2022	2666m3/h	7.2	44.0	7.3	14.0	90.0	1.3	Complying	Complying
	24.01.2023	11.01.2023	93 dt. 23.01.2023	1230m3/h	7.8	44.0	5.7	15.0	80.0	ND	Complying	Complying
	02.03.2023	17.02.2023	548 dt. 27.02.2023		7.8	40.0	6.1	14.0	80.0	ND	Complying	Complying
	11.04.2023	21.03.2023	919 dt. 29.03.2023	2547 m3/h	7.8	44.0	7.6	14.0	70.0	ND	Complying	Complying
	04.05.2023	20.04.2023	1300 dt. 01.05.2023	2714m3/h	8.0	48.0	2.8	14.0	90.0	ND	Complying	Complying
	12.06.2023	24.05.2023	1626 dt. 01.06.2023	1120m3/hr	7.6	28	6.53	13	80	ND	Complying	Complying
	24.06.2023	09.06.2023	1819 dt. 16.06.2023	2136m3	7.5	28	7.88	12	80	1.2	Complying	Complying
	08.08.2023	20.07.2023	2301 dt. 28.07.2023	922 m3/hr	6.8	40	7.68	12	80	ND	Complying	Complying
	25.08.2023	11.08.2023	2490 dt. 21.08.2023	2130m3/hr	7	36	7.07	11	80	ND	Complying	Complying
	29.09.2023	15.09.2023	2828 dt. 29.09.2023		5.8	28	7.01	10	50	ND	Complying	Complying
	10.11.2023	27.10.2023	3368 dt. 07.11.2023		7.2	36	6.7	11	60	ND	Complying	Complying
	14.12.2023	22.11.2023	3637 dt. 01.12.2023		4	20	7.54	10	50	ND	Complying	Complying
	18.01.2024	12.12.2023	3877 dt. 22.12.2023		6	32	6.78	12	60	ND	Complying	Complying
		24.01.2024	4314 dt. 31.01.2024		5.6	32	7.2	11	60	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		21.02.2024	4643 dt. 12.03.2024		7.2	40.0	6.7	13.0	60.0	ND	Complying	Complying
		23.05.2024	293 dt. 31.05.2024		7.6	40	7.01	11	80	ND	Complying	Complying
		26.07.2024	749 dt. 06.08.2024		5.6	28.0	7.4	10.0		ND	Complying	Complying
		30.08.2024	989 dt. 09.09.2024		7.5	48.0	6.8	12.0		ND	Complying	Complying
		12.09.2024	1094 dt. 20.09.2024		6.5	32.0	7.2	11.0		ND	Complying	Complying
		28.10.2024	1354 dt. 06.11.2024		5.2	40.0	6.9	13.0		ND	Complying	Complying
		14.11.2024	1456 dt. 21.11.2024		7.8	48.0	6.9	13.0		ND	Complying	Complying
10	(KRN-STP-003) 8 MLD STP RK Puram Karnal by ULBD in March dt. 31.10.2019 (SBR)	03.01.2021	10 dt. 14.01.2021		5.4	28	7.64	14	400	1.91	Complying	Complying
		03.02.2021	300 dt. 12.02.2021		7	44	7.54	10	4260	6.46	Complying	Complying
		02.03.2021	501 dt. 12.03.2021		7.6	48	7.46	18	3480	0.21	Complying	Complying
		02.04.2021	766 dt. 12.04.2021		6.2	24	7.89	10	490	1.14	Complying	Complying
		18.05.2021	1153 dt. 01.06.2021		8	44	7.15	7	1700	N.D.	Complying	Complying
		10.06.2021	1326 dt. 21.06.2021		7.8	44	8.15	12	700	0.38	Complying	Complying
	07.09.2021	20.07.2021	1723 dt. 30.07.2021	2098 m3	7.8	44	7.24	14	700	2.28	Complying	Complying
	24.09.2021	14.08.2021	2086 dt. 31.08.2021		7.4	44	7.34	11	2100	2.14	Complying	Complying
	25.10.2021	15.09.2021	2444 dt. 04.10.2021	565.68m3	6.5	48	8	12	3100	1.24	Complying	Complying
	30.11.2021	22.10.2021	2817 dt. 09.11.2021	2.0 MLD	6	24	7.67	12	200	0.64	Complying	Complying
	09.12.2021	15.11.2021	3038 dt. 26.11.2021	7.384m3/h	6.8	40	7.68	12	70	2.37	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	19.01.2022	17.12.2021	3406 dt. 29.12.2021		7.5	48	7.86	15	400	N.D.	Complying	Complying
	09.02.2022	13.01.2022	3695 dt. 25.01.2022		7.8	48	6.8	14	40	1.97	Complying	Complying
	05.04.2022	14.02.2022	4163 dt. 24.02.2022	7.565m3/h	2.8	16	7.92	7	Absent	0.77	Complying	Complying
	13.04.2022	10.03.2022	4539 dt. 25.03.2022	350 m3/hr	7.6	36	7.63	13	Absent	N.D.	Complying	Complying
	17.05.2022	11.04.2022	4989 dt. 28.04.2022	399 m^3/h	7.5	32	7.03	13	80	0.19	Complying	Complying
	08.06.2022	13.05.2022	5446 dt. 27.05.2022		7.6	40	7.27	15	90	1.92	Complying	Complying
	05.07.2022	07.06.2022	5694 dt. 20.06.2022	115m3/h	6.5	32	7.2	11	90	1.86	Complying	Complying
	05.08.2022	13.07.2022	6227 dt. 21.07.2022	437m3/h	6.5	28	7.98	11	60	1.23	Complying	Complying
	05.09.2022	16.08.2022	6556 dt. 25.08.2022	725 m3/h	5.8	28	7.03	11	50	2.39	Complying	Complying
	28.09.2022	07.09.2022	6728 dt. 16.09.2022	465m3/h	7.5	40	7.74	15	90	1.02	Complying	Complying
	09.11.2022	11.10.2022	7219 dt. 21.10.2022	644m3/h	7.2	44	7.06	15	80	1.12	Complying	Complying
	29.11.2022	15.11.2022	7458 dt. 28.11.2022	746m3/h	7	36	7.78	12	90	0.92	Complying	Complying
	05.01.2023	14.12.2022	7895 dt. 23.12.2022	699m3/h	7.5	40	7.02	15	80	1.2	Complying	Complying
	24.01.2023	11.01.2023	92 dt. 23.01.2023		8	48	7.5	16	70	ND	Complying	Complying
	02.03.2023	17.02.2023	549 dt. 27.02.2023		7.6	36	7.7	13	90	ND	Complying	Complying
	11.04.2023	21.03.2023	918 dt. 29.03.2023	405m3/hr	8.2	36	7.67	13	80	ND	Complying	Complying
	04.05.2023	20.04.2023	1301 dt. 01.05.2023	321m3/h	7	36	7.12	13	70	ND	Complying	Complying
	12.06.2023	24.05.2023	1628 dt. 01.06.2023	397m3/hr	6.8	24	7.18	11	70	ND	Complying	Complying
	24.06.2023	09.06.2023	1820 dt. 16.06.2023	518m3	6.2	32	7.51	15	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	08.08.2023	20.07.2023	2302 dt. 28.07.2023	224m3/hr	7.2	36	6.49	11	90	ND	Complying	Complying
	25.08.2023	11.08.2023	2491 dt. 21.08.2023	760m3/hr	6.2	28	6.79	12	50	ND	Complying	Complying
	29.09.2023	15.09.2023	2831 dt. 29.09.2023		7	36	7.08	12	80	ND	Complying	Complying
	10.11.2023	27.10.2023	3369 dt. 07.11.2023		7.8	44	6.86	15	80	ND	Complying	Complying
	14.12.2023	22.11.2023	3635 dt. 01.12.2023		4.8	24	7.35	10	50	ND	Complying	Complying
	18.01.2024	12.12.2023	3876 dt. 22.12.2023		7.8	44	6.68	13	80	ND	Complying	Complying
		23.01.2024	4295 dt. 30.01.2024		4.8	28	7.5	10	50	ND	Complying	Complying
		21.02.2024	4646 dt. 12.03.2024		5	28	6.6	10	60	ND	Complying	Complying
		23.05.2024	292 dt. 31.05.2024		7.5	48	6.88	13	90	ND	Complying	Complying
		26.07.2024	753 dt. 06.08.2024		7.2	40	7.07	12		ND	Complying	Complying
		30.08.2024	986 dt. 09.09.2024		7.2	32	7.76	15		ND	Complying	Complying
		12.09.2024	1097 dt. 20.09.2024		7.6	44	7.08	13		ND	Complying	Complying
		28.10.2024	1358-A dt. 06.11.2024		5.6	32	7.33	12		ND	Complying	Complying
		14.11.2024	1461 dt. 21.11.2024		7	48	6.94	15		ND	Complying	Complying
11	(KRN-STP-004) 7 MLD STP Gharaunda , Karnal by PHED in March 31.05.2019 (SBR)	03.01.2021	7 dt. 14.01.2021		7	46	7.84	7	270	2.42	Complying	Complying
		03.02.2021	298 dt. 12.02.2021		8	44	7.44	15	20	1.29	Complying	Complying
		10.03.2021	652 dt. 24.03.2021	245 m3	7.4	32	7.65	10	40	0.45	Complying	Complying
		09.04.2021	905 dt. 27.04.2021		5.2	28	6.97	10	580	3.4	Complying	Complying
		18.05.2021	1145 dt. 01.06.2021	5777 m3	7.6	44	7.28	17	1100	N.D.	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		09.06.2021	1327 dt. 21.06.2021		4.6	24	8.47	11	340	N.D.	Complying	Complying
	07.09.2021	20.07.2021	1719 dt. 30.07.2021	4.5 MLD	7.5	36	7.56	12	1100	1.29	Complying	Complying
	24.09.2021	13.08.2021	2089 dt. 31.08.2021	1750 m3	7.6	40	7.32	12	1100	N.D.	Complying	Complying
	25.10.2021	15.09.2021	2448 dt. 04.10.2021	260 m3/hr	5	28	8.17	12	Absent	2.14	Complying	Complying
	25.11.2021	08.10.2021	2679 dt. 22.10.2021	320 m3/hr	7.5	44	8.48	13	700	0.68	Complying	Complying
	24.12.2021	29.11.2021	3155 dt. 10.12.2021		7	44	7.78	12	90	1.32	Complying	Complying
	19.01.2022	09.12.2021	3280 dt. 20.12.2021		7	48	7.29	12	60	1.84	Complying	Complying
	09.02.2022	13.01.2022	3691 dt. 25.01.2022		6.2	24	7	10	40	N.D.	Complying	Complying
	05.04.2022	10.02.2022	4141 dt. 18.02.2022	3370m3	6.2	28	7.49	11	60	0.76	Complying	Complying
	13.04.2022	11.03.2022	4544 dt. 25.03.2022	466.3 m3	8	44	7.94	16	70	4.85	Complying	Complying
	08.06.2022	13.05.2022	5445 dt. 27.05.2022	263m^3/h	8	48	6.98	16	70	1.95	Complying	Complying
	05.07.2022	07.06.2022	5688 dt. 20.06.2022	312m3/h	7.6	44	7.21	11	90	0.28	Complying	Complying
	05.08.2022	13.07.2022	6226 dt. 21.07.2022	347 m3/h	6.8	28	7.95	10	80	1.02	Complying	Complying
	05.09.2022	16.08.2022	6555 dt. 25.08.2022	4.2 MLD	8	40	7.21	16	90	0.22	Complying	Complying
	28.09.2022	07.09.2022	6727 dt. 16.09.2022	3407m3/hr	7.8	40	7.86	14	80	2.04	Complying	Complying
	09.11.2022	12.10.2022	7220 dt. 21.10.2022	4.2 MLD	7.5	36	7.03	12	70	0.32	Complying	Complying
	29.11.2022	15.11.2022	7460 dt. 28.11.2022	252m3/h	7.4	28	7.59	10	70	0.82	Complying	Complying
	07.12.2022	25.11.2022	7565 dt. 07.12.2022	227m3/hr	7.6	44	7.36	14	90	1.18	Complying	Complying
	05.01.2023	14.12.2022	7897 dt. 23.12.2022	282m3/h	7.8	40	7	15	90	0.35	Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
24.01.2023	11.01.2023	91 dt. 23.01.2023	262m3/h	7.6	44	7.7	14	90	1.24	Complying	Complying
02.03.2023	17.02.2023	547 dt. 27.02.2023		8	36	7.88	15	50	ND	Complying	Complying
11.04.2023	21.03.2023	917 dt. 29.03.2023	298m3/h	7.8	48	7.6	15	90	ND	Complying	Complying
04.05.2023	20.04.2023	1299 dt. 01.05.2023	362 m3/h	7.6	40	7.24	12	90	ND	Complying	Complying
12.06.2023	24.05.2023	1627 dt. 01.06.2023	341m3/hr	7	44	7.15	15	90	ND	Complying	Complying
24.06.2023	09.06.2023	1821 dt. 16.06.2023	312m3/hr	6.4	28	7.52	11	80	ND	Complying	Complying
08.08.2023	20.07.2023	2303 dt. 28.07.2023	752m3/hr	8	36	6.59	17	80	ND	Complying	Complying
25.08.2023	11.08.2023	2492 dt. 21.08.2023	310m3/hr	7.5	32	6.78	12	90	ND	Complying	Complying
29.09.2023	15.09.2023	2829 dt. 29.09.2023		7.2	36	7.06	12	60	ND	Complying	Complying
10.11.2023	27.10.2023	3366 dt. 07.11.2023		7.8	44	6.75	12	80	ND	Complying	Complying
14.12.2023	22.11.2023	3641 dt. 01.12.2023		7.6	40	7.08	13	70	ND	Complying	Complying
22.12.2023	06.12.2023	3804 dt. 19.12.2023		7.6	40	7.33	13	80	ND	Complying	Complying
	24.01.2024	4112dt. 11.01.2024		7	40	7.2	12	80	ND	Complying	Complying
	21.02.2024	4650 dt. 12.03.2024		5.8	32	6.6	10	50	ND	Complying	Complying
	17.05.2024	261 dt. 23.05.2024		6	40	6.94	10	70	ND	Complying	Complying
	26.07.2024	758 dt. 06.08.2024		7.8	40	7.01	13		ND	Complying	Complying
	14.08.2024	873 dt. 21.08.2024		6.8	40	8.32	15		ND	Complying	Complying
	10.09.2024	1057 dt. 18.09.2024		6.2	32	6.96	11		ND	Complying	Complying
	15.10.2024	1268 dt. 24.10.2024		7.2	44	7.1	11		ND	Complying	Complying
	12.11.2024	1426 dt. 19.11.2024		5.6	28	6.95	11		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
12	(KRN-STP-005) 10 MLD STP at Gogari Road, Karnal by ULBD on 01.03.2018 (SBR)	03.01.2021	8 dt. 14.01.2021		5.8	28	7.65	10	1700	0.7	Complying	Complying
		03.02.2021	299 dt. 12.02.2021		7	32	7.34	13	140	1.44	Complying	Complying
		02.03.2021	503 dt. 12.03.2021		5.8	36	7.74	13	90	0.45	Complying	Complying
		09.04.2021	906 dt. 27.04.2021		5	24	6.7	10	120	2.6	Complying	Complying
		18.05.2021	1149 dt. 01.06.2021	2694 m3	6.2	24	7.82	7	1100	2.76	Complying	Complying
		10.06.2021	1321 dt. 21.06.2021		7.2	36	8.4	9	430	2.83	Complying	Complying
	07.09.2021	20.07.2021	1722 dt. 30.07.2021	9043	7.5	40	7.52	10	700	2.42	Complying	Complying
	24.09.2021	13.08.2021	2087 dt. 31.08.2021	5.9 MLD	6.8	36	7.27	13	1700	N.D.	Complying	Complying
	25.10.2021	09.09.2021	2387 dt. 29.09.2021	6.5 MLD	4	24	8.79	10	80	N.D.	Complying	Complying
	30.11.2021	22.10.2021	2819 dt. 09.11.2021	894.55m3/	7.2	40	7.49	11	500	0.64	Complying	Complying
	09.12.2021	15.11.2021	3037 dt. 26.11.2021	6.62	9	56	7.25	16	80	1.04	Complying	Complying
	19.01.2022	17.12.2021	3404 dt. 29.12.2021	4 MLD	3.5	40	7.6	16	Absent	0.11	Complying	Complying
	09.02.2022	13.01.2022	3688 dt. 21.01.2022	5 MLD	7.5	48	7.2	11	70	1.04	Complying	Complying
	05.04.2022	14.02.2022	4164 dt. 24.02.2022		6.8	32	7.64	9	90	0.85	Complying	Complying
	13.04.2022	10.03.2022	4540 dt. 25.03.2022	-	7.8	48	7.7	15	Absent	1.85	Complying	Complying
	17.05.2022	11.04.2022	4990 dt. 28.04.2022	616 m ³ /h	8	48	7.01	17	80	0.17	Complying	Complying
	08.06.2022	13.05.2022	5444 dt. 27.05.2022		6.8	44	7.1	10	80	0.46	Complying	Complying
	05.07.2022	07.06.2022	5687 dt. 20.06.2022	3866m ³	7.5	48	7.2	12	absent	2.5	Complying	Complying
	05.08.2022	13.07.2022	6228 dt. 21.07.2022	4.25 MLD	6	20	8.23	9	50	0.83	Complying	Complying
	05.09.2022	16.08.2022	6553 dt. 25.08.2022	922 m ³ /h	7.8	32	7.03	14	80	0.88	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	28.09.2022	07.09.2022	6725 dt. 16.09.2022	713m3/hr	8.2	44	7.56	14	50	0.98	Complying	Complying
	09.11.2022	11.10.2022	7218 dt. 21.10.2022	725m3/h	7.5	40	6.79	16	90	1.22	Complying	Complying
	29.11.2022	15.11.2022	7439 dt. 28.11.2022	615m3/h	7.8	48	7.75	13	80	1.15	Complying	Complying
	05.01.2023	14.12.2022	7894 dt. 23.12.2022	607m3/h	7.2	36	7.01	14	70	0.23	Complying	Complying
	24.01.2023	11.01.2023	90 dt. 23.01.2023	327m3/h	7.2	28	7.5	13	80	ND	Complying	Complying
	02.03.2023	17.02.2023	550 dt. 27.02.2023		7.2	32	7.14	14	80	ND	Complying	Complying
	11.04.2023	21.03.2023	920 dt. 29.03.2023	350 m3/hr	8.5	44	7.6	15	70	ND	Complying	Complying
	04.05.2023	20.04.2023	1298 dt. 01.05.2023		7.8	44	7.16	11	80	ND	Complying	Complying
	12.06.2023	24.05.2023	1625 dt. 01.06.2023	315m3/hr	7.5	40	7.15	16	80	ND	Complying	Complying
	24.06.2023	09.06.2023	1822 dt. 16.06.2023	340m3/hr	6.8	32	7.61	13	80	ND	Complying	Complying
	08.08.2023	20.07.2023	2300 dt. 28.07.2023	355m3/hr	6.8	28	6.59	11	80	ND	Complying	Complying
	25.08.2023	11.08.2023	2493 dt. 21.08.2023	370m3/hr	6.8	36	6.7	13	80	ND	Complying	Complying
	29.09.2023	15.09.2023	2830 dt. 29.09.2023		5.6	28	7.01	10	50	ND	Complying	Complying
	10.11.2023	27.10.2023	3367 dt. 07.11.2023		8	40	6.6	15	90	ND	Complying	Complying
	14.12.2023	22.11.2023	3636 dt. 01.12.2023		6.8	36	7.43	13	50	ND	Complying	Complying
	18.01.2024	12.12.2023	3880 dt. 20.12.2023		8.8	48	6.77	14	80	ND	Complying	Complying
		24.01.2024	4313 dt. 31.01.2024		8.4	48	7.24	13			Complying	Complying
		21.02.2024	4644 dt. 12.03.2024		5.8	32	6.7	10	60	ND	Complying	Complying
		23.05.2024	290 dt. 31.05.2024		7	32	6.98	12	80	0.82	Complying	Complying
		26.07.2024	751 dt. 06.08.2024		7	36	7.13	15		ND	Complying	Complying
		30.08.2024	987 dt. 09.09.2024		7.2	36	6.96	15		ND	Complying	Complying
		12.09.2024	1099 dt. 20.09.2024		6.8	40	7.16	17		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		28.10.2024	1355 dt. 06.11.2024		5	28	6.9	12		ND	Complying	Complying
		14.11.2024	1455 dt. 21.11.2024		6.2	36	7.14	14		ND	Complying	Complying
13	(KRN-STP-012) 4 MLD STP Indri, Karnal by PHED in April, 2021 (SBR)	18.05.2021	1152 dt. 01.06.2021	18891 m3	7.5	40	7.28	6	2200	N.D.	Complying	Complying
		09.06.2021	1328 dt. 21.06.2021		7.2	40	8.49	7	340	1.32	Complying	Complying
	07.09.2021	20.07.2021	1724 dt. 30.07.2021	2725 m3	7.5	40	7.5	14	1100	N.D.	Complying	Complying
	24.09.2021	13.08.2021	2088 dt. 31.08.2021	0.26 MLD	6.2	32	7.24	10	1400	N.D.	Complying	Complying
	25.10.2021	21.09.2021	2501 dt. 08.10.2021	86829.6m3	8	36	7.82	16	9400	2.83	Complying	Complying
	30.11.2021	22.10.2021	2818 dt. 09.11.2021	134.4m3/h	4.5	16	7.64	10	200	N.D.	Complying	Complying
	24.12.2021	29.11.2021	3156 dt. 10.12.2021	131.12m3/h	4.2	16	7.89	12	70	2.38	Complying	Complying
	19.01.2022	17.12.2021	3403 dt. 29.12.2021		6.4	40	6.56	3.6	Absent	1.61	Complying	Complying
	09.02.2022	13.01.2022	3692 dt. 25.01.2022	5 MLD	7.5	32	7.09	12	40	2.3	Complying	Complying
	05.04.2022	14.02.2022	4167 dt. 24.02.2022	2.2	4.2	24	7.81	8	Absent	0.12	Complying	Complying
	13.04.2022	10.03.2022	4543 dt. 25.03.2022	0.22 m3/h	7.5	40	7.55	14	80	0.68	Complying	Complying
	17.05.2022	15.04.2022	5087 dt. 05.05.2022		8	44	7	16	80	0.97	Complying	Complying
	08.06.2022	13.05.2022	5449 dt. 27.05.2022	125m^3/h	7.5	44	6.84	17	80	1.87	Complying	Complying
	05.07.2022	07.06.2022	5692 dt. 20.06.2022	222490.7	7.2	40	6.77	13	absent	1.31	Complying	Complying
	05.08.2022	13.07.2022	6229 dt. 21.07.2022		5.6	24	7.98	8	70	1.06	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	05.09.2022	16.08.2022	6559 dt. 25.08.2022	107.56	6.8	28	6.89	13	90	1.38	Complying	Complying
	28.09.2022	07.09.2022	6723 dt. 16.09.2022	108.61m3/	8	48	7.19	16	80	2.33	Complying	Complying
	16.11.2022	19.10.2022	7259 dt. 28.10.2022	130.28m3	8	44	7.02	15	80	1.24	Complying	Complying
	05.12.2022	18.11.2022	7497 dt. 30.11.2022	393.99	6.5	28	7.8	13	90	1.32	Complying	Complying
	07.12.2022	25.11.2022	7564 dt. 07.12.2022		8	40	7.1	15	80	1.23	Complying	Complying
	05.01.2023	16.12.2022	7936 dt. 27.12.2022	132m3/hr	5.4	24	7.2	11	50	1.28	Complying	Complying
	01.02.2023	20.01.2023	201 dt. 31.01.2023		7.5	40	7.98	13	90	ND	Complying	Complying
	02.03.2023	10.02.2023	499 dt. 21.02.2023		7.8	44	7.45	14	90	ND	Complying	Complying
	21.03.2023	03.03.2023	763 dt. 15.03.2023		6.8	32	7.12	11	80	ND	Complying	Complying
	04.05.2023	21.04.2023	1304 dt. 01.05.2023		7.2	44	7.08	16	90	1.22	Complying	Complying
	12.06.2023	24.05.2023	1621 dt. 01.06.2023	192789m3/	6.8	24	7.17	11	90	ND	Complying	Complying
	24.06.2023	09.06.2023	1818 dt. 16.06.2023	1590705m3	7.4	40	7.73	13	70	ND	Complying	Complying
	14.08.2023	25.07.2023	2341 dt. 02.08.2023		7.2	28	7.46	12	90	ND	Complying	Complying
	25.08.2023	10.08.2023	2485 dt. 21.08.2023		7.8	44	6.84	17	90	ND	Complying	Complying
	18.10.2023	28.09.2023	3058 dt. 14.10.2023		8	44	7.49	16	80	ND	Complying	Complying
	10.11.2023	27.10.2023	3372 dt. 07.11.2023		8	44	6.49	15	90	ND	Complying	Complying
	14.12.2023	22.11.2023	3640 dt. 01.12.2023		5.4	28	7.35	11	50	ND	Complying	Complying
	18.01.2024	12.12.2023	3878 dt. 22.12.2023		7.2	40	6.87	13	80	ND	Complying	Complying
		24.01.2024	4293 dt. 30.01.2024		8.6	48	7.4	11	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		21.02.2024	4642 dt. 12.03.2024		6.8	36	6.4	11	70	ND	Complying	Complying
		23.05.2024	288 dt. 31.05.2024		7.5	40	6.96	13	70	ND	Complying	Complying
		26.07.2024	750 dt. 06.08.2024		6.5	44	7.2	15		ND	Complying	Complying
		30.08.2024	985 dt. 09.09.2024		7.6	40	6.86	13		ND	Complying	Complying
		12.09.2024	1096 dt. 20.09.2024		7.6	36	7.4	15		ND	Complying	Complying
		28.10.2024	1358 dt. 06.11.2024		5.8	40	6.9	13		ND	Complying	Complying
		14.11.2024	1459 dt. 21.11.2024		6.8	40	7.09	15		ND	Complying	Complying
14	(KRN-STP-007) 6 MLD STP Nilokheri, Karnal by PHED in 1.8.2014 (MBBR+TT, 2019)	05.01.2021	26 dt. 15.01.2021		8	48	7.6	17	4900	20.43	Complying	Complying
		04.02.2021	301 dt. 12.02.2021		6	40	7.52	16	490	9.36	Complying	Complying
		04.03.2021	570 dt. 16.03.2021		7.6	44	8.05	8	270	1.81	Complying	Complying
		02.04.2021	765 dt. 12.04.2021		6.8	36	7.58	16	580	5.69	Complying	Complying
		18.05.2021	1148 dt. 01.06.2021	2.43 MLD	6.5	44	7.34	10	2700	0.04	Complying	Complying
		10.06.2021	1322 dt. 21.06.2021		7.8	40	7.9	10	700	0.12	Complying	Complying
	07.09.2021	05.07.2021	1504 dt. 15.07.2021	2.35 MLD	8	40	7.25	11	700	1.04	Complying	Complying
	24.09.2021	09.08.2021	1986 dt. 19.08.2021		7	36	7.77	12	200	0.23	Complying	Complying
	25.10.2021	15.09.2021	2447 dt. 04.10.2021	0.52 MLD	5.5	32	8.01	16	2700	2.04	Complying	Complying
	25.11.2021	08.10.2021	2681 dt. 22.10.2021	1.84 MLD	7.6	44	8.49	16	900	1.32	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	24.12.2021	23.11.2021	3119 dt. 02.12.2021	1 MLD	7.5	46	7.7	13	70	2.37	Complying	Complying
	19.01.2022	17.12.2021	3408 dt. 29.12.2021		8	44	7.01	17	60	0.51	Complying	Complying
	09.02.2022	13.01.2022	3690 dt. 25.01.2022	2 MLD	4.2	16	7.08	8	20	N.D.	Complying	Complying
	05.04.2022	15.02.2022	4170 dt. 24.02.2022	Out of or	6.5	36	7.9	10	Absent	0.68	Complying	Complying
	13.04.2022	07.03.2022	4510 dt. 21.03.2022		7.2	44	7.52	15	90	1.04	Complying	Complying
	17.05.2022	15.04.2022	5085 dt. 06.05.2022		14	68	7	28	800	1.06	Non-Complying	Non-Complying
	08.06.2022	13.05.2022	5448 dt. 27.05.2022		7.2	40	6.84	12	70	1.01	Complying	Complying
	05.07.2022	07.06.2022	5690 dt. 20.06.2022	270	7.2	32	7.81	10	60	1.43	Complying	Complying
	05.08.2022	13.07.2022	6230 dt. 21.07.2022	263m3	6.5	32	8.21	10	80	1.08	Complying	Complying
	05.09.2022	16.08.2022	6561 dt. 25.08.2022	370m3/h	8.5	40	7.64	13	80	2.42	Complying	Complying
	28.09.2022	07.09.2022	6724 dt. 16.09.2022	275m3/hr	7.8	44	7.5	15	200	1.92	Complying	Complying
	25.10.2022	07.10.2022	7111 dt. 18.10.2022	348.4 m3/hr	8	36	7.15	15	80	2.02	Complying	Complying
	05.12.2022	18.11.2022	7500 dt. 30.11.2022	472m3/h	13	68	8.03	25	400	1.36	Non-Complying	Non-Complying
	07.12.2022	25.11.2022	7566 dt. 07.12.2022	429m3/hr	6.8	28	7.52	13	70	ND	Complying	Complying
	05.01.2023	16.12.2022	7937 dt. 27.12.2022	425m3/hr	6	20	7.26	9	90	1.72	Complying	Complying
	01.02.2023	20.01.2023	203 dt. 31.01.2023		7.6	40	8.02	13	80	ND	Complying	Complying
	02.03.2023	10.02.2023	501 dt. 21.02.2023		7.5	40	7.46	13	80	ND	Complying	Complying
	21.03.2023	03.03.2023	761 dt. 15.03.2023		8.2	48	7.42	18	90	ND	Complying	Complying
	04.05.2023	21.04.2023	1306 dt. 02.05.2023		7	32	7.23	14	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	12.06.2023	24.05.2023	1622 dt. 01.06.2023	272m3/h	8.5	48	7.06	17	80	ND	Complying	Complying
	24.06.2023	08.06.2023	1816 dt. 16.06.2023	244m3/hr	6.8	32	7.71	12	90	ND	Complying	Complying
	14.08.2023	25.07.2023	2339 dt. 02.08.2023	251m3/hr	5.8	24	7.39	11	80	ND	Complying	Complying
	25.08.2023	10.08.2023	2487 dt. 21.08.2023		8	48	6.9	15	70	ND	Complying	Complying
	18.10.2023	28.09.2023	3057 dt. 14.10.2023		7.8	40	7.5	12	70	ND	Complying	Complying
	10.11.2023	27.10.2023	3370 dt. 07.11.2023		7.2	32	6.59	13	80	ND	Complying	Complying
	14.12.2023	22.11.2023	3638 dt. 01.12.2023		6.2	32	7.34	11	70	ND	Complying	Complying
	18.01.2024	12.12.2023	3875 dt. 22.12.2023		6.4	36	6.34	10	70	ND	Complying	Complying
		24.01.2024	4291 dt. 30.01.2024		8	44	7.4	12	80	ND	Complying	Complying
		21.02.2024	4647 dt. 12.03.2024		7	40	6.8	12	80	ND	Complying	Complying
		23.05.2024	287 dt. 31.05.2024		7	36	7.01	12	90	ND	Complying	Complying
		26.07.2024	752 dt. 06.08.2024		6.8	32	7.08	11		ND	Complying	Complying
		30.08.2024	988 dt. 09.09.2024		7.2	40	6.87	15		ND	Complying	Complying
		12.09.2024	1098 dt. 20.09.2024		7.6	48	6.75	15		ND	Complying	Complying
		28.10.2024	1353 dt. 06.11.2024		6.5	36	6.8	11		ND	Complying	Complying
		14.11.2024	1458 dt. 21.11.2024		6.5	44	7.02	16		ND	Complying	Complying
15	(KRN-STP-008) 4 MLD, Nissing Karnal by PHED in 10.8.2016 (MBBR+TT, 2020)	19. 01.2021	127 dt. 29.01.2021		6.5	46	7.93	7	1100	1.04	Complying	Complying
		12.02.2021	397 dt. 22.02.2021		5.5	32	8.1	6	Absent	4.63	Complying	Complying
		19.03.2021	721 dt. 31.03.2021		7.8	32	7.66	7.66	140	2.36	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		12.04.2021	921 dt. 27.04.2021		5.8	32	7.5	8	60	1.2	Complying	Complying
		18.05.2021	1150 dt. 01.06.2021		7.8	40	7.01	13	900	2.14	Complying	Complying
		09.06.2021	1324 dt. 21.06.2021		7.6	40	8.45	12	400	2.46	Complying	Complying
	07.09.2021	20.07.2021	1721 dt. 30.07.2021	1.20 MLD	6.2	28	7.55	12	900	2.3	Complying	Complying
	30.09.2021	23.08.2021	2179 dt. 06.09.2021	0.6	7.5	36	7.6	11	22100	2.14	Complying	Complying
	25.10.2021	17.09.2021	2451 dt. 01.10.2021		8	32	7.65	14	2300	N.D.	Complying	Complying
	25.11.2021	18.10.2021	2793 dt. 03.11.2021		7.5	44	7.88	14	900	1.67	Complying	Complying
	24.12.2021	23.11.2021	3120 dt. 03.12.2021		7.5	44	7.72	9	70	1.44	Complying	Complying
	19.01.2022	09.12.2021	3281 dt. 20.12.2021		7.5	48	7.57	16	80	1.41	Complying	Complying
	09.02.2022	13.01.2022	3687 dt. 21.01.2022		7.8	40	6.98	16	80	0.64	Complying	Complying
	05.04.2022	15.02.2022	4169 dt. 24.02.2022		8	48	7.83	14	60	1.32	Complying	Complying
	13.04.2022	22.03.2022	4668 dt. 31.03.2022		6.8	32	7.53	13	Absent	0.19	Complying	Complying
	18.05.2022	16.04.2022	5104 dt. 06.05.2022		7.6	44	7.57	15	80	1.32	Complying	Complying
	10.06.2022	17.05.2022	5460 dt. 28.05.2022	650.7m3/h	6.8	36	7.24	13	Absent	ND	Complying	Complying
	05.07.2022	07.06.2022	5689 dt. 20.06.2022		7	36	7.27	10	50	1.99	Complying	Complying
	05.08.2022	26.07.2022	6322 dt. 03.08.2022	649.2m3/h	16	72	6.96	28	500	4.67	Non-Complying	Non-Complying
	05.09.2022	16.08.2022	6560 dt. 25.08.2022	590.2m3/h	6.2	24	7.12	12	800	1.46	Non-Complying	Non-Complying
	16.09.2022	01.09.2022	6701 dt. 13.09.2022	132.8	5.8	20	7.87	7	50	ND	Complying	Complying
	16.11.2022	19.10.2022	7260 dt. 28.10.2022		7.8	40	7.01	14	90	1.13	Complying	Complying
	05.12.2022	18.11.2022	7496 dt. 30.11.2022		13	60	7.46	36	200	1.95	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	07.12.2022	25.11.2022	7568 dt. 07.12.2022	133 m3/hr	7	40	7.36	15	80	ND	Complying	Complying
	05.01.2023	16.12.2022	7939 dt. 27.12.2022		7.5	40	7.11	16	80	0.96	Complying	Complying
	01.02.2023	20.01.2023	200 dt. 31.01.2023		7.8	44	8.02	16	80	1.26	Complying	Complying
	02.03.2023	10.02.2023	500 dt. 21.02.2023		13	64	7.61	27	200	1.13	Non-Complying	Non-Complying
	21.03.2023	03.03.2023	765 dt. 15.03.2023		8	48	7.14	16	80	ND	Complying	Complying
	04.05.2023	21.04.2023	1307 dt. 02.05.2023		8.5	48	7.09	16	90	ND	Complying	Complying
	12.06.2023	24.05.2023	1620 dt. 01.06.2023	130	7.4	28	7.16	12	90	ND	Complying	Complying
	24.06.2023	09.06.2023	1817 dt. 16.06.2023	140 m3/hr	6	20	7.62	12	80	ND	Complying	Complying
	14.08.2023	25.07.2023	2343 dt. 02.08.2023	130m3/hr	8	40	7.45	12	70	ND	Complying	Complying
	25.08.2023	10.08.2023	2489 dt. 21.08.2023		7	36	6.9	14	50	ND	Complying	Complying
	19.10.2023	28.09.2023	3060 dt. 14.10.2023		6.8	44	7.56	13	80	ND	Complying	Complying
	10.11.2023	27.10.2023	3365 dt. 07.11.2023		7.6	48	6.67	15	90	ND	Complying	Complying
	14.12.2023	21.11.2023	3631 dt. 01.12.2023		8.2	44	7.2	13	80	ND	Complying	Complying
	22.12.2023	06.12.2023	3805 dt. 19.12.2023		7	40	7.32	10	70	ND	Complying	Complying
		24.01.2024	4289 dt. 30.01.2024		8.4	48	7.2	11	80	ND	Complying	Complying
		21.02.2024	4649 dt. 12.03.2024		7.8	44	6.7	11	80	ND	Complying	Complying
		17.05.2024	262 dt. 23.05.2024		8	48	7.01	13	80	ND	Complying	Complying
		26.07.2024	756 dt. 06.08.2024		7.5	44	7.06	15		ND	Complying	Complying
		14.08.2024	871 dt. 21.08.2024		7.5	44	6.7	16		ND	Complying	Complying
		10.09.2024	1072 dt. 18.09.2024		7.6	48	7.54	15		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		15.10.2024	1270 dt. 24.10.2024		6.2	36	7.03	11		ND	Complying	Complying
		12.11.2024	1428 dt. 19.11.2024		6.5	32	6.76	13		ND	Complying	Complying
16	(KRN-STP-009) 5.5 MLD STP Taraori, Karnal by PHED in 1.6.2016 (MBBR+TT, 2019)	05.01.2021	27 dt. 15.01.2021		7	36	7.61	15	1700	3.64	Complying	Complying
		04.02.2021	302 dt. 12.02.2021		8	36	7.8	11	9000	7.48	Complying	Complying
		04.03.2021	571 dt. 16.03.2021		7	40	7.98	10	5420	0.98	Complying	Complying
		02.04.2021	764 dt. 12.04.2021		7	44	7.52	14	10900	1.73	Complying	Complying
		18.05.2021	1146 dt. 01.06.2021	2.25 MLD	4.8	24	7.32	8	900	N.D.	Complying	Complying
		10.06.2021	1320 dt. 21.06.2021		4.8	20	7.79	6	490	1.32	Complying	Complying
	07.09.2021	05.07.2021	1505 dt. 15.07.2021	Damaged	8	40	7.25	11	700	1.04	Complying	Complying
	24.09.2021	09.08.2021	1985 dt. 19.08.2021		6.8	32	7.81	10	200	0.31	Complying	Complying
	25.10.2021	15.09.2021	2446 dt. 04.10.2021		5	26	8.53	8	2200	1.26	Complying	Complying
	25.11.2021	08.10.2021	2677 dt. 22.10.2021		7.2	48	8.24	14	400	1.4	Complying	Complying
	09.12.2021	10.11.2021	2946 dt. 24.11.2021	0.96 MLD	7.2	40	7.82	14	70	2.03	Complying	Complying
	19.01.2022	17.12.2021	3402 dt. 29.12.2021		6.2	36	7.94	9	60	0.68	Complying	Complying
	09.02.2022	13.01.2022	3689 dt. 21.01.2022	1.44 MLD	6	24	6.91	10	90	1.06	Complying	Complying
	05.04.2022	14.02.2022	4165 dt. 24.02.2022		3.8	20	7.91	8	Absent	N.D.	Complying	Complying
	13.04.2022	10.03.2022	4541 dt. 25.03.2022	0.2 MLD	6.5	32	7.97	11	60	1.41	Complying	Complying
	17.05.2022	15.04.2022	5086 dt. 05.05.2022	208.57m ³	7.5	40	7.01	17	90	1.24	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	08.06.2022	13.05.2022	5447 dt. 27.05.2022	251m ³ /h	7.8	36	7.2	11	80	1.17	Complying	Complying
	05.07.2022	07.06.2022	5691 dt. 20.06.2022	288.4m ³ /h	7.8	36	6.9	14	80	2.92	Complying	Complying
	05.08.2022	13.07.2022	6231 dt. 21.07.2022		15	76	7.64	32	500	1.41	Complying	Complying
	05.09.2022	16.08.2022	6558 dt. 25.08.2022	327.58m ³	7.5	28	7.62	10	400	2.42	Complying	Complying
	28.09.2022	07.09.2022	6722 dt. 16.09.2022	294.40m ³ /	7.2	36	7.74	17	200	2.98	Complying	Complying
	25.10.2022	07.10.2022	7112 dt. 18.10.2022		8	44	7.94	16	80	0.96	Complying	Complying
	05.12.2022	18.11.2022	7499 dt. 30.11.2022	424m ³ /h	16	80	8.67	27	500	1.42	Non-Complying	Non-Complying
	07.12.2022	25.11.2022	7563 dt. 07.12.2022	370m ³ /hr	7.4	36	7.14	13	80	1.24	Complying	Complying
	05.01.2023	16.12.2022	7938 dt. 27.12.2022		8	48	7.37	17	90	1.33	Complying	Complying
	01.02.2023	20.01.2023	202 dt. 31.01.2023		8	40	7.99	14	90	1.13	Complying	Complying
	02.03.2023	10.02.2023	502 dt. 21.02.2023		8	48	7.5	14	90	ND	Complying	Complying
	21.03.2023	03.03.2023	762 dt. 15.03.2023		7.5	40	7.32	13	90	ND	Complying	Complying
	04.05.2023	21.04.2023	1305 dt. 02.05.2023		7.4	36	7	13	80	ND	Complying	Complying
	12.06.2023	24.05.2023	1624 dt. 01.06.2023	312m ³ /hr	7.8	44	7.29	15	90	ND	Complying	Complying
	24.06.2023	09.06.2023	1823 dt. 16.06.2023	314m ³ /hr	5.8	24	7.49	9	70	ND	Complying	Complying
	14.08.2023	25.07.2023	2340 dt. 02.08.2023	292m ³ /hr	6.5	20	7.39	12	80	ND	Complying	Complying
	25.08.2023	10.08.2023	2488 dt. 21.08.2023		7.8	40	6.74	15	80	ND	Complying	Complying
	19.10.2023	28.09.2023	3059 dt. 14.10.2023		7.6	36	7.64	13	90	ND	Complying	Complying
	10.11.2023	27.10.2023	3371 dt. 07.11.2023		7.6	32	6.11	14	70	ND	Complying	Complying
	14.12.2023	22.11.2023	3639 dt. 01.12.2023		7	36	7.35	13	80	ND	Complying	Complying
	18.01.2024	12.12.2023	3879 dt. 22.12.2023		6.4	36	6.82	11	60	ND	Complying	Complying
		24.01.2024	4294 dt. 30.01.2024		7.8	44	7.5	12	60	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
21	(PNP-STP-001) 35 MLD STP Sewah, Panipat by PHED in March, 2000 (UASB Extended Aeration)	21.01.2021	169 dt. 03.2.2021		18	104	7.5	22	1100	0.44	Non-Complying	Non-Complying
		25.02.2021	473 dt. 08.03.2021		6.5	32	7.76	12	40	1.29	Complying	Complying
		25.03.2021	737 dt. 07.04.2021		13	72	7.76	23	170	1.97	Non-Complying	Non-Complying
		27.04.2021	985 dt. 10.05.2021		6.2	28	7.75	13	210	1.76	Complying	Complying
		18.05.2021	1139 dt. 31.05.2021		7.6	32	7.28	7	700	N.D.	Complying	Complying
		07.06.2021	1301 dt. 18.06.2021		7.8	40	7.7	12	1400	1.32	Complying	Complying
	07.09.2021	29.07.2021	1853 dt. 18.08.2021		4.4	20	7.43	14	490	2.28	Complying	Complying
	30.09.2021	24.08.2021	2189 dt. 06.09.2021		7.5	40	7.27	11	3400	0.25	Complying	Complying
	25.10.2021	28.09.2021	2539 dt. 12.10.2021		7.6	40	7.17	12	8400	0.23	Complying	Complying
	30.11.2021	28.10.2021	2851 dt. 11.11.2021		6	32	7.47	10	200	2.04	Complying	Complying
	24.12.2021	26.11.2021	3147 dt. 09.12.2021	648.31m3/h	6.8	44	7.11	14	400	1.29	Complying	Complying
	18.01.2022	28.12.2021	3496 dt. 06.01.2022	700m3/hr	9	56	7.5	18	400	1.84	Complying	Complying
		27.01.2022	3908 dt. 08.02.2022		7.8	44	7.76	12	200	1.09	Complying	Complying
	05.04.2022	17.02.2022	4197 dt. 28.02.2022	300m3/hr	8.2	48	7.2	14	500	1.85	Complying	Complying
	15.04.2022	25.03.2022	4694 dt. 31.03.2022		7.4	40	7.66	14	300	1.41	Complying	Complying
	17.05.2022	25.04.2022	5164 dt. 10.05.2022		6.4	32	7.42	13	200	N.D.	Complying	Complying
	20.06.2022	24.05.2022	5532 dt. 06.06.2022		7.5	44	7.13	15	200	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	18.07.2022	29.06.2022	6012 dt. 12.07.2022		14	68	7	14	600	1.72	Non-Complying	Non-Complying
	05.08.2022	25.07.2022	6313 dt. 03.08.2022		14	60	7.47	34	500	2.35	Non-Complying	Non-Complying
	09.09.2022	29.08.2022	6650 dt. 08.09.2022		8.5	48	7.6	17	200	2.03	Non-Complying	Non-Complying
	17.10.2022	27.09.2022	7008 dt. 10.10.2022		15	64	7.65	33	200	2.62	Non-Complying	Non-Complying
	16.11.2022	27.10.2022	7303 dt. 07.11.2022		6	32	6.62	13	70	0.23	Complying	Complying
	09.12.2022	24.11.2022	7561 dt. 07.12.2022		7.6	44	7.18	18	90	0.94	Complying	Complying
	13.01.2023	27.12.2022	8072 dt. 10.01.2023		7.2	36	7.19	12	90	1.02	Complying	Complying
	09.02.2023	24.01.2023	266 dt. 02.02.2023		8.5	44	7.48	15	70	1.29	Complying	Complying
	09.03.2023	22.02.2023	600 dt. 03.03.2023		8.2	44	7.63	15	90	ND	Complying	Complying
	17.04.2023	28.03.2023	1023 dt. 07.04.2023		8	48	6.8	17	90	1.32	Complying	Complying
	09.05.2023	25.04.2023	1327 dt. 08.05.2023		8	48	6.45	16	80	ND	Complying	Complying
	14.06.2023	25.05.2023	1696 dt. 02.06.2023		7.4	36	6.71	14	80	ND	Complying	Complying
	13.07.2023	22.06.2023	2003 dt. 03.07.2023		7.6	28	7.01	14	90	ND	Complying	Complying
	14.08.2023	26.07.2023	2352 dt. 03.08.2023		7	36	7.79	14	80	ND	Complying	Complying
	11.09.2023	24.08.2023	2583 dt. 04.09.2023		9	44	7.49	11	80	ND	Complying	Complying
	16.10.2023	27.09.2023	3017 dt. 14.10.2023		7.8	40	7.32	12	80	ND	Complying	Complying
	10.11.2023	26.10.2023	3342 dt. 06.11.2023		7.6	44	6.91	15	90	0.96	Complying	Complying
	14.12.2023	23.11.2023	3657 dt. 04.12.2023		8.6	44	7.41	12	80	ND	Complying	Complying
	18.01.2024	26.12.2023	4051 dt. 05.01.2024		9	48	7.27	13	90	ND	Complying	Complying
	Jan, 2024	24.01.2024	4324 dt..31.01.2024		8	48	7.7	12	80	ND	Complying	Complying
	Feb, 2024	26.02.2024	4767 dt. 14.03.2024		14	92	7.6	13	400	ND	Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	Mar, 2024	26.03.2024	5121 dt. 02.04.2024		7	40	7.01	10	60	ND	Complying	Complying
	April,2024	23.04.2024	118 dt 01.05.2024		7.2	40	7.8	13	80	ND	Complying	Complying
		27.05.2024	302 dt. 03.06.2024		7.6	48	7.43	12	80	ND	Complying	Complying
		25.06.2024	475 dt. 09.07.2024		7.6	40	6.83	10		ND	Complying	Complying
		24.07.2024	732 dt. 05.08.2024		7.2	32	6.98	13		ND	Complying	Complying
		29.08.2024	973 dt. 09.09.2024		7.2	44	77.02	13		ND	Complying	Complying
		26.09.2024	1155 dt. 08.10.2024		6.5	40	7.26	15		ND	Complying	Complying
		18.10.2024	1309 dt. 29.10.2024		7.2	44	7.16	15		ND	Complying	Complying
		28.11.2024	1527 dt. 11.12.2024		6	36	7.11	11		ND	Complying	Complying
		26.12.2024	1759 dt. 01.01.2025		6.8	48	6.92	13		ND	Complying	Complying
22	(PNP-STP-002) 10 MLD STP Jattal Road, Panipat by PHED in March,. 2000 (UASB Extended Aeration)	21.01.2021	171 dt. 03.2.2021		12	58	7.51	51	2100	0.25	Non-Complying	Non-Complying
		23.02.2021	457 dt. 05.03.2021		8	44	7.42	31	170	1.31	Complying	Complying
		25.03.2021	742 dt. 07.04.2021		13	64	7.9	16	140	0.54	Non-Complying	Non-Complying
		26.04.2021	982 dt. 10.05.2021		8	44	7.25	11	400	1.97	Complying	Complying
		18.05.2021	1134 dt. 31.05.2021		6.8	32	7.26	11	1700	1.97	Complying	Complying
		07.06.2021	1306 dt. 18.06.2021		6.2	28	7.82	10	900	2.37	Complying	Complying
	07.09.2021	29.07.2021	1849 dt. 18.08.2021		5.2	24	7.26	6	630	3.93	Complying	Complying
	30.09.2021	24.08.2021	2186 dt. 06.09.2021		8.2	48	7.19	13	2300	0.23	Complying	Complying
	25.10.2021	28.09.2021	2541 dt. 12.10.2021		7.5	44	7.2	11	7000	0.19	Complying	Complying
	30.11.2021	28.10.2021	2855 dt. 11.11.2021		6.5	28	8.52	13	600	1.85	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	24.12.2021	26.11.2021	3151 dt. 09.12.2021		7.5	44	7.58	11	400	5.46	Complying	Complying
	18.01.2022	28.12.2021	3499 dt. 07.01.2022		7.6	48	7.75	15	200	N.D.	Complying	Complying
		27.01.2022	3902 dt. 08.02.2022		8	48	7.62	13	80	1.29	Complying	Complying
	05.04.2022	17.02.2022	4199 dt. 28.02.2022	100m3/h	8.5	48	7.4	18	200	2.16	Complying	Complying
	15.04.2022	29.03.2022	4723 dt. 06.04.2022		6.6	28	7.82	17	80	N.D.	Complying	Complying
	17.05.2022	25.04.2022	5161 dt. 10.05.2022		7.5	32	7.4	12	90	1.04	Complying	Complying
	23.06.2022	31.05.2022	5636 dt. 13.06.2022		8	56	7.16	11	200	1.04	Complying	Complying
	18.07.2022	29.06.2022	6016 dt. 12.07.2022		6.5	28	7.34	12	200	0.82	Complying	Complying
	05.08.2022	25.07.2022	6315 dt. 03.08.2022		15	76	7.68	38	600	1.62	Non-Complying	Non-Complying
	09.09.2022	29.08.2022	6646 dt. 08.09.2022		7.8	44	7.36	17	80	1.05	Complying	Complying
	17.10.2022	28.09.2022	7021 dt. 10.10.2022		8	48	7.08	15	80	0.93	Complying	Complying
	16.11.2022	27.10.2022	7308 dt. 07.11.2022	70	7.5	36	6.85	14	70	ND	Complying	Complying
	14.12.2022	25.11.2022	7585 dt. 07.12.2022		8	48	7.03	18	90	ND	Complying	Complying
	13.01.2023	27.12.2022	8074 dt. 10.01.2023		7.5	44	7.52	15	50	1.21	Complying	Complying
	09.02.2023	24.01.2023	268 dt. 02.02.2023		6.8	24	7.6	11	50	ND	Complying	Complying
	09.03.2023	22.02.2023	596 dt. 03.03.2023		7	32	7.17	13	80	ND	Complying	Complying
	17.04.2023	28.03.2023	1024 dt. 07.04.2023		7.8	44	7.56	16	80	ND	Complying	Complying
	09.05.2023	26.04.2023	1331 dt. 08.05.2023		7.8	44	7.38	11	80	ND	Complying	Complying
	14.06.2023	25.05.2023	1703 dt. 02.06.2023		7.8	40	7.64	15	80	ND	Complying	Complying
	13.07.2023	22.06.2023	2000 dt. 03.07.2023		8	48	6.88	16	200	1.26	Complying	Complying
	14.08.2023	26.07.2023	2346 dt. 03.08.2023		7	36	7.56	15	80	ND	Complying	Complying
	12.09.2023	24.08.2023	2587 dt. 04.09.2023		8.5	40	7.08	12	80	ND	Complying	Complying
	16.10.2023	27.09.2023	3018 dt. 14.10.2023		7	36	7.58	10	60	BDL	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	10.11.2023	26.10.2023	3348 dt. 06.11.2023		7.6	44	7.05	13	50	ND	Complying	Complying
	14.12.2023	23.11.2023	3664 dt. 04.12.2023		4.8	24	7.2	10	50	ND	Complying	Complying
	18.01.2024	26.12.2023	4053 dt. 05.01.2024		6.8	36	7.29	11	60	ND	Complying	Complying
	Jan, 2024	24.01.2024	4325 dt. 31.01.2024		11	56	7.5	25	200	ND	Non-Complying	Non-Complying
	Feb, 2024	26.02.2024	4766 dt. 14.03.2024		8.6	48	6.95	13	80	ND	Complying	Complying
	Mar, 2024	26.03.2024	5118 dt. 02.04.2024		6	36	7.03	10	50	ND	Complying	Complying
	April, 2024	23/04/2024	122 dt 01/05/2024		6.2	40	7.43	12	50	ND	Complying	Complying
		27.05.2024	303 dt. 03.06.2024		6.6	40	7.33	13	70	ND	Complying	Complying
		20.06.2024	448dt. 05.07.2024		7.5	36	7.02	13		ND	Complying	Complying
		24.07.2024	744 dt. 05.08.2024		7.4	32	7.09	12		ND	Complying	Complying
		27.08.2024	945 dt. 09.09.2024		7.5	40	6.98	15		ND	Complying	Complying
		26.09.2024	1154 dt. 08.10.2024		7.6	44	7.6	13		ND	Complying	Complying
		31.10.2024	1373 dt. 08.11.2024		7.6	48	7.1	16		ND	Complying	Complying
		31.11.2024	1529 dt. 11.12.2024		8	48	6.52	12		ND	Complying	Complying
		26.12.2024	1765 dt. 01.01.2025		6.8	40	6.79	15		ND	Complying	Complying
23	(PNP-STP-003) 5 MLD STP Samalkha, Panipat by PHED in June, 2013 (MBBR)	21.01.2021	168 dt. 03.2.2021		12	72	7.91	48	1700	0.82	Complying	Complying
		23.02.2021	455 dt. 05.03.2021		8	48	7.36	10	130	2.87	Complying	Complying
		26.03.2021	734 dt. 07.04.2021		16	88	7.85	7	170	1.67	Complying	Non-Complying
		27.04.2021	979 dt. 10.05.2021		15	76	7.8	21	700	1.15	Complying	Non-Complying
		18.05.2021	1136 dt. 31.05.2021		8.2	44	7.76	12	1700	2.26	Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	07.06.2021	1302 dt. 18.06.2021		11	52	7.13	14	1700	2.83	Complying	Non-Complying
07.09.2021	29.07.2021	1852 dt. 18.08.2021		7	40	7.54	14	490	2.83	Complying	Complying
30.09.2021	25.08.2021	2192dt. 09.09.2021		7.2	36	8.79	14	2100	0.1	Complying	Complying
25.10.2021	30.09.2021	2552 dt. 12.10.2021		7	44	8.1	14	4900	1.04	Complying	Complying
30.11.2021	28.10.2021	2852 dt. 11.11.2021		16	88	8.14	34	400	1.87	Non-Complying	Non-Complying
24.12.2021	26.11.2021	3149 dt. 09.12.2021		7.2	40	6.89	13	400	1.04	Complying	Complying
18.01.2022	28.12.2021	3498 dt. 07.01.2022		7.8	48	7.18	15	400	0.54	Complying	Complying
	27.01.2022	3903 dt. 08.02.2022		8	48	7.74	14	200	0.48	Complying	Complying
05.04.2022	18.02.2022	4200 dt. 28.02.2022		20	108	7.39	29	300	1.58	Non Complying	Non Complying
15.04.2022	25.03.2022	4693 dt. 31.03.2022		6.8	44	7.79	12	200	1.32	Complying	Complying
17.05.2022	25.04.2022	5162 dt. 10.05.2022		15	64	7.56	41	400	N.D.	Non Complying	Non Complying
20.06.2022	24.05.2022	5535 dt. 06.06.2022		16	80	7.46	38	400	1.2	Non Complying	Non Complying
18.07.2022	29.06.2022	6014 dt. 12.07.2022		16	72	7.37	28	200	2.14	Non Complying	Non Complying
05.08.2022	25.07.2022	6318 dt. 03.08.2022		14	68	7.13	32	500	1.02	Non Complying	Non Complying
09.09.2022	30.08.2022	6643 dt. 08.09.2022		17	76	7.35	36	500	1.87	Non Complying	Non Complying
17.10.2022	28.09.2022	7020 dt. 10.10.2022		15	72	7.5	28	400	1.82	Non Complying	Non Complying
16.11.2022	27.10.2022	7307 dt. 07.11.2022		13	64	7.1	29	200	1.07	Non Complying	Non Complying
14.12.2022	25.11.2022	7588 dt. 07.12.2022		16	92	7.23	24	200	1.28	Non Complying	Non Complying
13.01.2023	27.12.2022	8077 dt. 10.01.2023		58	240	7.88	138	700	3.74	Non Complying	Non Complying
09.02.2023	24.01.2023	264 dt. 02.02.2023		27	96	7.68	45	500	2.23	Non Complying	Non Complying
09.03.2023	22.02.2023	594 dt. 03.03.2023		13	68	7.29	31	200	1.32	Non Complying	Non Complying
17.04.2023	28.03.2023	1027 dt. 07.04.2023		13	64	7.1	26	200	ND	Non Complying	Non Complying
09.05.2023	26.04.2023	1329 dt. 08.05.2023		15	76	7.5	26	400	2.62	Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
24	(PNP-STP-004) 25 MLD STP Sewah, Panipat by PHED in April, 2016 (SBR)	21.01.2021	170 dt. 03.2.2021		11	52	8.07	17	2100	0.23	Non Complying	Non Complying
		25.02.2021	472 dt. 05.03.2021		5.8	24	7.9	11	3480	1.31	Complying	Complying
		25.03.2021	738 dt. 07.04.2021		12	60	7.8	15	390	2.26	Non Complying	Non Complying
		26.04.2021	980 dt. 10.05.2021		13	64	8.36	23	580	1.02	Non Complying	Non Complying
		18.05.2021	1135 dt. 31.05.2021		6	32	7.38	7	700	1.99	Complying	Complying
		07.06.2021	1300 dt. 18.06.2021		6.8	28	7.48	10	1100	1.04	Complying	Complying
	07.09.2021	29.07.2021	1854 dt. 18.08.2021		6	32	7.56	12	790	1.61	Complying	Complying
	30.09.2021	24.08.2021	2188 dt. 06.09.2021		7.4	36	6.63	8	3200	0.19	Complying	Complying
	25.10.2021	29.09.2021	2540 dt. 12.10.2021		7.2	36	6.79	10	7600	0.31	Complying	Complying
	30.11.2021	28.10.2021	2850 dt. 11.11.2021		2.2	12	7.85	6	Absent	N.D.	Complying	Complying
	24.12.2021	26.11.2021	3146 dt. 09.12.2021	820m3/h	6.2	40	8.33	13	200	1.44	Complying	Complying
	18.01.2022	28.12.2021	3495 dt. 06.01.2022	586 m3/hr	8	40	6.52	14	50	2.48	Complying	Complying
		27.01.2022	3907 dt. 08.02.2022		7.6	48	6.89	12	120	1.19	Complying	Complying
	05.04.2022	17.02.2022	4196 dt. 28.02.2022	250m3/hr	14	56	7.49	28	200	3.14	Non Complying	Non Complying
	15.04.2022	25.03.2022	4695 dt. 31.03.2022		8	48	7.5	16	80	0.25	Complying	Complying
	17.05.2022	25.04.2022	5163 dt. 10.05.2022		7.6	40	7.88	14	300	1.47	Complying	Complying
	20.06.2022	24.05.2022	5531 dt. 06.06.2022		7	48	6.09	14	20	ND	Complying	Complying
	05.07.2022	07.06.2022	5696 dt. 21.06.2022		6	32	6.08	13	50	1.43	Complying	Complying
	18.07.2022	29.06.2022	6011 dt. 12.07.2022		12	60	7.54	15	400	1.87	Non Complying	Non Complying
	05.08.2022	25.07.2022	6312 dt. 03.08.2022		6.5	36	6.23	13	80	1.04	Complying	Complying
	09.09.2022	29.08.2022	6651 dt. 08.09.2022	300m3/h	7.6	40	6.35	15	80	2.76	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	17.10.2022	28.09.2022	7009 dt. 10.10.2022	150m3/h	7.5	44	6.67	17	90	0.93	Complying	Complying
	16.11.2022	27.10.2022	7304 dt. 07.11.2022	350m3/h7.	7.8	40	6.86	16	90	1.02	Complying	Complying
	09.12.2022	24.11.2022	7558 dt. 06.12.2022		8	40	6.2	12	80	ND	Complying	Complying
	13.01.2023	27.12.2022	8070 dt. 10.01.2023		6.8	44	7.17	17	70	ND	Complying	Complying
	09.02.2023	24.01.2023	269 dt. 02.02.2023		6	28	6.34	12	70	ND	Complying	Complying
	09.03.2023	22.02.2023	601 dt. 03.03.2023		6.8	32	6.02	12	70	ND	Complying	Complying
	17.04.2023	28.03.2023	1026 dt. 07.04.2023		7.2	36	6.26	14	80	ND	Complying	Complying
	09.05.2023	26.04.2023	1328 dt. 08.05.2023		7.8	44	6.47	14	70	ND	Complying	Complying
	14.06.2023	25.05.2023	1695 dt. 02.06.2023		7.4	44	6.06	13	90	ND	Complying	Complying
	13.07.2023	22.06.2023	1999 dt. 03.07.2023		7.6	36	6.02	15	80	ND	Complying	Complying
	14.08.2023	26.07.2023	2353 dt. 03.08.2023		6.2	28	7.7	10	50	ND	Complying	Complying
	12.09.2023	24.08.2023	2585 dt. 04.09.2023		8.2	36	7.26	12	70	0.62	Complying	Complying
	16.10.2023	27.09.2023	3020 dt. 14.10.2023		9	44	7.23	12	80	BDL	Complying	Complying
	10.11.2023	26.10.2023	3339 dt. 06.11.2023		7.6	32	6.65	14	70	ND	Complying	Complying
	14.12.2023	23.11.2023	3658 dt. 04.12.2023		7.2	40	7.4	10	80	ND	Complying	Complying
	18.01.2024	26.12.2023	4057 dt. 05.01.2024		7	36	7.24	11	60	ND	Complying	Complying
	Jan, 2024	24/01/2024	4327 dt. 31/01/2024		7.6	44	7.79	13	60	ND	Complying	Complying
	Feb, 2024	26/02/2024	4770 dt.14/03/2024		34	204	7.3	26	1200	ND	Non Complying	Non Complying
	Mar, 2024	26.03.2024	5120 dt. 02.04.2024		8.2	48	6.9	12	70	ND	Complying	Complying
	April, 2024	23.04.2024	120 dt 01.05.2024		8.8	48	7.4	13	70	ND	Complying	Complying
		27.05.2024	305 dt. 03.06.2024		6	36	7.22	11	60	ND	Complying	Complying
		25.06.2024	474 dt. 09.07.2024		10	48	6.8	11		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		24.07.2024	733 dt. 05.08.2024		7.4	48	7	16		ND	Complying	Complying
		29.08.2024	972 dt. 09.09.2024		6	36	6.78	12		ND	Complying	Complying
		26.09.2024	1157 dt. 08.10.2024		6.5	40	7.01	15		ND	Complying	Complying
		18.10.2024	1370 dt. 29.10.2024		7.4	44	7.02	12		ND	Complying	Complying
		28.11.2024	1528 dt. 11.12.2024		5.2	32	7.24	11		ND	Complying	Complying
		26.12.2024	1762 dt. 01.01.2025		6	40	6.97	12		ND	Complying	Complying
25	(PNP-STP-005) 20 MLD STP Jattal Road, Panipat by PHED in April, 2016 (SBR)	21.01.2021	174 dt. 03.2.2021		76	312	7.3	87	10900	7.89	Non Complying	Non Complying
		23.02.2021	456 dt. 05.03.2021		26	124	7.71	86	330	3.49	Non Complying	Non Complying
		25.03.2021	741 dt. 07.04.2021		15	68	7.53	36	340	2.92	Non Complying	Non Complying
		26.04.2021	981 dt. 10.05.2021		7.2	36	7.8	18	340	2.26	Complying	Complying
		18.05.2021	1132 dt. 31.05.2021		8	40	7.52	15	900	2.11	Complying	Complying
		07.06.2021	1305 dt. 18.06.2021		9	48	8.15	12	1400	3.92	Complying	Complying
	07.09.2021	29.07.2021	1848 dt. 18.08.2021		5.6	28	7.42	7	490	3.9	Complying	Complying
	30.09.2021	24.08.2021	2187 dt. 06.09.2021		6.2	24	6.86	9	2200	0.31	Complying	Complying
	25.10.2021	28.09.2021	2542 dt. 12.10.2021		8	48	7.17	13	6300	0.25	Complying	Complying
	30.11.2021	28.10.2021	2856 dt. 11.11.2021		6.2	24	7.7	12	Absent	2.02	Complying	Complying
	24.12.2021	26.11.2021	3152 dt. 09.12.2021		7.2	40	7.51	12	400	2.92	Complying	Complying
	18.01.2022	28.12.2021	3500 dt. 07.01.2022		7.2	44	7.13	10	80	N.D.	Complying	Complying
		27.01.2022	3905 dt. 08.02.2022		7.2	40	7.04	15	Absent	1.31	Complying	Complying
	05.04.2022	17.02.2022	4195 dt. 28.02.2022	221m3/hr	18	124	7.38	88	300	6.45	Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	15.04.2022	29.03.2022	4722 dt. 06.04.2022		3.8	20	2.91	10	20	N.D.	Complying	Complying
	17.05.2022	25.04.2022	5160 dt. 10.05.2022		4.8	20	7.62	9	80	0.77	Complying	Complying
	20.06.2022	24.05.2022	5537 dt. 06.06.2022		6	36	6.62	9	20	1.02	Complying	Complying
	18.07.2022	29.06.2022	6015 dt. 12.07.2022		7.6	32	7.4	10	50	2.85	Complying	Complying
	05.08.2022	25.07.2022	6317 dt. 03.08.2022		8.5	48	7.56	18	80	ND	Complying	Complying
	09.09.2022	29.08.2022	6645 dt. 08.09.2022		8	44	7.36	16	90	0.89	Complying	Complying
	17.10.2022	28.09.2022	7022 dt. 10.10.2022		7	32	7.43	10	90	ND	Complying	Complying
	16.11.2022	27.10.2022	7309 dt. 07.11.2022		7.6	40	6.92	15	80	1.22	Complying	Complying
	14.12.2022	25.11.2022	7587 dt. 07.12.2022		6.8	32	7.1	14	70	1.02	Complying	Complying
	13.01.2023	27.12.2022	8073 dt. 10.01.2023		7.2	32	8.02	16	70	ND	Complying	Complying
	09.02.2023	24.01.2023	267 dt. 02.02.2023		7.5	40	7.7	13	90	1.12	Complying	Complying
	09.03.2023	22.02.2023	595 dt. 03.03.2023		6.2	24	7.25	9	70	ND	Complying	Complying
	17.04.2023	28.03.2023	1025 dt. 07.04.2023		7	44	7.89	15	90	1.24	Complying	Complying
	09.05.2023	26.04.2023	1330 dt. 08.05.2023		7.8	36	7.4	13	90	ND	Complying	Complying
	14.06.2023	26.05.2023	1700 dt. 02.06.2023		7.6	36	7.34	15	90	ND	Complying	Complying
	13.07.2023	22.06.2023	2001 dt. 03.07.2023		6.5	24	7.01	13	90	ND	Complying	Complying
	14.08.2023	26.07.2023	2347 dt. 03.08.2023		7	24	7.62	13	70	ND	Complying	Complying
	12.09.2023	24.08.2023	2588 dt. 04.09.2023		8	36	7.68	11	80	ND	Complying	Complying
	16.10.2023	27.09.2023	3023 dt. 14.10.2023		5.6	28	7.92	10	50	BDL	Complying	Complying
	10.11.2023	26.10.2023	3346 dt. 06.11.2023		7.5	40	7.1	13	90	ND	Complying	Complying
	14.12.2023	23.11.2023	3661 dt. 04.12.2023		6	32	7.12	10	50	ND	Complying	Complying
	18.01.2024	26.12.2023	4059 dt. 05.01.2024		8.4	48	6.95	10	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	Jan, 2024	24/01/2024	4328 dt. 31/01/2024		6.8	36	7.46	12	60	ND	Complying	Complying
	Feb, 2024	26.02.2024	4765 dt. 14.03.2024		5	28	6.94	11	40	ND	Complying	Complying
	Mar, 2024	26.03.2024	5117 dt. 02.04.2024		8.4	48	6.88	10	90	ND	Complying	Complying
	April,2024	23.04.2024	121 dt 01.05.2024		5.8	32	7.37	10	60	ND	Complying	Complying
		27.05.2024	306 dt. 03.06.2024		4.8	28	7.95	215	50	ND	Complying	Complying
		20.06.2024	451 dt. 05.07.2024		5.4	32	7.04	10		ND	Complying	Complying
		24.07.2024	743 dt. 05.08.2024		7.8	36	7.28	14		ND	Complying	Complying
		27.08.2024	944 dt. 04.09.2024		7.8	36	7.01	14		ND	Complying	Complying
		26.09.2024	1153 dt. 08.10.2024		7.5	48	7.65	14		ND	Complying	Complying
		31.10.2024	1372 dt. 08.11.2024		6.8	44	7.23	18		ND	Complying	Complying
		28.11.2024	1530 dt. 11.12.2024		6.2	36	6.91	11		ND	Complying	Complying
		26.12.2024	1766 dt. 01.01.2025		5	32	6.56	9		ND	Complying	Complying
26	(PNP-STP-006) 30 MLD, STP, Sector-19 by HSVP, Panipat 1.11.2018 (SBR)	21.01.2021	172 dt. 03.2.2021		6.8	40	7.73	8	700	1.82	Complying	Complying
		23.02.2021	459 dt. 05.03.2021		9	48	8.05	16	120	3.14	Complying	Complying
		26.03.2021	736 dt. 07.04.2021		10	56	6.94	10	110	1.84	Complying	Complying
		26.04.2021	978 dt. 10.05.2021		BDL	16	2.04	6	Absent	1.2	Complying	Complying
		18.05.2021	1133 dt. 31.05.2021		7.2	36	7.76	11	1100	N.D.	Complying	Complying
		07.06.2021	1304 dt. 18.06.2021		4.5	28	2.7	8	Absent	0.77	Complying	Complying
	07.09.2021	29.07.2021	1851 dt. 18.08.2021		7.8	44	8.56	11	400	1.61	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	30.09.2021	24.08.2021	2190 dt. 09.09.2021		7.6	40	6.95	7	2100	0.25	Complying	Complying
	25.10.2021	28.09.2021	2543 dt. 12.10.2021		6.8	36	8.42	9	8400	0.25	Complying	Complying
	30.11.2021	28.10.2021	2858 dt. 11.11.2021		7	32	7.96	12	Absent	0.68	Complying	Complying
	24.12.2021	26.11.2021	3148 dt. 09.12.2021	620m3/h	7.6	48	7.1	11	500	0.93	Complying	Complying
	18.01.2022	28.12.2021	3494 dt. 06.01.2022	1186m3/hr	7.6	48	6.89	12	80	1.99	Complying	Complying
		27.01.2022	3906 dt. 08.02.2022		6.5	36	7.11	15	110	0.28	Complying	Complying
	05.04.2022	17.02.2022	4194 dt. 28.02.2022	300m3/hr	6.2	28	6.45	8	Absent	1.67	Complying	Complying
	15.04.2022	24.03.2022	4691 dt. 31.03.2022		6.5	32	7.12	12	90	1.44	Complying	Complying
	17.05.2022	25.04.2022	5158 dt. 09.05.2022	1200m3/hr	8	44	7.37	14	70	0.92	Complying	Complying
	20.06.2022	24.05.2022	5536 dt. 06.06.2022		4.5	32	2.93	13	Absent	ND	Complying	Complying
	05.08.2022	25.07.2022	6314 dt. 03.08.2022	1545m3/hr	5.2	28	7.73	10	Absent	0.34	Complying	Complying
	09.09.2022	29.08.2022	6649 dt. 08.09.2022	350m3/h	7.8	24	6.3	13	50	2.14	Complying	Complying
	17.10.2022	28.09.2022	7016 dt. 10.10.2022	300m3/h	7.5	44	7.79	16	90	ND	Complying	Complying
	16.11.2022	27.10.2022	7302 dt. 07.11.2022	1545m3	6.2	28	6.65	10	80	ND	Complying	Complying
	14.12.2022	25.11.2022	7584 dt. 07.12.2022		7.5	44	7.14	16	90	0.29	Complying	Complying
	13.01.2023	27.12.2022	8071 dt. 10.01.2023		7	40	7.41	15	80	ND	Complying	Complying
	09.02.2023	24.01.2023	265 dt. 02.02.2023		5.8	36	7.14	13	50	ND	Complying	Complying
	09.03.2023	22.02.2023	602 dt. 03.03.2023		7.8	40	5.85	15	80	ND	Complying	Complying
	17.04.2023	28.03.2023	1028 dt. 07.04.2023		6.8	32	6.62	14	70	ND	Complying	Complying
	09.05.2023	26.04.2023	1326 dt. 08.05.2023		7.5	40	6.84	13	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
27	(PNP-STP-007) 0.8 MLD STP, Sector-6 by HSVP, Panipat 30.04.2019 (SBR)	21.01.2021	173 dt. 03.2.2021		10	56	7.7	6	50	0.54	Complying	Complying
		23.02.2021	458 dt. 05.03.2021		6.2	32	7.3	18	210	1.99	Complying	Complying
		26.03.2021	735 dt. 07.04.2021		8	44	8.06	8	220	1.47	Complying	Complying
		26.04.2021	986 dt. 10.05.2021		5.8	28	7.8	11	330	2.48	Complying	Complying
		18.05.2021	1131 dt. 31.05.2021		7.8	40	7.75	17	4800	2.42	Complying	Complying
		07.06.2021	1303 dt. 18.06.2021		10	56	8.19	13	2100	0.12	Complying	Complying
	07.09.2021	29.07.2021	1850 dt. 18.08.2021		7.5	36	7.7	9	210	1.32	Complying	Complying
	30.09.2021	24.08.2021	2191 dt. 09.09.2021		7.8	44	7.85	11	7900	0.25	Complying	Complying
	25.10.2021	30.09.2021	2553 dt. 12.10.2021		6.5	40	7.56	12	3400	1.32	Complying	Complying
	30.11.2021	28.10.2021	2857 dt. 11.11.2021		7	28	8.33	10	200	1.04	Complying	Complying
	24.12.2021	26.11.2021	3150 dt. 09.12.2021		7	44	7.46	9	500	1.06	Complying	Complying
	18.01.2022	28.12.2021	3497 dt. 06.01.2022		6.8	44	7.55	9	200	0.63	Complying	Complying
		27.01.2022	3904 dt. 08.02.2022		6	20	7.38	11	60	2.5	Complying	Complying
	05.04.2022	17.02.2022	4198 dt. 28.02.2022	10m3/hr	7.8	32	9.65	16	300	2.03	Non Complying	Non Complying
	15.04.2022	24.03.2022	4692 dt. 31.03.2022		7.8	44	8.14	14	300	1.04	Complying	Complying
	17.05.2022	25.04.2022	5159 dt. 09.05.2022		7.8	36	7.98	12	200	1.29	Complying	Complying
	20.06.2022	24.05.2022	5538 dt. 06.06.2022		6.2	36	7.4	10	50	0.97	Complying	Complying
	18.07.2022	29.06.2022	6013 dt. 12.07.2022		6.8	32	7.55	9	80	1.26	Complying	Complying
	05.08.2022	25.07.2022	6316 dt. 03.08.2022		7	48	7.62	17	90	0.34	Complying	Complying
	09.09.2022	29.08.2022	6644 dt. 08.09.2022		24	204	7.87	56	50	1.04	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	17.10.2022	28.09.2022	7015 dt. 10.10.2022	0.60m3/h	7.8	48	8.06	17	80	ND	Complying	Complying
	16.11.2022	27.10.2022	7310 dt. 07.11.2022		5	20	8.16	9	Absent	ND	Complying	Complying
	14.12.2022	25.11.2022	7586 dt. 07.12.2022		7.4	40	8.35	13	80	0.92	Complying	Complying
	13.01.2023	27.12.2022	8078 dt. 10.01.2023		8	48	8.38	16	200	ND	Complying	Complying
	09.02.2023	24.01.2023	263 dt. 02.02.2023		7.8	48	7.16	16	90	ND	Complying	Complying
	09.03.2023	22.02.2023	597 dt. 03.03.2023		6.4	28	8.73	13	70	ND	Complying	Complying
	17.04.2023	28.03.2023	1029 dt. 07.04.2023		6.5	28	7.49	12	50	1.08	Complying	Complying
	14.06.2023	26.05.2023	1701 dt. 02.06.2023		7.6	28	7.56	12	80	ND	Complying	Complying
	13.07.2023	22.06.2023	2002 dt. 03.07.2023		7.8	48	7.96	14	90	ND	Complying	Complying
	14.08.2023	26.07.2023	2348 dt. 03.08.2023		7.8	44	7.55	16	70	ND	Complying	Complying
	12.09.2023	24.08.2023	2586 dt. 04.09.2023		7	32	6.95	11	60	ND	Complying	Complying
	16.10.2023	27.09.2023	3026 dt. 14.10.2023		5.6	28	7.29	10	50	BDL	Complying	Complying
	10.11.2023	26.10.2023	3347 dt. 06.11.2023		8.6	48	8.21	17	70	ND	Complying	Complying
	14.12.2023	23.11.2023	3666 dt. 04.12.2023		6	32	7.25	11	70	ND	Complying	Complying
	18.01.2024	26.12.2023	4052 dt. 05.01.2024		4.2	24	8.29	10	absent	ND	Complying	Complying
	Jan, 2024	24/01/2024	4330 dt. 31/01/2024		5.8	32	7.23	11	50	ND	Complying	Complying
	Feb, 2024	26.02.2024	4764 dt.14.03.2024		6.8	36	6.79	10	70	ND	Complying	Complying
	Mar, 2024	26.03.2024	5116 dt. 02.04.2024		7.2	40	6.89	13	70	ND	Complying	Complying
	April, 2024	23.04.2024	124 dt 01.05.2024		6.8	40	7.33	12	70	ND	Complying	Complying
		27.05.2024	307 dt. 03.06.2024		5.2	32	6.71	13	60	ND	Complying	Complying
		20.06.2024	449 dt. 05.07.2024		6.8	40	7.09	15		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		24.07.2024	741 dt. 05.08.2024		7.4	40	6.5	13		ND	Complying	Complying
		27.08.2024	942 dt. 04.09.2024		7	44	6.78	15		ND	Complying	Complying
		26.09.2024	1152 dt. 08.10.2024		7	44	7.29	15		ND	Complying	Complying
		31.10.2024	1374 dt. 08.11.2024		7.2	36	6.97	15		ND	Complying	Complying
		28.11.2024	1531 dt. 11.12.2024		7.2	40	7.06	11		ND	Complying	Complying
		26.12.2024	1764 dt. 01.01.2025		5.6	32	6.59	10		ND	Complying	Complying
28	(PNP-STP-008) 15 MLD STP, Dev Colony, Panipat by ULBD 31.07.2023											
	Jan, 2024	24/01/2024	4323 dt. 31/01/2024		8.8	48	7.66	13	90	ND	Complying	Complying
	Feb, 2024											
	Mar, 2024	26/03/2024	5114 dt. 02/04/2024		6	32	6.75	10	60	ND	Complying	Complying
	April, 2024	23.04.2024	113 dt 01.05.2024		6	32	7.33	10	60	ND	Complying	Complying
		27.05.2024	309 dt. 03.06.2024		6	36	7.45	12	70	ND	Complying	Complying
		20.06.2024	450 dt. 05.07.2024		7.4	44	7.27	13		ND	Complying	Complying
		24.07.2024	745 dt. 05.08.2024		7.6	40	6.76	13		ND	Complying	Complying
		27.08.2024	943 dt. 04.09.2024		14	72	7.15	36		ND	Complying	Complying
		26.09.2024	1150 dt. 08.10.2024		6	36	7.94	13		ND	Complying	Complying
		31.10.2024	1371 dt. 08.11.2024		6.2	36	7.47	11		ND	Complying	Complying
		28.11.2024	1533 dt. 11.12.2024		7	44	6.81	13		ND	Complying	Complying
		26.12.2024	1768 dt. 01.01.2025		6.5	40	7.13	13		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
29	(PNP-STP-009) 25 MLD STP, Barasat Road, Panipat by ULBD 31.12.2023											
	Jan, 2024	24/01/2024	4321 dt. 31/01/2024		7.6	44	7.85	14	80	ND	Complying	Complying
	Feb, 2024	26.02.2024	4769 dt. 14.03.2024		7.8	44	7.36	10	70	ND	Complying	Complying
	Mar, 2024	26.03.2024	5123 dt. 02.04.2024		6.6	36	6.65	10	50	ND	Complying	Complying
	April, 2024	23.04.2024	114 dt 01.05.2024		8	48	7.8	13	90	ND	Complying	Complying
		27.05.2024	310 dt. 03.06.2024		8	48	7.18	12	90	ND	Complying	Complying
		25.06.2024	473 dt. 09.07.2024		8	44	7.34	12		ND	Complying	Complying
		24.07.2024	735 dt. 05.08.2024		7.2	40	6.96	15		ND	Complying	Complying
		27.08.2024	975 dt. 04.09.2024		8.2	44	6.37	15		ND	Complying	Complying
		26.09.2024	1151 dt. 08.10.2024		6.8	40	7.7	14		ND	Complying	Complying
		31.10.2024	1368 dt. 07.11.2024		6.5	44	7.24	11		ND	Complying	Complying
		28.11.2024	1525 dt. 11.12.2024		5	32	6.14	13		ND	Complying	Complying
		26.12.2024	1761 dt. 01.01.2025		6.4	36	6.94	11		ND	Complying	Complying
30	(PNP-STP-010) 3 MLD STP, Sewah, Panipat by PHED, Sept., 2023	25.06.2024	477 dt. 09.07.2024		7	44	7.6	11		ND	Complying	Complying
		24.07.2024	742 dt. 05.08.2024		8.2	44	7.1	14		ND	Complying	Complying
		27.08.2024	946 dt. 04.09.2024		7.8	48	7.12	15		ND	Complying	Complying
		26.09.2024	1149 dt. 08.10.2024		7.8	44	8.6	13		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks	
		31.10.2024	1375 dt. 08.11.2024		6.5	40	7.93	16		ND	Complying	Complying	
		28.11.2024	1532 dt. 11.12.2024		5	32	6.31	10		ND	Complying	Complying	
		26.12.2024	1767 dt. 01.01.2025		5.2	28	7.62	10		ND	Complying	Complying	
	Sonepat												
31	(SNP-STP-001) 30 MLD STP Rathdana Road , Sonepat by ULBD in 2003 (UASB)		3972 dt. 4.1.18		18	80	7.8	18			Complying		
			4427 dt. 6.4.18		18	103.6	7.93	68			Complying		
			5758 dt. 21.05.18		23	112	8.1	62			Complying		
			5180 dt. 11.10.18		15	66	7.47	32			Complying		
			372 dt. 14.3.19		180	542.4	6.95	224			Non-complying		
			Sample could not be collected as effluent is not reaching to STP. The sample of bypass has been collected and show cause for prosecution issued.										
			1927 dt. 07.01.2020		75	344.4	7.62	46	70000		Non-complying		
		31.08.2020	3775 dt. 22.09.2020		22	76.4	6.04	32	4000		Complying	Non-complying	
			Not effluent generated										
	25.11.2021	08.10.2021	2715 dt. 27.10.2021	702 m3/h	7.6	44	7.66	14	40	2.47	Complying	Complying	
	24.12.2021	18.11.2021	3101 dt. 02.12.2021		7.5	44	7.8	12	60	0.95	Complying	Complying	
	21.01.2022	07.12.2021	3205 dt. 17.12.2021		6.8	40	7.73	11	Absent	N.D.	Complying	Complying	
	08.02.2022	27.01.2022	3911 dt. 08.02.2022	17 KLD	7.5	40	7.74	13	20	1.97	Complying	Complying	
	04.05.2022	05.04.2022	4874 dt. 21.04.2022	18-20MLD	8.5	48	7.66	18	90	2.14	Complying	Complying	
	17.05.2022	28.04.2022	5202 dt. 12.05.2022	18 MLD	7.6	44	7.32	12	70	1.24	Complying	Complying	
	13.07.2022	29.06.2022	80 dt. 07.07.2022		9	44	7.9	14	90	1.3	Complying	Complying	

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	06.08.2022	28.07.2022	414 dt. 05.08.2022	22	7	40	7.1	13	80	0.98	Complying	Complying
	14.11.2022	01.11.2022	944 dt. 10.11.2022	22.5 apx.	6	32.3	6.9	11	67	1.3	Complying	Complying
	07.01.2023	28.12.2022	1522 dt. 05.01.2023	25 aprox	8	40.7	6.6	17	70	1.8	Complying	Complying
	14.02.2023	30.01.2023	1845 dt. 07.02.2023	27	9	44.1	7.1	16	77	1.5	Complying	Complying
	10.03.2023	28.02.2023	2074 dt. 09.03.2023	27 aprx	7	36.3	7.2	13	80	1.9	Complying	Complying
	13.04.2023	29.03.2023	2350 dt. 07.04.2023			40.4	7.1	14	88	2.2	Complying	Complying
	13.06.2023	27.05.2023	231 dt. 05.06.2023		8	48.4	6.9	16	77	2.5	Complying	Complying
	30.06.2023	30.06.2023	458 dt. 11.07.2023		7	42.6	7.2	17	60	4.1	Complying	Complying
	15.09.2023	28.08.2023	1016 dt. 05.09.2023		5	36	8.3	13	72	1.8	Complying	Complying
	16.11.2023	30.10.2023	1353 dt. 07.11.2023		7	44	7.8	15	60	BDL	Complying	Complying
	19.12.2023	30.11.2023	1477 dt. 11.12.2023		9	48	7.2	18	80	1.3	Complying	Complying
	10.01.2024	29.12.2023	1646 dt. 08.01.2024		5	36	7.4	14	48	BDL	Complying	Complying
		29.01.2024	1975 dt. 05.02.2024		6	48	7.61	12	78	ND	Complying	Complying
	Feb, 2024	29.02.2024	2179 dt. 07.03.2024		6	32	7.19	16	63	ND	Complying	Complying
	Mar, 2024	29.03.2024	2344 dt. 08.04.2024		7	44	7.55	14	70	1.4	Complying	Complying
		29.04.2024	99 dt. 06.05.2024		5	40	7.24	18	77	1.4	Complying	Complying
		27.05.2024	196 dt. 03.06.2024		4	36	7.14	12	63	2.8	Complying	Complying
		26.07.2024	943 dt. 01.08.2024		9	48	7.56	17	53	2.8	Complying	Complying
		28.08.2024	1228 dt. 03.09.2024		5	20	7.23	16	63	4.2	Complying	Complying
		25.09.2024	1414 dt. 01.10.2024		7	36	7.49	14	41	5.6	Complying	Complying
		24.10.2024	1616 dt. 04.11.2024		6	40	7.55	15	79	8.4	Complying	Complying
		25.11.2024	1787 dt. 02.12.2024		8	32	7.78	16	58	7	Complying	Complying
		31.12.2024	2045 dt. 08.01.2025		8.5	31.8	7.24	18	33	4.2	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks	
32	(SNP-STP-002) 25 MLD STP Kakrai Road, Sonapat by ULBD in March dt. 2018 (SBR)		371 dt. 14.03.2019		21	108	7.64	13			Complying		
			1925 dt. 07.01.2020		50	182	7.69	47	330000		Non-complying		
		31.08.2020	3774 dt. 22.09.2020		15	51.6	6.72	16	7000		Complying	Non-complying	
			Not effluent generated										
	09.12.2021	17.11.2021	3066 dt. 30.11.2021		8	46	7.55	17	90	2.83	Complying	Complying	
	08.02.2022	27.01.2022	3915 dt. 08.02.2022	7.3 MLD	7.6	44	7.6	12	20	1.93	Complying	Complying	
	07.04.2022	28.02.2022	4343 dt. 15.03.2022	6.5 MLD	7.8	48	7.92	17	60	1.32	Complying	Complying	
	20.04.2022	31.03.2022	4818 dt. 13.04.2022	5427 m^3	6	28	7	9	80	0.19	Complying	Complying	
	17.05.2022	28.04.2022	5206 dt. 12.05.2022	5.57 MLD	7.5	48	7.28	15	80	0.77	Complying	Complying	
	23.06.2022	26.05.2022	5602 dt. 09.06.2022	429.66	7.5	48	8.01	17	90	1.08	Complying	Complying	
	06.08.2022	28.07.2022	410 dt. 05.08.2022	5.6	8	46	7.7	15	90	1.2	Complying	Complying	
	14.11.2022	01.11.2022	943 dt. 10.11.2022	6.25	7	43.5	7.6	13	77	1.9	Complying	Complying	
	07.01.2023	28.12.2022	1521 dt. 05.01.2023	6.0 aprox	6	32.3	7.1	11	63	1.4	Complying	Complying	
	14.02.2023	30.01.2023	1844 dt. 07.02.2023	5.0 aprox	8	40.4	7.3	14	70	1.9	Complying	Complying	
	10.03.2023	28.02.2023	2076 dt. 09.03.2023	6.5	6	32.3	7.2	17	63	1.5	Complying	Complying	
	13.04.2023	29.03.2023	2351 dt. 07.04.2023		8	36.3	7.5	16	70	2.8	Complying	Complying	
	13.06.2023	27.05.2023	230 dt. 05.06.2023		9	44.1	7.1	18	83	3.4	Complying	Complying	
		30.06.2023	459 dt. 11.07.2023		6	39.2	7.5	18	70	3.9	Complying	Complying	
	14.09.2023	28.08.2023	1007 dt. 05.09.2023		7	44	8.4	15	82	1.8	Complying	Complying	
	16.11.2023	30.10.2023	1357 dt. 07.11.2023		6	36	7.9	17	60	BDL	Complying	Complying	

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	19.12.2023	30.11.2023	1473 dt. 11.12.2023		8	40	7.6	15	93	1.4	Complying	Complying
	10.01.2024	29.12.2023	1648 dt. 08.01.2024		9	48	7.2	13	36	BDL	Complying	Complying
		29.01.2024	1974 dt. 05.02.2024		5	36	7.36	12	75	BDL	Complying	Complying
	Feb, 2024	29.02.2024	2180 dt. 07.03.2024		6	32	7.44	17	84	2.9	Complying	Complying
	Mar, 2024	29.03.2024	2345 dt. 08.04.2024		7	40	7.19	11	--	4.2	Complying	Complying
		29.04.2024	98 dt. 06.05.2024		5	28	7.72	14	63	2.8	Complying	Complying
		27.05.2024	194 dt. 03.06.2024		6	32	7.43	17	58	5.6	Complying	Complying
		26.07.2024	944 dt. 01.08.2024		8	44	6.46	13	79	4.2	Complying	Complying
		28.08.2024	1226 dt. 03.09.2024		6	40	7.15	17	94	8.4	Complying	Complying
		24.09.2024	1413 dt. 01.10.2024		5	32	7.33	12	70	4.8	Complying	Complying
		24.10.2024	1615 dt. 04.11.2024		7	36	7.28	15	63	7	Complying	Complying
		25.11.2024	1786 dt. 02.12.2024		5	24	7.6	11	79	5.6	Complying	Complying
33	(SNP-STP-003) 7.5 MLD Sonepat Rajiv Gandhi Edu. City Phase.I dt. Sonepat by HSVP (ASP)	19.01.2021	153 dt. 01.02.2021		4.8	22	6.9	6	Absent	0.92	Complying	Complying
		24.02.2021	470 dt. 05.03.2021		4.5	32	6.78	6	Absent	1.04	Complying	Complying
		08.03.2021	596 dt. 24.03.2021		6.8	32	7.15	18	Absent	2.26	Complying	Complying
		16.04.2021	941 dt. 28.04.2021		2.8	36	6.43	6	Absent	0.38	Complying	Complying
		18.05.2021	1142 dt. 01.6.2021		6.8	32	7.96	11	400	N.D.	Complying	Complying
		17.06.2021	1382 dt. 28.06.2021		BDL (DL	28	2.5	6	Absent	N.D.	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	24.09.2021	05.08.2021	1910 dt. 18.08.2021		5.6	32	6.39	19	BDL	2.83	Complying	Complying
	25.10.2021	09.09.2021	2372 dt. 29.09.2021	0.6086MLD	6	40	7.45	16	4600	0.85	Complying	Complying
	25.11.2021	08.10.2021	2712 dt. 27.10.2021		3.5	20	7.63	6	Absent	0.34	Complying	Complying
	09.12.2021	08.11.2021	2894 dt. 18.11.2021	0.7022MLD	4.6	24	7.4	10	Absent	0.31	Complying	Complying
	21.01.2022	07.12.2021	3208 dt. 17.12.2021	0.9 MLD	6.5	40	8.32	14	Absent	1.06	Complying	Complying
	10.02.2022	27.01.2022	3917 dt. 08.02.2022	0.8 MLD	6.4	24	7.05	12	Absent	0.22	Complying	Complying
	07.04.2022	28.02.2022	4349 dt. 15.03.2022		8	44	8.14	18	70	N.D.	Complying	Complying
	15.04.2022	29.03.2022	4753 dt. 08.04.2022		5.6	24	7.01	9	70	N.D.	Complying	Complying
	17.05.2022	28.04.2022	5207 dt. 12.05.2022	1 MLD	6.5	24	6.42	8	50	1.17	Complying	Complying
	23.06.2022	26.05.2022	5601 dt. 09.06.2022	0.85MLD	6.2	28	8.06	9	20	0.12	Complying	Complying
	13.07.2022	29.06.2022	79 dt. 07.07.2022		8	40	7.8	13	40	2.9	Complying	Complying
	06.08.2022	28.07.2022	419 dt. 05.08.2022	1	7	44	7.5	11	60	2.5	Complying	Complying
	08.09.2022	29.08.2022	571 dt. 5.09.2022	1.3	7	36	7.7	14	70	2.2	Complying	Complying
	14.11.2022	31.10.2022	924 dt. 10.11.2022		7	31.6	6.5	12	65	1.9	Complying	Complying
	06.12.2022	28.11.2022	1175 dt. 06.12.2022		8	39.2	7.1	14	40	1.7	Complying	Complying
	16.01.2023	28.12.2022	1542 dt. 09.01.2023		7	32.4	7.4	16	50	1.9	Complying	Complying
	14.02.2023	30.01.2023	1852 dt. 07.02.2023		8	36.1	7.5	18	55	1.6	Complying	Complying
	10.03.2023	28.02.2023	2080 dt. 10.03.2023		6	28.2	7.3	14	60	1.2	Complying	Complying
	13.04.2023	30.03.2023	2396 dt. 11.04.2023		8	36.3	7.2	17	67	1.7	Complying	Complying
	19.05.2023	28.04.2023	114 dt. 08.05.2023		6	28.2	7.1	16	60	1.4	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	13.06.2023	27.05.2023	234 dt. 05.06.2023		7	32.1	7.3	13	67	1.7	Complying	Complying
	11.08.2023	25.07.2023	796 dt. 02.08.2023		8	48.4	7	16	87	2.9	Complying	Complying
	14.09.2023	28.08.2023	1012 dt. 05.09.2023		6	40	7.9	13	62	2.1	Complying	Complying
	14.09.2023	28.08.2023	1012 dt. 05.09.2023		6	40	7.9	13	62	2.1	Complying	Complying
	10.10.2023	23.09.2023	1164 dt. 06.10.2023		7	44	8.2	15	70	BDL	Complying	Complying
	16.11.2023	30.10.2023	1350 dt. 07.11.2023		5	36	7.9	17	60	BDL	Complying	Complying
	12.12.2023	29.11.2023	1449 dt. 08.12.2023		9	48	7.2	13	80	BDL	Complying	Complying
	09.01.2024	23.12.2023	1595 dt. 02.01.2024		7	40	7.5	15	90	BDL	Complying	Complying
		3.1.2024	1678 dt. 12.01.2024		5	36	7.4	18	56	1.6	Complying	Complying
	Feb, 2024	22.02.2024	2121 dt. 01.03.2024		7	40	7.35	16	70	2.1	Complying	Complying
	Mar, 2024	22.03.2024	2308 dt. 01.04.2024		8	48	7.13	14	52	2.8	Complying	Complying
		29.04.2024	75 dt. 06.05.2024		5	32	8.12	17	77	4.2	Complying	Complying
		25.07.2024	881 dt. 01.08.2024		7	36	7.73	11	49	4.2	Complying	Complying
		23.08.2024	1206 dt. 30.08.2024		8	44	7.26	17	84	3.6	Complying	Complying
		26.09.2024	1431 dt. 04.10.2024		6	32	7.33	15	70	2.8	Complying	Complying
		24.10.2024	1613 dt. 04.11.2024		7	40	7.13	18	93	5.6	Complying	Complying
		25.11.2024	1779 dt. 02.12.2024		9	48	7.58	12	63	4.2	Complying	Complying
		24.12.2024	1974 dt. 07.01.2025		7.6	40.08	7.54	14	84	7	Complying	Complying
34	(SNP-STP-004) 4.5 MLD STP Kharkhoda Sonapat by PHED 1.8.2013 (MBBR)	13.01.2021	111 dt. 22.01.2021		12	64	7.58	26	13000	0.38	Complying	Complying
		23.02.2021	451 dt. 05.03.2021		13	76	7.71	21	340	3.88	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		08.03.2021	598 dt. 24.03.2021		12	72	7.17	17	310	0.44	Complying	Complying
		16.04.2021	943 dt. 28.04.2021		18	88	7.35	36	1100	0.38	Complying	Complying
		19.05.2021	1158 dt. 02.06.2021		10	56	7.72	28	8000	1.97	Complying	Complying
		17.06.2021	1385 dt. 28.06.2021		7.6	48	7.99	14	2000	2.35	Complying	Complying
	07.09.2021	20.07.2021	1735 dt. 30.07.2021		13	72	7.97	26	2330	7.48	Non-Complying	Non-Complying
	24.09.2021	14.08.2021	2098 dt. 31.08.2021		9	52	7.46	16	1400	1.87	Complying	Complying
	25.10.2021	09.09.2021	2371 dt. 29.09.2021		14	88	7.39	16	3300	0.32	Non-Complying	Non-Complying
	25.11.2021	08.10.2021	2714 dt. 27.10.2021		25	100	7.51	26	2200	1.03	Non-Complying	Non-Complying
	09.12.2021	08.11.2021	2895 dt. 18.11.2021	1.9 MLD	11	52	8.6	18	90	0.35	Non-Complying	Non-Complying
	21.01.2022	09.12.2021	3294 dt. 20.12.2021	1.9 MLD	7.5	48	7.78	13	70	2.26	Complying	Complying
	10.02.2022	27.01.2022	3916 dt. 08.02.2022		7.2	36	7.61	13	200	2.11	Complying	Complying
	15.04.2022	29.03.2022	4754 dt. 08.04.2022		6.5	40	7.32	17	80	2.04	Complying	Complying
	17.05.2022	28.04.2022	5208 dt. 12.05.2022	1.9 MLD	14	68	7.4	35	200	1.04	Non-Complying	Non-Complying
	23.06.2022	26.05.2022	5598 dt. 09.06.2022		21	112	8.05	37	1100	3.38	Non-Complying	Non-Complying
	06.08.2022	28.07.2022	417 dt. 05.08.2022	2	17	76	7.5	28	400	2.1	Non-Complying	Non-Complying
	08.09.2022	29.08.2022	574 dt. 5.09.2022	1.9	21	96	8.1	34	450	2.4	Non-Complying	Non-Complying
	14.11.2022	31.10.2022	923 dt. 10.11.2022		24	102.9	7.9	41	500	3.1	Non-Complying	Non-Complying
	06.12.2022	28.11.2022	1177 dt. 06.12.2022		35	141.1	6.7	65	700	4.2	Non-Complying	Non-Complying
	16.01.2023	29.12.2022	1539 dt. 09.01.2023		45	183.2	7.2	60	900	4.7	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	14.02.2023	30.01.2023	1850 dt. 07.02.2023		34	132.5	7.1	52	700	4.2	Non-Complying	Non-Complying
	10.03.2023	28.02.2023	2082 dt. 10.03.2023		28	113.1	7.4	46	770	4.6	Non-Complying	Non-Complying
	13.04.2023	30.03.2023	2398 dt. 11.04.2023		27	132.3	7.7	58	800	4.2	Non-Complying	Non-Complying
	13.06.2023	27.05.2023	236 dt. 05.06.2023		115	473.8	8.8	240	3500	20.2	Non-Complying	Non-Complying
		30.06.2023	465 dt. 11.07.2023		28	145.4	7.6	42	1300	3.2	Non-Complying	Non-Complying
	14.09.2023	28.08.2023	1013 dt. 05.09.2023		24	116	8.1	39	900	2.4	Non-Complying	Non-Complying
	16.11.2023	30.10.2023	1351 dt. 07.11.2023		20	92	7.9	36	640	1.7	Non-Complying	Non-Complying
	15.12.2023	29.11.2023	1450 dt. 08.12.2023		9	48	7.6	16	90	BDL	Complying	Complying
	09.01.2024	23.12.2023	1598 dt. 02.01.2024		7	40	7.1	18	60	BDL	Complying	Complying
		3.1.2024	1677 dt. 12.01.2024		8	44	7.3	13	80	BDL	Complying	Complying
	Feb, 2024	29.02.2024	2184 dt. 07.03.2024		6	40	7.23	17	58	2.3	Complying	Complying
	Mar, 2024	29.03.2024	2363 dt. 08.04.2024		5	32	7.18	12	63	2.8	Complying	Complying
		24.04.2024	66 dt. 01.05.2024		5	28	7.78	17	70	4.2	Complying	Complying
		31.05.2024	261 dt. 11.06.2024		7	40	7.44	14	77	5.6	Complying	Complying
		30.07.2024	1004 dt. 09.08.2024		6	40	7.6	17	58	4.2	Complying	Complying
		31.08.2024	1295 dt. 06.09.2024		8	32	7.53	15	94	5.6	Complying	Complying
		28.09.2024	1461 dt. 07.10.2024		7	44	7.22	18	79	8.4	Complying	Complying
		22.11.2024	1769 dt. 29.11.2024		12	56	7.54	17	84	7	Non-Complying	Non-Complying
		30.12.2024	2007 dt. 07.01.2025		9.5	47.4	7.12	16	93	8.4	Complying	Complying
35	(SNP-STP-005) 7 MLD STP Ganaur Sonapat by PHED in 1.1.2012 (MBBR)	27.01.2021	202 dt. 04.02.2021		7	36	7.6	16	490	0.92	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		23.02.2021	454 dt. 05.03.2021		23	124	7.66	27	410	2.15	Complying	Complying
		12.03.2021	658 dt. 25.03.2021		22	112	7.54	43	430	0.51	Complying	Complying
		16.04.2021	942 dt. 28.04.2021		13	72	7.4	17	1400	0.44	Complying	Complying
		19.05.2021	1157 dt. 02.06.2021		17	88	7.3	29	9000	2.42	Complying	Complying
		17.06.2021	1383 dt. 28.06.2021		8	40	7.6	12	800	1.04	Complying	Complying
	07.09.2021	20.07.2021	1739 dt. 30.07.2021		15	76	7.43	22	1700	5.46	Non-Complying	Non-Complying
	24.09.2021	10.08.2021	2022 dt. 24.08.2021		9	44	7.5	29	1700	0.97	Complying	Complying
	25.10.2021	09.09.2021	2370 dt. 29.09.2021		22	100	7.8	10	4900	1.08	Non-Complying	Non-Complying
	25.11.2021	08.10.2021	2717 dt. 27.10.2021		12	40	7.77	18	2600	1.86	Non-Complying	Non-Complying
	09.12.2021	16.11.2021	3063 dt. 30.11.2021		26	112	7.46	45	1100	1.41	Non-Complying	Non-Complying
	21.01.2022	07.12.2021	3207 dt. 17.12.2021		60	200	7.48	145	2100	17.33	Non-Complying	Non-Complying
	08.02.2022	27.01.2022	3912 dt. 08.02.2022	7 MLD	7.6	44	7.21	14	200	1.88	Complying	Complying
	07.04.2022	28.02.2022	4347 dt. 15.03.2022	4.0 MLD	22	100	7.6	54	1400	4.03	Non-Complying	Non-Complying
	20.04.2022	31.03.2022	4815 dt. 13.04.2022		82	284	7.5	146	3900	0.23	Non-Complying	Non-Complying
	17.05.2022	28.04.2022	5203 dt. 12.05.2022	5 MLD	18	92	7.26	88	2100	0.98	Non-Complying	Non-Complying
	23.06.2022	26.05.2022	5604 dt. 09.06.2022	5.0MLD	18	92	7.66	33	500	5.75	Non-Complying	Non-Complying
	06.08.2022	28.07.2022	415 dt. 05.08.2022	6.75	58	272	7.3	64	2600	1.1	Non-Complying	Non-Complying
	14.11.2022	01.11.2022	945 dt. 10.11.2022	5.0 KLD	36	138.6	7.7	47	2100	2.6	Non-Complying	Non-Complying
	16.01.2023	29.12.2022	1545 dt. 09.01.2023		42	179.1	7.6	68	2700	3.1	Non-Complying	Non-Complying
	14.02.2023	30.01.2023	1843 dt. 07.02.2023	6.5	36	148.5	7.2	45	3000	3.3	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	10.03.2023	28.02.2023	2073 dt. 09.03.2023	5.8	40	169.6	7.6	56	4100	3.9	Non-Complying	Non-Complying
	13.04.2023	29.03.2023	2347 dt. 11.04.2023		32	136.1	7.9	48	3700	4.1	Non-Complying	Non-Complying
	13.06.2023	27.05.2023	237 dt. 05.06.2023		38	160.6	7.5	55	4100	3.8	Non-Complying	Non-Complying
		30.06.2023	461 dt. 11.07.2023		27	117.6	7.2	42	3700	4.4	Non-Complying	Non-Complying
	14.09.2023	28.08.2023	1009 dt. 05.09.2023		45	192	7.6	56	4600	5.2	Non-Complying	Non-Complying
	10.01.2024	26.12.2023	1616 dt. 03.01.2024		8	48	7.2	14	80	1.9	Complying	Complying
		30.1.2024	2010 dt. 07.02.2024		6	44	7.16	12	63	ND	Complying	Complying
	Feb, 2024	29.02.2024	2177 dt. 07.03.2024		7	40	7.55	15	70	1.2	Complying	Complying
	Mar, 2024	29.03.2024	2341 dt. 08.04.2024		5	32	7.24	13	84	1.4	Complying	Complying
		29.04.2024	105 dt. 06.05.2024		9	48	7.56	17	77	2.8	Complying	Complying
		28.05.2024	220 dt. 05.06.2024		5	24	6.04	8	94	4.2	Complying	Complying
		26.07.2024	948 dt. 05.08.2024		8	48	7.33	17	93	8.4	Complying	Complying
		22.08.2024	1181 dt. 29.08.2024		6	32	7.56	16	84	9.8	Complying	Complying
		27.09.2024	1440 dt. 04.10.2024		9	48	7.64	18	63	7	Complying	Complying
		29.10.2024	1653 dt. 06.11.2024		4	28	7.58	12	70	5.6	Complying	Complying
		28.11.2024	1819 dt. 05.12.2024		18	92	7.54	25	170	11.2	Non-Complying	Non-Complying
		30.12.2024	2005 dt. 07.01.2025		26	118.5	8.07	32	130	12.6	Non-Complying	Non-Complying
36	(SNP-STP-006) 3 MLD STP , Gohana , Sonepat by PHED in 1.11.2015 (MBBR)	27.01.2021	201 dt. 04.02.2021		4.8	28	7.67	14	270	2.46	Complying	Complying
		23.02.2021	449 dt. 04.03.2021		14	84	7.71	24	230	1.76	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		12.03.2021	656 dt. 25.03.2021		15	80	7.07	38	270	0.62	Complying	Complying
		09.04.2021	894 dt. 23.04.2021		9	52	7.7	34	580	2.46	Complying	Complying
		19.05.2021	1156 dt. 02.06.2021		12	64	7.43	31	4000	1.88	Complying	Complying
		17.06.2021	1381 dt. 28.06.2021		7.2	36	7.7	14	1700	0.64	Complying	Complying
	07.09.2021	20.07.2021	1738 dt. 30.07.2021		12	72	7.61	25	2600	1.29	Non-Complying	Non-Complying
	24.09.2021	9.08.2021	1998 dt. 20.08.2021		9	44	7.66	18	2600	N.D.	Complying	Complying
	25.10.2021	09.09.2021	2368 dt. 29.09.2021		8	36	7.47	24	3100	2.36	Complying	Complying
	25.11.2021	08.10.2021	2718 dt. 27.10.2021		28	132	7.7	48	3200	3.88	Non-Complying	Non-Complying
	09.12.2021	16.11.2021	3064 dt. 30.11.2021		21	104	7.44	36	900	2.37	Non-Complying	Non-Complying
	21.01.2022	08.12.2021	3206 dt. 17.12.2021		7.4	48	7.78	13	400	1.67	Complying	Complying
	08.02.2022	27.01.2022	3914 dt. 08.02.2022	2 MLD	7	36	7.48	11	200	2.17	Complying	Complying
	07.04.2022	28.02.2022	4345 dt. 15.03.2022		23	104	7.72	36	1200	2.83	Non-Complying	Non-Complying
	20.04.2022	31.03.2022	4819 dt. 13.04.2022	2.5MLD	42	192	7.68	82	1700	4.56	Non-Complying	Non-Complying
	17.05.2022	28.04.2022	5204 dt. 12.05.2022	2 MLD	68	252	7.55	172	2200	5.75	Non-Complying	Non-Complying
	23.06.2022	26.05.2022	5605 dt. 09.06.2022	2.25MLD	27	128	7.18	78	400	4.85	Non-Complying	Non-Complying
	06.08.2022	28.07.2022	412 dt. 05.08.2022	2.5	105	424	7.2	76	2400	6.7	Non-Complying	Non-Complying
	16.01.2023	29.12.2022	1544 dt. 09.01.2023		85	340.7	7.4	68	3300	6.2	Non-Complying	Non-Complying
	14.02.2023	30.01.2023	1847 dt. 07.02.2023		76	305.2	7.6	55	3500	5.5	Non-Complying	Non-Complying
	10.03.2023	28.02.2023	2077 dt. 09.03.2023	2.5 aprx	85	355.5	7.9	76	4200	5.7	Non-Complying	Non-Complying
	13.04.2023	29.03.2023	2348 dt. 07.04.2023		55	240.9	7.4	62	3500	4.7	Non-Complying	Non-Complying
		30.06.2023	462 dt. 11.07.2023		40	172.4	7.1	58	3000	4.1	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	14.09.2023	28.08.2023	1006 dt. 05.09.2023		35	160	7.2	49	2600	3.6	Non-Complying	Non-Complying
	16.11.2023	30.10.2023	1356 dt. 07.11.2023		29	144	7.1	72	2200	1.8	Non-Complying	Non-Complying
	19.12.2023	30.11.2023	1476 dt. 11.12.2023		9	48	7.7	18	80	1.2	Complying	Complying
	10.01.2024	29.12.2023	1645 dt. 08.01.2024		23	96	7.3	48	360	3.5	Non-Complying	Non-Complying
		30.1.2024	2014 dt. 07.02.2024		65	296	7.04	118	366	4.7	Complying	Complying
	Feb, 2024	29.02.2024	2181 dt. 07.03.2024		75	312	7.46	165	700	5.6	Non-Complying	Non-Complying
	Mar, 2024	29.03.2024	2343 dt. 08.04.2024		78	328	7.31	140	580	7	Non-Complying	Non-Complying
		28.05.2024	206 dt. 04.06.2024		12	64	7.96	18	93	9.84	Non-Complying	Non-Complying
		26.07.2024	941 dt. 05.08.2024		26	168	7.17	72	3300	9.4	Non-Complying	Non-Complying
		28.08.2024	1229 dt. 03.09.2024		28	192	7.34	85	2900	9.8	Non-Complying	Non-Complying
		24.09.2024	1412 dt. 01.10.2024		8	44	7.56	17	77	8.4	Complying	Complying
		27.10.2024	1629 dt. 05.10.2024		6	32	7.04	12	79	9.8	Complying	Complying
		25.11.2024	1782 dt. 02.12.2024		16	72	7.48	38	210	11.2	Non-Complying	Non-Complying
		31.12.2024	2044 dt. 08.01.2025		58	235.5	7.15	110	580	14.01	Non-Complying	Non-Complying
37	(SNP-STP-007) 8.3 MLD STP Gohana, Sonepat by PHED in 2.7.2012 (MBBR)	27.01.2021	203 dt. 04.02.2021		8	40	7.55	25	630	0.32	Complying	Complying
		23.02.2021	450 dt. 05.03.2021		13	72	7.66	45	390	2.87	Complying	Complying
		12.03.2021	657 dt. 25.03.2021		13	72	7.53	45	340	0.68	Complying	Complying
		09.04.2021	895 dt. 23.04.2021		7.4	48	7.58	31	490	0.74	Complying	Complying
		19.05.2021	1155 dt. 02.06.2021		11	68	7.2	24	7000	2.3	Complying	Complying
		17.06.2021	1384 dt. 28.06.2021		7.8	40	7.83	13	1400	4.32	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	24.09.2021	9.08.2021	1997 dt. 20.08.2021		4.6	20	7.67	14	3400	1.41	Complying	Complying
	25.10.2021	09.09.2021	2369 dt. 29.09.2021		18	116	7.09	22	10900	4.25	Non-Complying	Non-Complying
	25.11.2021	08.10.2021	2716 dt. 27.10.2021		26	128	7.8	42	2800	0.95	Non-Complying	Non-Complying
	09.12.2021	16.11.2021	3065 dt. 30.11.2021		14	62	7.36	24	600	1.04	Non-Complying	Non-Complying
	21.01.2022	08.12.2021	3204 dt. 17.12.2021		7	44	7.8	12	400	N.D.	Complying	Complying
	08.02.2022	27.01.2022	3913 dt. 08.02.2022	6.2 MLD	7.2	48	7.61	15	200	2.42	Complying	Complying
	07.04.2022	28.02.2022	4348 dt. 15.03.2022		12	72	7.47	38	500	2.16	Non-Complying	Non-Complying
	20.04.2022	31.03.2022	4816 dt. 13.04.2022		14	68	7.67	38	1700	0.31	Non-Complying	Non-Complying
	17.05.2022	28.04.2022	5205 dt. 12.05.2022	6.5 MLD	18	76	7.3	54	600	2.83	Non-Complying	Non-Complying
	23.06.2022	26.05.2022	5603 dt. 09.06.2022	7.0MLD	15	76	7.77	29	500	3.96	Non-Complying	Non-Complying
	06.08.2022	28.07.2022	411 dt. 05.08.2022	7.5	26	116	7.4	32	2600	1.2	Non-Complying	Non-Complying
	16.01.2023	29.12.2022	1543 dt. 09.01.2023	6.9 aprox	25	105.4	7.1	38	3000	1.7	Non-Complying	Non-Complying
	14.02.2023	30.01.2023	1847 dt. 07.02.2023	7.5	21	84.3	7.3	29	2700	2.1	Non-Complying	Non-Complying
	10.03.2023	28.02.2023	2072 dt. 09.03.2023	7.75 aprx	23	96.9	7.5	38	2500	2.6	Non-Complying	Non-Complying
	13.04.2023	29.03.2023	2349 dt. 07.04.2023		20	88.8	7.7	31	1900	3.5	Non-Complying	Non-Complying
		30.06.2023	460 dt. 11.07.2023		22	101.9	7.5	38	1500	3.2	Non-Complying	Non-Complying
	14.09.2023	28.08.2023	1006 dt. 05.09.2023		19	92	7.3	32	1200	2.6	Non-Complying	Non-Complying
	19.12.2023	30.11.2023	1475 dt. 11.12.2023		8	44	7.8	10	70	1.8	Complying	Complying
	10.01.2024	29.12.2023	1647 dt. 08.01.2024		17	80	7.5	39	420	2.4	Non-Complying	Non-Complying
		30.1.2024	2013 dt. 07.02.2024		7	40	7.38	18	91	ND	Complying	Complying
	Feb, 2024	29.02.2024	2182 dt. 07.03.2024		8	48	7.64	19	84	ND	Complying	Complying
	Mar, 2024	29.03.2024	2342 dt. 08.04.2024		6	36	7.18	17	70	2.8	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		29.04.2024	101 dt. 06.05.2024		7	44	7.61	12	93	4.2	Complying	Complying
		28.05.2024	205 dt. 04.06.2024		5	32	8.23	15	63	1.4	Complying	Complying
		26.07.2024	942 dt. 05.08.2024		15	72	7.44	45	89	9.8	Non-Complying	Non-Complying
		28.08.2024	1227 dt. 03.09.2024		7	28	7.31	18	63	7	Complying	Complying
		24.09.2024	1412 dt. 01.10.2024		8	44	7.56	17	77	8.4	Complying	Complying
		27.10.2024	1631 dt. 05.11.2024		5	40	7.29	16	84	5.6	Complying	Complying
		25.11.2024	1781 dt. 02.12.2024		12	64	7.79	28	79	9.8	Complying	Complying
		31.12.2024	2043 dt. 08.01.2025		7.6	39.8	7.16	16	63	7	Complying	Complying
38	(SNP-STP-008) 15 MLD STP Sonapat (Aterna) by HSVP in 30.04.2024											
39	(SNP-STP-009) 3 MLD, STP Murthal Sonapat by ULBD in 31.12.2024											
	Jhajjar											
40	(JHJ-STP-004) 5.5 MLD STP Kosli Road, Jhajjar by PHED in March dt. 2007 (MBBR)	22.01.2021	1149-1150 dt. 29.01.2021		24	104	7.9	38	21000		Complying	Non-Complying
		09.02.2021	1265-1266 dt. 15.02.2021		22	112	7.9	44	17000		Complying	Non-Complying
		15.02.2021	1311-1312 dt. 22.02.2021		24	120	7.9	48	15000		Complying	Non-Complying
		18.03.2021	1481-1482 dt. 25.03.2021		22	104	8	36	13000		Complying	Non-Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	22.04.2021	132-133 dt. 03.05.2021		58	304	8.2	186	64000	26.2	Non-Complying	Non-Complying
	27.05.2021	280-281 dt. 03.06.2021		46	272	8.1	134	52000	25.8	Non-Complying	Non-Complying
	25.06.2021	426-427 dt. 02.07.2021		28	176	8	48	62000	9.2	Non-Complying	Non-Complying
16.08.2021	22.07.2021	667-668 dt. 30.07.2021		27	160	8.1	36	56000	8.6	Non-Complying	Non-Complying
29.10.2021	30.09.2021	1099-1100 dt. 08.10.2021	4	38	168	8.2	58	39000		Non-Complying	Non-Complying
30.11.2021	22.10.2021	1246-1247 dt. 02.11.2021	3.75	22	144	8.1	48	960		Non-Complying	Non-Complying
20.12.2021	10.11.2021	1371-1372 dt. 24.11.2021	3.5	45	304	8.1	268	94000		Non-Complying	Non-Complying
02.02.2022	25.12.2021	1622-1623 dt. 31.12.2021	3.5	42	296	8.2	242	86000		Non-Complying	Non-Complying
05.04.2022	28.02.2022	4325 dt. 14.03.2022	5.5 MLD	24	132	7.72	84	900	1.32	Non-Complying	Non-Complying
18.04.2022	30.03.2022	4777 dt. 08.04.2022	5 MLD	40	148	7.26	52	600	1.97	Non-Complying	Non-Complying
20.05.2022	29.04.2022	5222 dt. 13.05.2022		48	188	7.18	112	800	4.94	Non-Complying	Non-Complying
23.06.2022	26.05.2022	5595 dt. 08.06.2022		52	192	7.23	87	1700	5.33	Non-Complying	Non-Complying
09.07.2022	30.06.2022	98 dt. 08.07.2022		48	176	7.2	36	4500	3.45	Non-Complying	Non-Complying
09.08.2022	30.07.2022	433 dt. 08.08.2022	4	52	200	7.5	43	3800	3.1	Non-Complying	Non-Complying
09.09.2022	31.08.2022	599 dt. 07.09.2022		52	192	7.3	44	4600	4.6	Non-Complying	Non-Complying
12.10.2022	29.09.2022	717 dt. 10.10.2022	4	41	148	7.6	32	3700	3.2	Non-Complying	Non-Complying
14.11.2022	31.10.2022	928 dt. 10.11.2022		45	162.3	7.4	52	4000	3.7	Non-Complying	Non-Complying
13.12.2022	29.11.2022	1213 dt. 09.12.2022		55	197.9	6.8	70	4500	4.1	Non-Complying	Non-Complying
07.01.2023	28.12.2022	1514 dt. 05.01.2023		42	174.7	7.2	38	3800	3.9	Non-Complying	Non-Complying
15.02.2023	31.01.2023	1862 dt. 08.02.2023		52	212.8	7.6	85	4500	5.8	Non-Complying	Non-Complying
10.03.2023	28.02.2023	2067 dt. 07.03.2023		68	278.7	7.9	122	6000	7.4	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	08.04.2023	27.03.2023	2318 dt. 06.04.2023		62	253.4	7.3	136	5200	6.2	Non-Complying	Non-Complying
	05.05.2023	27.04.2023	110 dt. 04.05.2023		140	566.2	6.8	210	7000	9.8	Non-Complying	Non-Complying
	16.06.2023	29.05.2023	242 dt. 05.06.2023		145	610.4	7.2	230	6700	8.8	Non-Complying	Non-Complying
	15.07.2023	30.06.2023	451 dt. 10.07.2023		160	636.3	8.1	255	7500	9.1	Non-Complying	Non-Complying
	14.08.2023	27.07.2023	839 dt. 05.08.2023		152	605.8	7.5	276	8200	8.6	Non-Complying	Non-Complying
	15.09.2023	31.08.2023	1033 dt. 11.09.2023		145	576	7.2	178	7600	7.5	Non-Complying	Non-Complying
	17.10.2023	27.09.2023	1186 dt. 07.10.2023		120	496	7.5	190	8200	6.8	Non-Complying	Non-Complying
	09.11.2023	28.10.2023	1335 dt. 06.11.2023		112	456	7.1	234	9400	5.4	Non-Complying	Non-Complying
	15.12.2023	30.11.2023	1462 dt. 08.12.2023		132	528	7.8	170	7600	4.2	Non-Complying	Non-Complying
	19.01.2024	30.12.2023	1664 dt. 09.01.2024		138	560	7.5	206	6700	4.8	Non-Complying	Non-Complying
		30.01.2024	2008 dt. 07.2.2024		120	488	7.72	162	5300	5.6	Non-Complying	Non-Complying
		28.02.2024	2171 dt. 07.03.2024		125	520	7.18	232	2900	4.5	Non-Complying	Non-Complying
		29.06.2024	461 dt. 10.07.2024		115	504	7.49	220	3900	8.4	Non-Complying	Non-Complying
		30.08.2024	1282 dt. 06.09.2024		95	376	7.44	175	2100	9.8	Non-Complying	Non-Complying
		07.10.2024	1499 dt. 15.10.2024		72	304	7.02	315	1300	11.2	Non-Complying	Non-Complying
		29.10.2024	1671 dt. 08.11.2024		88	360	7.32	160	2700	16.81	Non-Complying	Non-Complying
		29.11.2024	1828 dt. 05.12.2024		75	296	7.85	140	2100	18.21	Non-Complying	Non-Complying
		31.12.2024	2030 dt. 08.01.2025		82	326.6	7.02	175	1900	20.01	Non-Complying	Non-Complying
41	(JHJ-STP-005) 5 MLD STP Sampla Road , Jhajjar by PHED in 3.11.2014 (MBBR)	22.01.2021	1151-1152 dt. 29.01.2021		26	112	8	32	72000		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		09.02.2021	1263-1264 dt. 15.02.2021		20	96	7.8	32	54000		Complying	Complying
		15.02.2021	1315-1316 dt. 22.02.2021		22	104	7.9	28	45000		Complying	Complying
		18.03.2021	1479-1480 dt. 25.03.2021		25	112	7.8	32	64000		Complying	Complying
		22.04.2021	134-135 dt. 03.05.2021		26	104	7.9	38	56000	6.4	Complying	Complying
		27.05.2021	278-279 dt. 03.06.2021		22	96	8	32	45000	5.8	Complying	Complying
		25.06.2021	424-425 dt. 01.07.2021		20	96	7.9	28	38000	5.4	Complying	Complying
	16.08.2021	22.07.2021	665-666 dt. 30.07.2021		18	80	7.8	26	45000	4.8	Complying	Complying
		26.08.2021	705-706 dt. 02.09.2021	3	19	92	7.1	45	52000	4.9	Non-Complying	Non-Complying
	28.10.2021	30.09.2021	1095-1096 dt. 08.10.2021	4	34	160	8	48	56000		Non-Complying	Non-Complying
	29.11.2021	22.10.2021	1244-1245 dt. 02.11.2021	3.25	20	168	8.3	58	900		Non-Complying	Non-Complying
	20.12.2021	10.11.2021	1369-1370 dt. 24.11.2021	3.25	42	336	8	258	68000		Non-Complying	Non-Complying
	02.02.2022	25.12.2021	1620-1621 dt. 31.12.2021	3.25	40	312	8	234	80000		Non-Complying	Non-Complying
	05.04.2022	28.02.2022	4326 dt. 14.03.2022	5 MLD	14	72	7.56	33	600	2.83	Non-Complying	Non-Complying
	18.04.2022	30.03.2022	4778 dt. 08.04.2022		32	140	7.39	46	1200	2.26	Non-Complying	Non-Complying
	20.05.2022	29.04.2022	5223 dt. 13.05.2022		26	132	7.04	39	400	1.04	Non-Complying	Non-Complying
	23.06.2022	26.05.2022	5593 dt. 08.06.2022		15	68	8.08	27	400	2.36	Non-Complying	Non-Complying
	09.07.2022	30.06.2022	98 dt. 08.07.2022		21	84	7.4	26	600	2.81	Non-Complying	Non-Complying
	09.08.2022	30.07.2022	434 dt. 08.08.2022	4	19	76	7.7	32	700	2.2	Non-Complying	Non-Complying
	09.09.2022	31.08.2022	600 dt. 07.09.2022	4	23	92	7.7	38	900	1.8	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	12.10.2022	29.09.2022	712 dt. 10.10.2022	3.5	35	136	7.1	48	1200	1.5	Non-Complying	Non-Complying
	14.11.2022	31.10.2022	930 dt. 10.11.2022		37	142.5	7.1	41	1100	1.8	Non-	Non-
	13.12.2022	29.11.2022	1212 dt. 09.12.2022		42	171.3	7.2	45	1500	2.1	Non-	Non-
	07.01.2023	28.12.2022	1513 dt. 05.01.2023		48	205.9	7.5	56	2000	2.4	Non-Complying	Non-Complying
	14.02.2023	31.01.2023	1858 dt. 08.02.2023		46	184.7	7.4	68	2300	3.3	Non-Complying	Non-Complying
	10.03.2023	28.02.2023	2065 dt. 07.03.2023		42	173.7	7.1	70	3000	3.9	Non-Complying	Non-Complying
	08.04.2023	27.03.2023	2319 dt. 06.04.2023		48	205.9	7.3	56	2700	4.2	Non-Complying	Non-Complying
	05.05.2023	27.04.2023	108 dt. 04.05.2023		52	221.7	7.5	68	2500	3.9	Non-Complying	Non-Complying
	16.06.2023	29.05.2023	241 dt. 05.06.2023		55	248.9	7.3	75	2900	4.3	Non-Complying	Non-Complying
	15.07.2023	30.06.2023	452 dt. 10.07.2023		48	210.2	7.2	92	3300	5.9	Non-Complying	Non-Complying
	14.08.2023	27.07.2023	840 dt. 05.08.2023		66	274.7	8	118	3800	6.8	Non-Complying	Non-Complying
	15.09.2023	31.08.2023	1034 dt. 11.09.2023		78	312	8.5	133	4200	7.2	Non-Complying	Non-Complying
	17.10.2023	27.09.2023	1187 dt. 07.10.2023		65	296	7.9	160	4900	6.4	Non-Complying	Non-Complying
	09.11.2023	28.10.2023	1336 dt. 06.11.2023		90	368	7.3	192	4200	4.9	Non-Complying	Non-Complying
	15.12.2023	30.11.2023	1461 dt. 08.12.2023		78	312	7.6	182	4600	5.2	Non-Complying	Non-Complying
	19.01.2024	30.12.2023	1659 dt. 09.01.2024		72	288	7.2	168	5200	4.6	Non-Complying	Non-Complying
		30.01.2024	2003 dt. 06.2.2024		82	328	7.81	156	3800	2.8	Non-Complying	Non-Complying
		28.02.2024	2170 dt. 07.03.2024		75	296	7.15	180	2600	3.1	Non-Complying	Non-Complying
		29.06.2024	462 dt. 10.07.2024		92	368	7.89	190	1900	2.8	Non-Complying	Non-Complying
		30.08.2024	1285 dt. 06.09.2024		72	328	8.24	120	2400	11.2	Non-Complying	Non-Complying
		30.09.2024	1468 dt. 08.10.2024		80	376	7.66	175	2100	12.4	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		29.10.2024	1672 dt. 08.11.2024		75	344	7.72	145	1900	14.01	Non-Complying	Non-Complying
		29.11.2024	1829 dt. 05.12.2024		55	288	7.82	80	1300	12.6	Non-Complying	Non-Complying
		31.12.2024	2031 dt. 08.01.2025		70	302.7	7.74	110	2100	18.21	Non-Complying	Non-Complying
42	(JHJ-STP-007) 3.0 MLD STP Beri town, Beri, Jhajjar by PHED dt. 31.03.2022	29.09.2022	713 dt. 07.10.2022	1.25	7	44	7.4	18	80	2.9	Complying	Complying
	14.11.2022	31.10.2022	927 dt. 10.11.2022		6	39.6	7.8	13	67	2.4	Complying	Complying
	13.12.2022	29.11.2022	1214 dt. 09.12.2022		8	42.5	7.7	17	77	2.7	Complying	Complying
	07.01.2023	28.12.2022	1517 dt. 05.01.2023		7	40.7	7.5	16	70	2.9	Complying	Complying
	14.02.2023	31.01.2023	1859 dt. 08.02.2023		6	36.1	7.2	14	65	2.4	Complying	Complying
	10.03.2023	28.02.2023	2066 dt. 07.03.2023		8	40.4	7.4	17	80	2.9	Complying	Complying
	08.04.2023	27.03.2023	2320 dt. 06.04.2023		7	44.4	7.1	13	87	2.1	Complying	Complying
	05.05.2023	27.04.2023	109 dt. 04.05.2023		6	39.6	7.2	15	77	1.9	Complying	Complying
	16.06.2023	29.05.2023	246 dt. 06.06.2023		5	28.2	7.4	16	57	1.6	Complying	Complying
	15.07.2023	30.06.2023	454 dt. 10.07.2023		7	38.8	7.1	18	80	2.2	Complying	Complying
	14.08.2023	27.07.2023	841 dt. 05.08.2023		8	48.9	7.3	16	93	1.6	Complying	Complying
	15.09.2023	31.08.2023	1032 dt. 11.09.2023		7	36	7.1	18	68	2.4	Complying	Complying
	17.10.2023	27.09.2023	1185 dt. 07.10.2023		9	44	7.4	16	80	BDL	Complying	Complying
	09.11.2023	28.10.2023	1340 dt. 06.11.2023		6	36	7.1	13	60	BDL	Complying	Complying
	19.01.2024	30.12.2023	1665 dt. 09.01.2024		7	40	7.3	16	76	BDL	Complying	Complying
		30.01.2024	2005 dt. 06.2.2024		7	40	7.38	14	75	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		28.02.2024	2172 dt. 07.03.2024		6	36	7.47	18	63	ND	Complying	Complying
		29.06.2024	460 dt. 10.07.2024		4	24	7.55	12	49	2.8	Complying	Complying
		30.08.2024	1287 dt. 06.09.2024		8	44	7.49	19	58	2.8	Complying	Complying
		30.09.2024	1471 dt. 08.10.2024		6	32	7.65	19	63	7	Complying	Complying
		29.10.2024	1668 dt. 06.11.2024		8	44	7.32	14	93	2.8	Complying	Complying
		29.11.2024	1830 dt. 05.12.2024		4	32	7.5	18	70	5.6	Complying	Complying
		31.12.2024	2027 dt. 08.01.2025		8.6	39.8	7.12	16	93	8.4	Complying	Complying
Bahadurgarh												
43	(JHJ-STP-001) 18 MLD STP,Linepar, Bahadurgarh by PHED, October, 2012 (UASB+EA)	20.01.2021	1110-1111 dt. 27.01.2021		26	144	8.1	58	28000		Non-Complying	Non-Complying
		26.02.2021	1379-1380 dt. 08.03.2021		38	192	7.9	84	17000		Non-Complying	Non-Complying
		03.03.2021	1415-1416 dt. 12.03.2021		35	204	8.1	98	15000		Non-Complying	Non-Complying
		26.04.2021	150-151 dt. 04.05.2021		38	228	8.1	108	28000	24.3	Non-Complying	Non-Complying
		27.05.2021	276-277 dt. 03.06.2021		36	340	8	110	25000	24.8	Non-Complying	Non-Complying
		28.06.2021	447-448 dt. 05.07.2021		28	176	8	54	22000	9.2	Non-Complying	Non-Complying
	16.08.2021	31.07.2021	742-743 dt. 09.08.2021		26	168	8	52	15000	8.6	Non-Complying	Non-Complying
		27.08.2021	711-712 dt. 02.09.2021	8.1	37	188	7.7	79	89000	9.2	Non-Complying	Non-Complying
	30.11.2021	30.10.2021	1304-1305 dt. 09.11.2021	7.5	35	272	8.3	140	25000		Non-Complying	Non-Complying
	27.12.2021	30.11.2021	1488-1489 dt. 09.12.2021	7	34	264	8.3	120	42000		Non-Complying	Non-Complying
	03.02.2022	31.12.2021	1690-1691 dt. 07.01.2022	7	33	208	8.4	110	48000		Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	05.04.2022	28.02.2022	4324 dt. 14.03.2022	18 MLD	8.5	52	7.82	28	600	0.34	Non-Complying	Non-Complying
	18.04.2022	31.03.2022	4811 dt. 13.04.2022	18 MLD	106	368	7.22	148	1200	7.04	Non-Complying	Non-Complying
	17.05.2022	29.04.2022	5218 dt. 13.05.2022		64	232	7.26	144	2200	9.97	Non-Complying	Non-Complying
	23.06.2022	31.05.2022	5638 dt. 13.06.2022		58	216	7.48	120	1100	9.97	Non-Complying	Non-Complying
	09.07.2022	30.06.2022	95 dt. 08.07.2022		41	168	7.3	62	900	6.24	Non-Complying	Non-Complying
	09.08.2022	30.07.2022	436 dt. 08.08.2022	8	27	108	7.6	54	700	5.7	Non-Complying	Non-Complying
	12.09.2022	31.08.2022	602 dt. 09.09.2022	8	35	136	7.2	49		4.8	Non-Complying	Non-Complying
	12.10.2022	29.09.2022	718 dt. 10.10.2022	8	42	160	7.6	56	700	3.5	Non-Complying	Non-Complying
	14.11.2022	31.10.2022	931 dt. 10.11.2022		35	134.6	7.3	42	650	3.1	Non-Complying	Non-Complying
	13.12.2022	29.11.2022	1209 dt. 09.12.2022		39	149.1	6.9	45	770	3.4	Non-Complying	Non-Complying
	07.01.2023	28.12.2022	1516 dt. 05.01.2023		45	181.2	7.2	38	1100	3.7	Non-Complying	Non-Complying
	14.02.2023	31.01.2023	1857 dt. 08.02.2023		50	204.8	7.4	42	1700	4.2	Non-Complying	Non-Complying
	10.03.2023	28.02.2023	2071 dt. 07.03.2023		58	243.4	7.6	82	2100	6.6	Non-Complying	Non-Complying
	08.04.2023	28.03.2023	2331 dt. 07.04.2023		64	269.7	7.9	115	2900	7.5	Non-Complying	Non-Complying
	05.05.2023	27.04.2023	106 dt. 04.05.2023		70	293.4	7.6	82	3300	6.8	Non-Complying	Non-Complying
	16.06.2023	29.05.2023	244 dt. 05.06.2023		75	309.2	7.9	90	2700	7.1	Non-Complying	Non-Complying
	15.07.2023	30.06.2023	450 dt. 10.07.2023		82	349.2	7.7	135	3500	7.7	Non-Complying	Non-Complying
	14.08.2023	27.07.2023	836 dt. 05.08.2023		110	453.2	6.6	168	4200	6.4	Non-Complying	Non-Complying
	15.09.2023	31.08.2023	1035 dt. 11.09.2023		102	416	6.9	136	4600	6.2	Non-Complying	Non-Complying
	17.10.2023	27.09.2023	1188 dt. 07.10.2023		115	448	7.3	180	5400	6.8	Non-Complying	Non-Complying
	09.11.2023	28.10.2023	1337 dt. 06.11.2023		130	512	7.1	226	6300	5.4	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	15.12.2023	30.11.2023	1463 dt. 08.12.2023		122	496	7.8	160	5800	4.7	Non-Complying	Non-Complying
	19.01.2024	30.12.2023	1660 dt. 09.01.2024		114	456	7.5	212	5400	3.6	Non-Complying	Non-Complying
		30.01.2024	2009 dt. 07.02.2024		112	448	7.34	186	4600	4.2	Non-Complying	Non-Complying
		28.02.2024	2175 dt. 07.03.2024		120	488	7.25	255	3800	5.4	Non-Complying	Non-Complying
		29.06.2024	463 dt. 10.07.2024		120	484	7.45	255	3900	9.4	Non-Complying	Non-Complying
		30.08.2024	1283 dt. 06.09.2024		105	408	7.16	195	3300	15.41	Non-Complying	Non-Complying
		30.09.2024	1473 dt. 08.10.2024		96	348	7.39	210	2700	18.21	Non-Complying	Non-Complying
		29.10.2024	1669 dt. 06.11.2024		112	448	7.45	275	2100	20.01	Non-Complying	Non-Complying
		26.11.2024	1804 dt. 03.12.2024		102	408	8.17	292	1900	15.61	Non-Complying	Non-Complying
		31.12.2024	2028 dt. 08.01.2025		95	374.4	7.79	245	1500	14.01	Non-Complying	Non-Complying
44	(JHJ-STP-002) 36 MLD STP Najafgarh Road, Bahadurgarh by PHED in 1.4.2014 (SBR)	20.01.2021	1108-1109 dt. 27.01.2021		6	32	7.9	9	120		Complying	Complying
		26.02.2021	1381-1382 dt. 08.03.2021		12	64	7.7	28	450000		Non-Complying	Non-Complying
		26.04.2021	148-149 dt. 04.05.2021		7	32	7.6	8	150	2.5	Complying	Complying
		27.05.2021	284-285 dt. 03.06.2021		7	24	7.7	8	130	1.9	Complying	Complying
		28.06.2021	445-446 dt. 05.07.2021		6.4	16	7.6	8	120	2.2	Complying	Complying
	16.08.2021	31.07.2021	744-745 dt. 09.08.2021		6	24	7.5	8	150	2.1	Complying	Complying
		27.08.2021	709-710 dt. 02.09.2021	10.2	7	28	7.8	9	170	0.9	Complying	Complying
	29.10.2021	30.09.2021	1097-1098 dt. 08.10.2021	18	6.4	32	7.8	12	210		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	30.11.2021	30.10.2021	1306-1307 dt. 09.11.2021	10	9.8	48	8	16	18000		Complying	Complying
	27.12.2021	30.11.2021	1484-1485 dt. 09.12.2021	10	9.4	48	8	18	12000		Complying	Complying
	03.02.2022	31.12.2021	1692-1693 dt. 07.01.2022	10	7.8	40	7.8	16	94		Complying	Complying
	05.04.2022	28.02.2022	4323 dt. 14.03.2022	36 MLD	6	56	7.65	29	70	1.03	Complying	Complying
	18.04.2022	30.03.2022	4776 dt. 08.04.2022	36 MLD	13	56	7.25	28	800	2.37	Non-Complying	Non-Complying
	20.05.2022	29.04.2022	5219 dt. 13.05.2022		13	64	7.12	25	400	1.32	Non-Complying	Non-Complying
	23.06.2022	26.05.2022	5592 dt. 08.06.2022		7.6	44	7.3	16	90	3.9	Complying	Complying
	09.07.2022	30.06.2022	96 dt. 08.07.2022		8	36	7.2	17	80	2.81	Complying	Complying
	09.08.2022	30.07.2022	432 dt. 08.08.2022	11	9	44	7.3	15	90	2.3	Complying	Complying
	09.09.2022	31.08.2022	596 dt. 07.09.2022		8	36	7.5	13	70	1.8	Complying	Complying
		29.09.2022	715 dt. 07.10.2022	10	7	24	7.6	15	55	1.4	Complying	Complying
	14.11.2022	31.10.2022	933 dt. 10.11.2022		7	39.6	7.9	14	63	1.2	Complying	Complying
	13.12.2022	29.11.2022	1216 dt. 09.12.2022		8	44.4	7.2	16	70	1.6	Complying	Complying
	07.01.2023	27.12.2022	1501 dt. 04.01.2023		6	28.5	7.2	8	60	1.8	Complying	Complying
	14.02.2023	31.01.2023	1860 dt. 08.02.2023		7	32.1	7.3	13	70	1.3	Complying	Complying
	10.03.2023	28.02.2023	2070 dt. 07.03.2023		6	28.4	7.8	15	77	1.9	Complying	Complying
	08.04.2023	28.03.2023	2330 dt. 07.04.2023		9	48.1	8.2	18	93	2.4	Complying	Complying
	05.05.2023	27.04.2023	105 dt. 04.05.2023		8	43.5	7.5	14	88	2.8	Complying	Complying
	16.06.2023	29.05.2023	243 dt. 05.06.2023		7	43.5	7.3	17	80	2.3	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	15.07.2023	30.06.2023	453 dt. 10.07.2023		10	48.4	7.2	19	93	3.4	Complying	Complying
	14.08.2023	27.07.2023	829 dt. 04.08.2023		7	38.8	7.5	16	60	2.9	Complying	Complying
	15.09.2023	31.08.2023	1031 dt. 11.09.2023		9	44	7.2	14	80	2.4	Complying	Complying
	17.10.2023	27.09.2023	1190 dt. 07.10.2023		8	48	7.5	17	72	3.2	Complying	Complying
	09.11.2023	28.10.2023	1338 dt. 06.11.2023		7	36	7.8	15	90	2.4	Complying	Complying
	15.12.2023	30.11.2023	1459 dt. 08.12.2023		6	40	7.3	19	80	1.9	Complying	Complying
	19.01.2024	30.12.2023	1661 dt. 09.01.2024		9	48	7.5	18	93	1.3	Complying	Complying
		30.01.2024	2007 dt. 07.02.2024		5	36	7.18	14	78	1.7	Complying	Complying
		28.02.204	2174 dt. 07.03.2024		8	44	7.25	17	79	3.1	Complying	Complying
		29.06.2024	464 dt. 10.07.2024		8	48	7.55	18	93	7	Complying	Complying
		30.08.2024	1284 dt. 06.09.2024		8	48	7.49	12	49	4.2	Complying	Complying
		30.09.2024	1472 dt. 08.10.2024		7	36	7.54	18	63	7	Complying	Complying
		29.10.2024	1670 dt. 06.11.2024		4	32	7.42	16	49	5.6	Complying	Complying
		26.11.2024	1805 dt. 03.12.2024		7	44	7.65	13	70	4.2	Complying	Complying
		31.12.2024	2029 dt. 08.01.2025		9.5	43.8	7.31	17	93	8.4	Complying	Complying
45	(JHJ-STP-003) 10 MLD STP Beri Road, Jhajjar, Bahadurgarh by HUDA in 2.2.2013 (EPA)	25.01.2021	1189-1190 dt. 02.02.2021		18	80	7.6	24	17000		Complying	Non-Complying
		27.02.2021	1391-1392 dt. 08.03.2021		21	88	7.6	34	21000		Complying	Non-Complying
		26.04.2021	146-147 dt. 04.05.2021		25	80	7.8	34	18000	7.4	Complying	Non-Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	26.06.2021	428-429 dt. 2.07.2021		22	96	7.9	32	11000	7.2	Complying	Non-Complying
	16.07.2021	603-604 dt. 22.07.2021		22	104	7.8	28	9600	6.7	Non-Complying	Non-Complying
28.10.2021	29.09.2021	1081-1082 dt. 08.10.2021	4	36	168	8.1	46	42000		Non-Complying	Non-Complying
30.11.2021	30.10.2021	1302-1303 dt. 09.11.2021	5.5	39	216	8.2	78	56000		Non-Complying	Non-Complying
	29.11.2021	1480-1481 dt. 09.12.2021	4.5	42	296	8.2	128	68000		Non-Complying	Non-Complying
02.02.2022	29.12.2021	1658-1659 dt. 06.01.2022	3.5	40	248	8.3	134	56000		Non-Complying	Non-Complying
05.04.2022	28.02.2022	4321 dt. 14.03.2022	10 MLD	9	56	7.71	25	400	0.1	Non-Complying	Non-Complying
18.04.2022	30.03.2022	4782 dt. 08.04.2022	10 MLD	14	60	7.37	35	400	1.97	Non-Complying	Non-Complying
20.05.2022	29.04.2022	5220 dt. 13.05.2022		13	28	7.62	33	400	3.94	Non-Complying	Non-Complying
23.06.2022	26.05.2022	5596 dt. 08.06.2022		7.2	48	8.07	16	200	1.48	Complying	Complying
09.07.2022	30.06.2022	96 dt. 08.07.2022		8	44	7.9	15	90	2.6	Complying	Complying
09.08.2022	30.07.2022	431 dt. 08.08.2022	4.5	9	46	7.3	17	80	3.1	Complying	Complying
09.09.2022	31.08.2022	598 dt. 07.09.2022		7	48	7.4	14	90	3.5	Complying	Complying
12.10.2022	29.09.2022	716 dt. 10.10.2022	4.5	8	44	8.4	16	70	2.4	Complying	Complying
14.11.2022	31.10.2022	932 dt. 10.11.2022		7	35.6	6.9	17	65	2.1	Complying	Complying
13.12.2022	29.11.2022	1210 dt. 09.12.2022		8	42.4	7.1	15	70	2.6	Complying	Complying
07.01.2023	28.12.2022	1515 dt. 05.01.2023		8	47.5	7.4	18	90	3.1	Complying	Complying
15.02.2023	31.01.2023	1863 dt. 08.02.2023		7	40.1	7.5	15	77	3.5	Complying	Complying
10.03.2023	28.02.2023	2069 dt. 07.03.2023		8	48.4	7.3	19	83	3.9	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	08.04.2023	28.03.2023	2332 dt. 07.04.2023		8	46.2	7.8	17	90	2.6	Complying	Complying
	05.05.2023	27.04.2023	107 dt. 04.05.2023		9	47.5	7.5	18	80	2.8	Complying	Complying
	16.06.2023	29.05.2023	245 dt. 05.06.2023		7	36.1	7.3	16	76	2.2	Complying	Complying
	15.07.2023	30.06.2023	455 dt. 10.07.2023		6	28.2	7.5	11	90	3.9	Complying	Complying
	14.08.2023	27.07.2023	837 dt. 04.08.2023		8	42.6	7.1	17	60	2.4	Complying	Complying
	15.09.2023	31.08.2023	1029 dt. 11.09.2023		7	48	7.5	19	90	1.8	Complying	Complying
	17.10.2023	27.09.2023	1184 dt. 07.10.2023		6	40	6.9	14	70	BDL	Complying	Complying
	09.11.2023	28.10.2023	1339 dt. 06.11.2023		7	48	7.6	19	93	BDL	Complying	Complying
	15.12.2023	30.11.2023	1457 dt. 08.12.2023		5	36	7.2	16	60	BDL	Complying	Complying
	19.01.2024	30.12.2023	1663 dt. 09.01.2024		6	44	7.4	18	48	BDL	Complying	Complying
		30.01.2024	2006 dt. 07.02.2024		9	48	7.36	18	70	ND	Complying	Complying
		28.02.2024	07.03.2024		8	32	7.5	12	84	2.7	Complying	Complying
		29.06.2024	465 dt. 10.07.2024		8	36	7.55	15	79	7	Complying	Complying
		30.08.2024	1288 dt. 06.09.2024		7	40	7.36	17	70	5.6	Complying	Complying
		30.09.2024	1470 dt. 08.10.2024		9	48	7.64	15	84	2.8	Complying	Complying
		29.10.2024	1665 dt. 06.11.2024		6	40	7.73	11	63	7	Complying	Complying
		26.11.2024	1808 dt. 03.12.2024		8	36	7.48	14	79	5.6	Complying	Complying
		31.12.2024	2026 dt. 08.01.2025		7.5	27.8	7.12	17	63	7	Complying	Complying
	Rohtak											
46	(RTK-STP-001) 19.5 MLD STP, PGIIMS , Rohtak by PHED in 31.3.2016 (SBR)	25.01.2021	1195-1196 dt. 02.02.2021		7	40	7.7	12	1100		Complying	Complying
		27.02.2021	1385-1386 dt. 08.03.2021		7.2	32	7.6	8	1500		Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	20.03.2021	1510-1511 dt. 31.03.2021		6.8	40	7.9	16	1200		Complying	Complying
	27.04.2021	152-153 dt. 04.05.2021		7.4	32	7.8	12	1300	2.8	Complying	Complying
	26.05.2021	264-265 dt. 03.06.2021		7	32	7.8	9	720	2.1	Complying	Complying
	26.06.2021	434-435 dt. 2.07.2021		6.5	32	7.6	8	560	1.9	Complying	Complying
16.08.2021	31.07.2021	729-730 dt. 09.08.2021		7	24	7.8	9	620	2.1	Complying	Complying
	28.08.2021	729-730 dt. 03.09.2021	7.8	5	36	7.1	7	580	1	Complying	Complying
28.10.2021	29.09.2021	1076-1077 dt. 06.10.2021	10	8.9	40	8	14	1300		Complying	Complying
30.11.2021	30.10.2021	1323-1324 dt. 10.11.2021	9	7.2	32	7.8	12	80		Complying	Complying
27.12.2021	29.11.2021	1470-1471 dt. 09.12.2021	7.5	7.4	48	8	16	68		Complying	Complying
02.02.2022	29.12.2021	1664-1665 dt. 06.01.2022	10	7.6	48	8.1	18	72		Complying	Complying
05.04.2022	28.02.2022	4334 dt. 15.03.2022		8	48	7.78	15	200	2.9	Complying	Complying
18.04.2022	30.03.2022	4780 dt. 08.04.2022		7.5	40	7.34	14	80	2.26	Complying	Complying
20.05.2022	29.04.2022	5230 dt. 17.05.2022		8	40	7.3	16	90	1.86	Complying	Complying
22.06.2022	26.05.2022	5586 dt. 08.06.2022		7.2	48	7.4	14	80	1.04	Complying	Complying
12.07.2022	30.06.2022	106 dt. 09.07.2022		7	44	7.6	18	90	1.2	Complying	Complying
09.08.2022	30.07.2022	445 dt. 09.08.2022		8	46	7.1	16	70	1.4	Complying	Complying
09.09.2022	31.08.2022	594 dt. 07.09.2022		7	40	7.3	18	80	1.8	Complying	Complying
07.10.2022	28.09.2022	701 dt. 06.10.2022		6	32	7.5	14	70	1.5	Complying	Complying
07.11.2022	28.10.2022	892 dt. 07.11.2022		5	28	7.2	16	63	1.2	Complying	Complying
13.12.2022	30.11.2022	1219 dt. 09.12.2022		6	36.3	7.4	14	60	1.4	Complying	Complying
19.01.2023	31.12.2022	1564 dt. 11.01.2023		8	40.7	7.5	16	70	1.1	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
47	(RTK-STP-002) 40 MLD STP, Sonariyan , Rohtak, PHED, 31.03.2016	08.01.2021	1618-1619 dt. 15.01.2021		42	200	7	76	76000		Non complying	Non complying
		15.02.2021	1320-1321 dt. 22.02.2021		42	232	8.1	112	17000		Non complying	Non complying
		29.04.2021	156-157 dt. 10.05.2021		48	224	8.4	158	56000	26.8	Non complying	Non complying
		31.05.2021	286-287 dt. 07.06.2021		28	136	8.2	48	36000	84	Complying	Non complying
		30.06.2021	453-454 dt. 07.07.2021		25	112	8.1	42	32000	7.9	Complying	Non complying
	16.08.2021	27.07.2021	701-702 dt. 03.08.2021		27	128	8	42	38000	8.4	Complying	Non complying
		28.08.2021	733-734 dt. 03.09.2021	27.2	26	136	7.4	49	67000	4.2	Non complying	Non complying
	28.10.2021	29.09.2021	1072-1073 dt. 06.10.2021	28	25	120	8.2	38	28000		Non complying	Non complying
	30.11.2021	30.10.2021	1321-1322 dt. 10.11.2021	29	34	208	8.3	110	4500		Non complying	Non complying
	27.12.2021	29.11.2021	1476-1477 dt. 09.12.2021	27	33	192	8.1	106	12000		Non complying	Non complying
	02.02.2022	28.12.2021	1640-1641 dt. 06.01.2022	1.2	32	208	8.2	110	11000		Non complying	Non complying
	05.04.2022	28.02.2022	4333 dt. 15.03.2022		228	800	7.56	187	2100	15.38	Non complying	Non complying
	18.04.2022	30.03.2022	4775 dt. 08.04.2022		40	192	7.13	125	2200	3.9	Non complying	Non complying
	20.05.2022	29.04.2022	5228 dt. 13.05.2022		52	192	7.23	158	1900	4.67	Non complying	Non complying
	22.06.2022	26.05.2022	5590 dt. 08.06.2022		36	180	7.84	210	2100	9.4	Non complying	Non complying
	12.07.2022	30.06.2022	105 dt. 09.07.2022		26	128	8.1	68	2300	8.6	Non complying	Non complying
	09.08.2022	30.07.2022	447 dt. 09.08.2022		28	152	7.6	54	2500	7.9	Non complying	Non complying
	09.09.2022	31.08.2022	595 dt. 07.09.2022		26	144	7.2	43	2100	6.2	Non complying	Non complying
	07.10.2022	28.09.2022	697 dt. 06.10.2022		23	128	7.2	39	1900	6.5	Non complying	Non complying
	07.11.2022	28.10.2022	894 dt. 07.11.2022		45	184	8.2	86	2400	8.9	Non complying	Non complying
	13.12.2022	30.11.2022	1218 dt. 09.12.2022		48	199.9	7.2	70	2700	8.6	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
48	(RTK-STP-003) 3.5 MLD STP Kalanour , Rohtak by PHED in 1.10.2010	21.01.2021	1123-1124 28.01.2021		22	96	7.7	32	38000		Complying	Non complying
		11.02.2021	1289-1290 dt. 17.02.2021		20	88	7.9	26	35000		Complying	Non complying
		20.03.2021	1514-1515 dt. 31.03.2021		22	96	8.1	32	46000		Complying	Non complying
		26.04.2021	138-139 dt. 04.05.2021		23	104	8	34	35000	7.9	Complying	Non complying
		26.05.2021	260-261 dt. 03.6.2021		22	96	7.9	28	32000	7.4	Complying	Non complying
		24.06.2021	416-417 dt. 01.07.2021		20	88	7.8	32	25000	7.2	Complying	Non complying
	16.08.2021	27.07.2021	703-704 dt. 03.08.2021		18	72	8	28	22000	7.8	Complying	Non complying
		28.08.2021	720-721 dt. 03.09.2021	2	25	132	7.9	45	27000	3.8	Non complying	Non complying
	28.10.2021	30.09.2021	1090-1091 dt. 08.10.2021	2	26	104	8.1	42	28000		Non complying	Non complying
	30.11.2021	30.10.2021	1319-1320 dt. 10.11.2021	2	34	136	8	56	42000		Non complying	Non complying
	27.12.2021	27.11.2021	1468-1469 dt. 07.12.2021	2.78	33	152	8.2	78	25000		Non complying	Non complying
	02.02.2022	28.12.2021	1644-1645 dt. 06.01.2022	2.5	34	232	8.4	126	21000		Non complying	Non complying
	05.04.2022	28.02.2022	4330 dt. 14.03.2022		25	120	7.32	70	900	3.9	Non complying	Non complying
	18.04.2022	30.03.2022	4784 dt. 08.04.2022		52	200	6.78	120	800	5.46	Non complying	Non complying
	20.05.2022	29.04.2022	5225 dt. 13.05.2022		160	628	7.87	224	1200	14.54	Non complying	Non complying
	22.06.2022	26.05.2022	5585 dt. 08.05.2022		38	18	7.76	96	2600	4.67	Non complying	Non complying
	09.07.2022	30.06.2022	101 dt. 08.07.2022		27	120	8.1	38	2200	3.87	Non complying	Non complying
	09.08.2022	30.07.2022	443 dt. 09.08.2022		25	112	7.3	31	3.68	3.68	Non complying	Non complying
	09.09.2022	31.08.2022	591 dt. 06.09.2022		36	184	7.3	80	1900	4.2	Non complying	Non complying
	07.10.2022	28.09.2022	698 dt. 06.10.2022		25	104	7.2	62	1500	4.5	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	07.11.2022	28.10.2022	893 dt. 07.11.2022		36	144	7.6	58	1800	4.9	Non complying	Non complying
	14.12.2022	30.11.2022	1223 dt. 09.12.2022		40	189.8	7.2	70	2400	5.2	Non complying	Non complying
	19.01.2023	31.12.2022	1568 dt. 11.01.2023		52	211.7	7.8	110	3300	6.4	Non complying	Non complying
	15.02.2023	31.01.2023	1866 dt. 08.02.2023		25	116.4	7.7	43	2900	5.2	Non complying	Non complying
	10.03.2023	28.02.2023	2064 dt. 07.03.2023		28	133.3	7.2	49	3300	6.1	Non complying	Non complying
	13.04.2023	30.03.2023	2383 dt. 10.04.2023		38	152.6	6.8	72	3700	6.9	Non complying	Non complying
	05.05.2023	27.04.2023	99 dt. 04.05.2023		72	324.7	7.1	150	4900	8.5	Non complying	Non complying
	16.06.2023	30.05.2023	259 dt. 07.06.2023		84	357.1	7.3	132	5300	7.6	Non complying	Non complying
	15.07.2023	29.06.2023	434 dt. 08.07.2023		76	311.8	7.1	150	4700	6.6	Non complying	Non complying
	14.08.2023	26.07.2023	826 dt. 03.08.2023		88	359.5	7.8	142	5600	5.8	Non complying	Non complying
	15.09.2023	29.08.2023	1023 dt. 06.09.2023		94	384	7.6	176	6800	5.2	Non complying	Non complying
	17.10.2023	27.09.2023	1196 dt. 09.10.2023		85	344	7.2	140	6200	3.6	Non complying	Non complying
	08.11.2023	26.10.2023	1316 dt. 03.11.2023		95	392	7.6	176	5600	2.8	Non complying	Non complying
	15.12.2023	30.11.2023	1464 dt. 08.12.2023		72	304	7.2	219	4600	1.4	Non complying	Non complying
	10.01.2024	29.12.2023	1635 dt. 10.01.2024		68	276	7.5	195	5200	3.4	Non complying	Non complying
		28.05.2024	199 dt. 04.06.2024		6	32	7.5	17	84	4.2	Complying	Complying
		28.06.2024	438 dt. 08.07.2024		4	20	7.44	11	79	5.6	Complying	Complying
		29.08.2024	1242 dt. 04.09.2024		5	36	7.41	12	63	4.2	Complying	Complying
		28.09.2024	1451 dt. 07.10.2024		7	40	7.21	14	49	7	Complying	Complying
		25.12.2024	1983 dt. 02.01.2025		7.2	36.07	7.52	15	79	5.6	Complying	Complying
		31.01.2025	2361 dt. 11.02.2025		8.2	38.4	7.5	11	93	7	Complying	Complying
		25.02.2025	2503 dt. 05.03.2025		9.2	48.3	7.38	19	70	5.6	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		19.03.2025	2623 dt. 26.03.2025		6.4	32.2	7.13	17	63	4.2	Complying	Complying
49	(RTK-STP-004) 5 MLD STP, Meham , Bharan Road , Rohtak by PHED January dt. 2013	21.01.2021	1121-1122 dt. 28.01.2021		23	104	7.8	38	36000		Complying	Non complying
		11.02.2021	1291-1292 dt. 17.02.2021		22	96	8	34	25000		Complying	Non complying
		20.03.2021	1512-1513 dt. 31.03.2021		21	104	8.2	36	18000		Complying	Non complying
		26.04.2021	140-141 dt. 04.05.2021		22	112	8	42	21000	8.6	Complying	Non complying
		26.05.2021	262-263 dt. 03.6.2021		20	104	8.1	38	15000	8.2	Complying	Non complying
		24.06.2021	414-415 dt. 01.07.2021		21	96	8	44	17000	7.8	Complying	Non complying
	16.08.2021	27.07.2021	699-700 dt. 03.08.2021		20	80	7.8	38	15000	7.2	Complying	Non complying
		28.08.2021	724-725 dt. 03.09.2021	3.4	24	140	7	62	32000	2.1	Non complying	Non complying
	28.10.2021	29.09.2021	1070-1071 dt. 06.10.2021	3.5	24	104	8	32	21000		Non complying	Non complying
	30.11.2021	30.10.2021	1317-1318 dt. 10.11.2021		34	120	8	48	32000		Non complying	Non complying
	27.12.2021	27.11.2021	1466-1467 dt. 07.12.2021	3.5	28	136	8.1	54	25000		Non complying	Non complying
	02.02.2022	28.12.2021	1646-1647 dt. 06.01.2022	3.5	34	176	8.1	84	21000		Non complying	Non complying
	05.04.2022	28.02.2022	4331 dt. 14.03.2022		26	196	7.28	92	1700	5.75	Non complying	Non complying
	18.04.2022	30.03.2022	4779 dt. 08.04.2022		58	284	7.84	128	2100	4.87	Non complying	Non complying
	20.05.2022	29.04.2022	5224 dt. 13.05.2022		15	72	7.66	33	800	2.37	Non complying	Non complying
	22.06.2022	26.05.2022	5587 dt. 08.06.2022		23	108	7.88	52	1700	3.68	Non complying	Non complying
	09.07.2022	30.06.2022	102 dt. 08.07.2022		25	120	8.1	38	1300	3.16	Non complying	Non complying
	09.08.2022	30.07.2022	444 dt. 09.08.2022		27	140	7.4	43	1500	2.87	Non complying	Non complying
	09.09.2022	31.08.2022	593 dt. 06.09.2022		24	104	7.8	47	1200	3.6	Non complying	Non complying
	07.10.2022	28.09.2022	699 dt. 06.10.2022		22	96	7.4	43	900	3.2	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		07.11.2022	28.10.2022	890 dt. 4.11.2022	20	84	7.1	38	1100	3.6	Non complying	Non complying
		13.12.2022	30.11.2022	1222 dt. 09.12.2022	35	146.8	7.2	65	2100	4.2	Non complying	Non complying
		19.01.2023	31.12.2022	1567 dt. 11.01.2023	40	171.2	7.7	54	2700	4.6	Non complying	Non complying
		15.02.2023	31.01.2023	1864 dt. 08.02.2023	26	120.4	7.9	62	1700	3.9	Non complying	Non complying
		10.03.2023	28.02.2023	2062 dt. 07.03.2023	39	163.2	7.8	90	4200	4.6	Non complying	Non complying
		13.04.2023	30.03.2023	2384 dt. 08.04.2023	35	136.6	7.6	80	4000	4.2	Non complying	Non complying
		05.05.2023	27.04.2023	101 dt. 04.05.2023	52	225.7	7.2	118	4200	5.1	Non complying	Non complying
		16.06.2023	30.05.2023	260 dt. 07.06.2023	48	199.6	7.6	110	3900	4.7	Non complying	Non complying
		15.07.2023	29.06.2023	433 dt. 08.07.2023	41	165.6	7.3	58	3300	4.2	Non complying	Non complying
		14.08.2023	26.07.2023	825 dt. 03.08.2023	52	209.6	7	66	3800	3.8	Non complying	Non complying
		15.09.2023	29.08.2023	1026 dt. 06.09.2023	70	288	7.1	84	4600	4.2	Non complying	Non complying
		17.10.2023	27.09.2023	1197 dt. 09.10.2023	78	312	7.5	114		4.8	Non complying	Non complying
		08.11.2023	26.10.2023	1323 dt. 03.11.2023	70	288	7.8	86	5200	3.1	Non complying	Non complying
		15.12.2023	30.11.2023	1465 dt. 08.12.2023	82	336	7.5	94	4200	3.4	Non complying	Non complying
		10.01.2024	29.12.2023	1652 dt. 08.01.2024	60	240	7.3	72	4600	2.7	Non complying	Non complying
			28.05.2024	203 dt. 04.06.2024	78	304	7.81	88	2100	7	Non complying	Non complying
			28.06.2024	450 dt. 08.07.2024	82	328	8.06	95	3900	2.8	Non complying	Non complying
			29.08.2024	1258 dt. 05.09.2024	7	32	7.61	14	63	7	Complying	Complying
			28.09.2024	1445 dt. 04.10.2024	8	40	7.32	16	91	9.8	Complying	Complying
			25.12.2024	1984 dt. 02.01.2025	5.6	28.05	7.53	17	63	4.2	Complying	Complying
			31.01.2025	2351 dt. 11.02.2025	6.8	31.6	7.52	15	84	7	Complying	Complying
			25.02.2025	2501 dt. 05.03.2025	7.2	44.3	7.79	18	84	2.8	Complying	Complying
			19.03.2025	2622 dt. 26.03.2025	6.8	36.2	7.16	19	84	9.8	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
50	(RTK-STP-005) 10 MLD STP Singhpura, Rohtak by ULBD in February, 2012		232 dt. 10.01.2018		12	32	8.2	18			Complying	
			313. dt. 13.04.2018		16	48	7.9	18			Complying	
			89 dt. 07.07.2018		12	40	8.1	20			Complying	
			160 dt. 21.09.218		10	32	8.7	14			Complying	
			364 dt. 31.12.2018		16	40	8.3	20			Complying	
			548 dt. 03.04.2019		26	72	8.6	24			Complying	
			136-37 dt. 24.06.2019		24	88	7.9	40			Complying	
			291-92 dt. 13.9.2019		22	72	8.6	30			Complying	
			STP has been inspected on 20.11.2019 and found under maintenance, the effluent is being treated through 14 MLD STP.									
			TP has been inspected on 25.07.2020 and found under maintenance, the effluent is being treated through 14 MLD STP installed in the same premises.									
		29.08.2024	1247 dt. 04.09.2024		8	48	7.86	18	84	7	Complying	Complying
		28.09.2024	1449 dt. 04.10.2024		4	28	7.02	11	33	4.2	Complying	Complying
		25.12.2024	1994 dt. 02.01.2025		8.2	44.08	7.79	17	79	8.4	Complying	Complying
		31.01.2025	2356 dt. 11.02.2025		6.8	32.2	7.39	12	93	7	Complying	Complying
		25.02.2025	2506 dt. 05.03.2025		8.2	40.4	7.16	15	58	4.2	Complying	Complying
		19.03.2025	2620 dt. 26.03.2025		9.2	48.3	7.25	18	79	5.6	Complying	Complying
51	(RTK-STP-006) 14 MLD STP, Singhpura , Rohtak by PHED in 31.3.2015	08.01.2021	1616-1617 dt. 15.01.2021		8	44	7	10	2400	4	Complying	Complying
		15.02.2021	1317-1318 dt. 22.02.2021		12	56	8	24	5600		Non-Complying	Non-Complying
		20.03.2021	1508-1509 dt. 31.03.2021		8.9	48	8.2	12	4500		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		26.04.2021	142-143 dt. 04.05.2021		9.1	40	7.9	14	5600	3.2	Complying	Complying
		26.05.2021	257-258 dt. 03.06.2021		8.2	32	7.8	10	4800	2.1	Complying	Complying
		26.06.2021	438-439 dt. 02.07.2021		7.8	32	7.9	10	4200	2.1	Complying	Complying
	16.08.2021	31.07.2021	736-737 dt. 09.08.2021		8	32	8	10	4500	2.6	Complying	Complying
		28.08.2021	731-732 dt. 03.09.2021	3.9	7	40	7	9	1800	1.1	Complying	Complying
	28.10.2021	29.09.2021	1068-1069 dt. 06.10.2021	4	8.4	40	7.8	10	2200		Complying	Complying
	30.11.2021	30.10.2021	1313-1314 dt. 10.11.2021	4	7.2	32	7.6	9	94		Complying	Complying
	27.12.2021	29.11.2021	1474-1475 dt. 09.12.2021	4.5	7	48	8.2	18	82		Complying	Complying
	02.02.2022	28.12.2021	1642-1643 dt. 06.01.2022	5	7.6	40	8.1	14	90		Complying	Complying
	05.04.2022	28.02.2022	4332 dt. 14.03.2022	5 MLD	26	100	7.85	104	1700	4.85	Non-Complying	Non-Complying
	18.04.2022	30.03.2022	4785 dt. 08.04.2022		8	44	7.02	16	90	0.12	Complying	Complying
	20.05.2022	29.04.2022	5227 dt. 13.05.2022		7.2	44	7.52	18	70	1.03	Complying	Complying
	22.06.2022	26.05.2022	5591 dt. 08.06.2022		8	48	8.06	17	90	1.46	Complying	Complying
	09.07.2022	30.06.2022	103 dt. 08.07.2022		7	40	7.6	18	88	2.38	Complying	Complying
	09.08.2022	30.07.2022	448 dt. 09.08.2022		8	44	7.6	15	70	2.14	Complying	Complying
	09.09.2022	31.08.2022	592 dt. 07.09.2022		7	40	7.9	18	80	3.6	Complying	Complying
	07.10.2022	28.09.2022	700 dt. 06.10.2022		4	20	7.9	13	27	3.2	Complying	Complying
	07.11.2022	28.10.2022	889 dt. 4.11.2022		5	28	7.6	16	35	8.2	Complying	Complying
	13.12.2022	30.11.2022	1221 dt. 09.12.2022		7	39.2	7.3	18	40	6.4	Complying	Complying
	19.01.2023	31.12.2022	1566 dt. 11.01.2023		8	44.8	7.2	15	56	5.2	Complying	Complying
	15.02.2023	31.01.2023	1865 dt. 08.02.2023		7	44.8	7.8	18	63	4.2	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	10.03.2023	28.02.2023	2061 dt. 07.03.2023		8	41.2	7.2	16	77	3.1	Complying	Complying
	13.04.2023	30.03.2023	2385 dt. 10.04.2023		9	48.4	7.1	18	70	2.8	Complying	Complying
	05.05.2023	27.04.2023	102 dt. 04.05.2023		7	27.4	7.3	15	63	2.2	Complying	Complying
	16.06.2023	30.05.2023	257 dt. 06.06.2023		8	40.1	7.5	17	77	2.6	Complying	Complying
	15.07.2023	29.06.2023	432 dt. 08.07.2023		7	46.5	7.1	14	65	2.2	Complying	Complying
	11.08.2023	26.07.2023	824 dt. 03.08.2023		6	37.4	7.3	16	60	3.9	Complying	Complying
	15.09.2023	29.08.2023	1025 dt. 06.09.2023		8	44	7.8	19	76	3.2	Complying	Complying
	17.10.2023	27.09.2023	1192 dt. 07.10.2023		9	48	7.3	17	93	2.6	Complying	Complying
	08.11.2023	26.10.2023	1317 dt. 03.11.2023		8	40	7.4	13	80	1.2	Complying	Complying
	10.01.2024	29.12.2023	1651 dt. 08.01.2024		6	32	7.2	17	68	BDL	Complying	Complying
		28.05.2024	201 dt. 04.06.2024		4	20	7.45	11	39	1.4	Complying	Complying
		29.08.2024	1261 dt. 05.09.2024		8	48	7.81	17	79	4.2	Complying	Complying
		28.09.2024	1448 dt. 04.10.2024		9	48	7.53	19	63	7	Complying	Complying
		30.10.2024	1662 dt. 06.11.2024		8	40	7.49	15	70	1.4	Complying	Complying
		25.12.2024	1987 dt. 02.01.2025		6.5	32.06	7.81	11	63	2.8	Complying	Complying
		31.01.2025	2352 dt. 11.02.2025		9.2	42	7.24	19	49	9.8	Complying	Complying
		25.02.2025	2498 dt. 05.03.2025		5.6	28.2	7.17	16	70	5.6	Complying	Complying
		19.03.2025	2626 dt. 26.03.2025		8.2	47.4	7.06	14	33	4.2	Complying	Complying
52	(RTK-STP-007) 20 MLD STP Rohtak, Kanheli Road, HUDA on 30.8.2024	08.01.2021	1615 dt. 15.01.2021		115	312	6.8	216	210000		Non-Complying	Non-Complying
		15.02.2021	1319 dt. 22.02.2021		102	312	8.6	380	280000		Non-Complying	Non-Complying
		29.04.2021	162 dt. 10.05.2021		112	352	8.5	410	380000	48.4	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks	
		26.05.2021	259 dt. 03.06.2021		98	312	8.3	378	320000	42.6	Non-Complying	Non-Complying	
		26.06.2021	440 dt. 02.07.2021		104	336	8.4	386	280000	48.7	Non-Complying	Non-Complying	
	16.08.2021	31.07.2021	731 dt. 09.08.2021		110	352	8.5	380	320000	56.8	Non-Complying	Non-Complying	
		28.08.2021	726 dt. 03.09.2021		125	312	6.7	349	150000	37.6	Non-Complying	Non-Complying	
	28.10.2021	30.09.2021	1092 dt. 08.10.2021		104	376	8.4	350	250000		Non-Complying	Non-Complying	
	30.11.2021	30.10.2021	1312 dt. 10.11.2021		102	352	8.3	320	170000		Non-Complying	Non-Complying	
			Under Upgradation										
		25.12.2024	1990 dt. 02.01.2025		9.2	48.09	8.08	17	93	5.6	Complying	Complying	
		31.01.2025	2362 dt. 11.02.2025		8.5	40.8	7.44	19	79	8.4	Complying	Complying	
		25.02.2025	2500 dt. 05.03.2025		6.5	36.2	7.39	13	84	4.2	Complying	Complying	
		19.03.2025	2624 dt. 26.03.2026		8.4	40.3	7.19	15	58	2.8	Complying	Complying	
53	(RTK-STP-008) 4 MLD STP Sampla Town Rohtak by PHED in 2011	08.01.2021	1620-1620 dt. 15.01.2021		20	96	7.1	46	2100		Complying	Non-Complying	
		27.02.2021	1383-1384 dt. 08.03.2021		32	168	8	78	42000		Non-Complying	Non-Complying	
		27.04.2021	154-155 dt. 04.05.2021		24	104	7.9	52	15000	2.9	Complying	Non-Complying	
		25.05.2021	253-254 dt. 01.06.2021		22	96	7.8	46	1300	2.6	Complying	Non-Complying	
		24.06.2021	418-419 dt. 01.07.2021		18	80	7.8	34	9600	2.4	Complying	Non-Complying	
	16.08.2021	31.07.2021	732-733 dt. 09.08.2021		20	88	7.9	32	8000	3.2	Complying	Non-Complying	
		28.08.2021	722-723 dt. 03.09.2021	2.6	26	132	7.9	45	27000	3.8	Non-Complying	Non-Complying	
	28.10.2021	30.09.2021	1093-1094 dt. 08.10.2021	3	24	96	8.1	46	9600		Non-Complying	Non-Complying	
	30.11.2021	30.10.2021	1310-1311 dt. 10.11.2021	2.5	36	112	8.2	48	12000		Non-Complying	Non-Complying	
	27.12.2021	29.11.2021	1472-1473 dt. 09.12.2021	3	34	208	8.2	124	9600		Non-Complying	Non-Complying	
	02.02.2022	29.12.2021	1662-1663 dt. 06.01.2022	3.5	32	176	8.1	84	8200		Non-Complying	Non-Complying	
	05.04.2022	28.02.2022	4336 dt. 14.03.2022		20	92	7.72	72	800	3.96	Non-Complying	Non-Complying	

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		18.04.2022	30.03.2022	4783 dt. 08.04.2022	14	72	7.48	36	800	2.28	Non-Complying	Non-Complying
		20.05.2022	29.04.2022	5226 dt. 13.05.2022	17	112	7.97	48	600	6.18	Non-Complying	Non-Complying
		22.06.2022	26.05.2022	5589 dt. 08.06.2022	16	92	7.58	32	1100	3.85	Non-Complying	Non-Complying
		09.07.2022	30.06.2022	100 dt. 08.07.2022	21	88	8.1	28	900	2.78	Non-Complying	Non-Complying
		09.08.2022	30.07.2022	446 dt. 09.08.2022	18	72	7.4	39	700	3.24	Non-Complying	Non-Complying
		09.09.2022	31.08.2022	590 dt. 06.09.2022	48	208	7.6	84	900	4.3	Non-Complying	Non-Complying
		07.10.2022	28.09.2022	696 dt. 06.10.2022	24	96	7.5	52	700	3.7	Non-Complying	Non-Complying
		07.11.2022	28.10.2022	895 dt. 7.11.2022	75	296	6.8	125	1300	5.2	Non-Complying	Non-Complying
		13.12.2022	30.11.2022	1217 dt. 09.12.2022	70	277.4	7.4	85	1700	3.6	Non-Complying	Non-Complying
		19.01.2023	31.12.2022	1565 dt. 11.01.2023	25	118.2	7.3	42	900	3.1	Non-Complying	Non-Complying
		15.02.2023	31.01.2023	1867 dt. 08.02.2023	22	96.3	7.6	56	700	2.7	Non-Complying	Non-Complying
		10.03.2023	28.02.2023	2058 dt. 07.03.2023	35	149.4	7.9	84	1100	3.3	Non-Complying	Non-Complying
		13.04.2023	30.03.2023	2382 dt. 10.04.2023	42	172.8	8.1	95	1300	4.6	Non-Complying	Non-Complying
		05.05.2023	27.04.2023	103 dt. 04.05.2023	49	209.8	7.8	135	1900	5.4	Non-Complying	Non-Complying
		16.06.2023	30.05.2023	254 dt. 06.06.2023	62	248.9	7.2	120	2300	6.2	Non-Complying	Non-Complying
		15.07.2023	29.06.2023	429 dt. 08.07.2023	55	214.1	7.5	82	2900	5.8	Non-Complying	Non-Complying
		11.08.2023	26.07.2023	821 dt. 03.08.2023	62	249.9	7.7	76	3200	4.8	Non-Complying	Non-Complying
		15.09.2023	29.08.2023	1022 dt. 06.09.2023	46	192	7.2	58	2600	3.6	Non-Complying	Non-Complying
		17.10.2023	27.09.2023	1198 dt. 09.10.2023	58	232	7.8	66	3400	2.8	Non-Complying	Non-Complying
		09.11.2023	26.10.2023	1322 dt. 03.11.2023	46	192	7.3	58	4200	3.2	Non-Complying	Non-Complying
		19.12.2023	30.11.2023	1471 dt. 11.12.2023	54	216	7.5	72	3800	2.3	Non-Complying	Non-Complying
		10.01.2024	29.12.2023	1649 dt. 08.01.2024	46	184	7.1	64	3200	1.7	Non-Complying	Non-Complying
			28.05.2024	204 dt. 04.06.2024	44	180	7.25	80	2400	5.6	Non-Complying	Non-Complying
			28.06.2024	449 dt. 10.07.2024	37	152	7.1	75	1900	7	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		29.08.2024	1260 dt. 04.09.2024		7	44	7.42	13	41	4.2	Complying	Complying
		28.09.2024	1444 dt. 04.10.2024		6	32	7.33	17	53	8.4	Complying	Complying
		25.12.2024	1985 dt. 02.01.2025		7.6	40.08	7.53	18	84	7	Complying	Complying
		19.03.2025	2621 dt. 26.03.2025		9.6	44.3	7.12	16	49	8.4	Complying	Complying
54	(RTK-STP-009) 12 MLD STP, Garhi Bohar, Rohtak by ULBD in 31.03.2022											
		29.08.2024	1259 dt. 05.09.2024		8	48	7.64	19	79	5.6	Complying	Complying
		28.09.2024	1446 dt. 04.10.2024		6	36	7.33	15	41	2.8	Complying	Complying
		30.10.2024	1661 dt. 06.11.2024		7	36	7.41	11	79	8.4	Complying	Complying
		25.12.2024	1991 dt. 02.01.2025		8.2	40.08	8.07	14	58	7	Complying	Complying
		31.01.2025	2353 dt. 11.02.2025		7.8	33.6	7.54	18	70	5.6	Complying	Complying
		25.02.2025	2505 dt. 05.03.2025		7.4	44.8	7.43	16	93	9.8	Complying	Complying
		19.03.2025	2625 dt. 26.03.2025		6.2	28.2	7.19	18	84	2.8	Complying	Complying
55	(RTK-STP-010) 10 MLD STP, Rohtak by HSVP in 31.03.2023											
	Jan, 2024											
	Feb, 2024											
	Mar, 2024											
56	(RTK-STP-011) 15 MLD STP, Peer Bodhi, Rohtak by ULBD in 31.12.2023	28.09.2024	1447 dt. 04.10.2024		7	44	7.33	14	79	5.6	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		30.10.2024	1659 dt. 06.11.2024		5	28	7.85	17	63	2.8	Complying	Complying
		25.12.2024	1989 dt. 02.01.2025		4	24	8.15	12	70	8.4	Complying	Complying
		31.01.2025	2354 dt. 11.02.2025		7.2	35.5	7.65	17	58	4.2	Complying	Complying
		25.02.2025	2499 dt. 05.03.2025		6.8	40.3	7.84	18	93	7	Complying	Complying
		19.03.2025	2619 dt. 26.03.2025		7.4	28.2	7.25	15	70	9.8	Complying	Complying
	Gurgaon North											
57	(GRN-STP-001) 68 MLD STP Dhanwapur, Gurgaon (North) by GMDA in January, 2004	13.02.2021	1967-1968 dt. 19.02.2021		8	44	7.5	7	430		Complying	Complying
		06.03.2021	2077-2078 dt. 15.03.2021	48.6	5	40	7.9	8	7000	1.4	Complying	Complying
		10.04.2021	31-32 dt. 17.04.2021	63.9	6	40	7.4	8	320	1	Complying	Complying
		10.05.2021	99-100 dt. 17.05.2021	64.7	7	40	7	9	190	0.9	Complying	Complying
		09.06.2021	193-194 dt. 15.06.2021	63.1	6	36	7.2	9	170	0.7	Complying	Complying
		08.07.2021	381-382 dt. 17.07.2021	63.7	7	40	7.4	9	270	0.8	Complying	Complying
		09.08.2021	639-640 dt. 16.08.2021	66.3	5	32	7.7	7	320	0.9	Complying	Complying
		09.09.2021	800-801 dt. 16.09.2021	66.8	6	36	7.6	9	340	0.7	Complying	Complying
	29.10.2021	08.10.2021	1194-1195 dt. 19.10.2021		9	32	7.4	12	72		Complying	Complying
	23.11.2021	10.11.2021	1090-1091 dt. 16.11.2021	-	8	40	7.4	10	86	2.6	Complying	Complying
	15.12.2021	02.12.2021	1185-1186 dt. 09.12.2021	-	9	44	7.2	9	76	2.2	Complying	Complying
	04.02.2022	11.01.2022	1794-1795 dt. 21.01.2022		8	40	7.3	10	56		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	06.04.2022	23.02.2022	4254 dt. 07.03.2022		9	56	7.77	24	30	1.32	Complying	Complying
	15.04.2022	22.03.2022	4665 dt. 31.03.2022		4.5	36	7.35	10	60	0.21	Complying	Complying
	20.05.2022	29.04.2022	5243 dt. 17.05.2022		4.5	28	6.09	13	70	0.69	Complying	Complying
	10.06.2022	18.05.2022	5472 dt. 29.05.2022		8.6	48	7.74	17	90	0.78	Complying	Complying
	12.07.2022	30.06.2022	121 dt. 11.07.2022		9	44	6.9	17	80	1.2	Complying	Complying
	09.08.2022	29.07.2022	429 dt. 08.08.2022		28	136	7.1	23	200	1.5	Non complying	Non complying
	08.09.2022	25.08.2022	554 dt. 02.09.2022		8	46	7.2	15	90	1.8	Complying	Complying
		28.09.2022	709 dt. 07.10.2022		6	28	7.4	11	70	1.5	Complying	Complying
	02.11.2022	26.10.2022	857 dt. 01.11.2022		9	44	8.5	13	60	1.8	Complying	Complying
	08.12.2022	28.11.2022	1201 dt. 08.12.2022		5	36.3	6.2	11	20	1.2	Complying	Complying
	30.12.2022	21.12.2022	1439 dt. 28.12.2022		6	40.4	6.9	19	40	1.4	Complying	Complying
	14.02.2023	28.01.2023	1826 dt. 04.02.2023		8	36.1	7.2	16	33	1.1	Complying	Complying
	07.03.2023	23.02.2023	2034 dt. 03.03.2023		9	44.8	7.3	18	50	1.4	Complying	Complying
	13.04.2023	22.03.2023	2259 dt. 31.03.2023		8	48.4	7.4	17	77	1.8	Complying	Complying
	16.06.2023	29.05.2023	251 dt. 06.06.2023		6	40.1	7.1	14	60	1.6	Complying	Complying
	15.07.2023	27.06.2023	415 dt. 05.07.2023		8	44.4	7.2	17	77	1.8	Complying	Complying
	11.08.2023	24.07.2023	790 dt. 2.08.2023		9	47.4	7.5	18	83	2.1	Complying	Complying
	11.09.2023	26.08.2023	997 dt. 02.09.2023		6	44	7.6	12	78	1.4	Complying	Complying
	03.11.2023	30.09.2023	1242 dt. 20.10.2023		5	36	7	14	93	1.2	Complying	Complying
	16.11.2023	30.10.2023	1359 dt. 07.11.2023		7	44	7.5	18	80	BDL	Complying	Complying
	19.12.2023	30.11.2023	1480 dt. 11.12.2023		16	72	7.3	26	170	2.6	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	19.01.2024	30.12.2023	1667 dt. 09.01.2024		8	48	7.1	13	93	2.3	Complying	Complying
		30.01.2024	1989 dt. 06.02.2024		6	40	7.38	18	78	2.1	Complying	Complying
		27.02.2024	2166 dt. 06.03.2024		7	44	7.98	15	70	1.8	Complying	Complying
		30.03.2024	2367 dt. 10.04.2024		9	48	7.61	18	84	1.4	Complying	Complying
		29.04.2024	108 dt. 06.05.2024		5	32	7.15	13	63	2.8	Complying	Complying
		30.05.2024	250 dt. 07.06.2024		6	36	7.18	19	77	4.2	Complying	Complying
		28.06.2024	452 dt. 10.07.2024		8	40	7.33	15	69	2.8	Complying	Complying
		30.07.2024	999 dt. 08.08.2024		7	36	7.43	17	83	5.6	Complying	Complying
		29.08.2024	1255 dt. 05.09.2024		8	40	7.19	12	94	2.8	Complying	Complying
		25.09.2024	1418 dt. 01.10.2024		7	40	7.02	15	84	4.2	Complying	Complying
		28.10.2024	1642 dt. 05.11.2024		6	48	7.26	18	63	7	Complying	Complying
		21.11.2024	1756 dt. 28.11.2024		4	24	7.9	17	53	4.2	Complying	Complying
58	(GRN-STP-002) 100 MLD STP Dhanwapur, Gurgoan by GMDA in 1.12.2014	27.01.2021	1871-1872-1873 dt. 02.02.2021		7	36	7.5	9	2400		Complying	Complying
		13.02.2021	1969-1970 dt. 19.02.2021		7	40	7.1	8	2700		Complying	Complying
		06.03.2021	2079-2080 dt. 15.03.2021	37.2	13	64	8.5	18	9000	2.1	Non complying	Non complying
		10.04.2021	33-34 dt. 17.04.2021	84.1	14	60	8.1	17	11000	2.6	Non complying	Non complying
		10.05.2021	95-96 dt. 17.05.2021	75.3	13	56	7.7	18	9000	1.6	Non complying	Non complying
		09.06.2021	197-198 dt. 15.06.2021	76.4	11	52	7.5	16	8600	1.1	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		08.07.2021	383-384 dt. 17.07.2021	78.3	12	64	7.4	17	7400	2	Non complying	Non complying
		09.08.2021	641-642 dt. 16.08.2021	88	9	56	7.2	15	4400	1.4	Complying	Complying
		09.09.2021	802-803 dt. 16.09.2021	91	10	60	7.4	17	4700	1.1	Complying	Complying
	23.11.2021	10.11.2021	1088-1089 dt. 16.11.2021	-	14	56	7.6	24	2900	2.2	Non complying	Non complying
	15.12.2021	02.12.2021	1183-1184 dt. 09.12.2021	-	12	52	7.3	29	2700	1.9	Non complying	Non complying
	04.02.2022	11.01.2022	1796-1797 dt. 21.01.2022		16	64	7.2	28	2100		Non complying	Non complying
	06.04.2022	23.02.2022	4252 dt. 07.03.2022		13	64	7.45	29	80	1.03	Non complying	Non complying
	15.04.2022	22.03.2022	4664 dt. 31.03.2022		17	76	7.51	22	200	0.25	Non complying	Non complying
	20.05.2022	29.04.2022	5244 dt. 17.05.2022		18	72	7.47	38	400	1.94	Non complying	Non complying
	10.06.2022	18.05.2022	5474 dt. 29.05.2022		135	500	7.29	432	2100	16.75	Non complying	Non complying
	09.08.2022	29.07.2022	428 dt. 08.08.2022		25	112	7.3	33	800	3.8	Non complying	Non complying
	08.09.2022	25.08.2022	555 dt. 02.09.2022		23	104	7.1	28	700	2.4	Non complying	Non complying
		28.09.2022	708 dt. 07.10.2022		28	136	7.8	52	600	2.1	Non complying	Non complying
	02.11.2022	26.10.2022	856 dt. 01.11.2022		21	88	7.6	28	700	1.7	Non complying	Non complying
	08.12.2022	28.11.2022	1199 dt. 08.12.2022		24	96.9	6.8	33	900	2.2	Non complying	Non complying
	30.12.2022	21.12.2022	1441 dt. 28.12.2022		21	82.3	7.2	26	1100	3.3	Non complying	Non complying
	14.02.2023	28.01.2023	1824 dt. 04.02.2023		24	112.4	7.8	55	1300	2.6	Non complying	Non complying
	07.03.2023	23.02.2023	2033 dt. 03.03.2023		13	64.6	7.5	22	400	2.1	Non	Non
	13.04.2023	22.03.2023	2258 dt. 31.03.2023		24	96.9	7.9	28	700	2.6	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	16.06.2023	29.05.2023	250 dt. 06.06.2023		15	72.2	7.8	26	630	2.2	Non complying	Non complying
	15.07.2023	27.06.2023	414 dt. 05.07.2023		17	92.9	7.2	32	770	2.8	Non complying	Non complying
	11.08.2023	24.07.2023	788 dt. 2.08.2023		19	105.8	6.9	28	840	3.3	Non complying	Non complying
	11.09.2023	26.08.2023	996 dt. 02.09.2023		25	136	7.8	42	720	2.8	Non complying	Non complying
	03.11.2023	30.09.2023	1241 dt. 20.10.2023		16	68	7.2	37	180	1.2	Non complying	Non complying
	16.11.2023	30.10.2023	1361 dt. 07.11.2023		23	96	7.1	36	320	2.6	Non complying	Non complying
	19.12.2023	30.11.2023	1479 dt. 11.12.2023		92	368	7.4	128	760	6.4	Non complying	Non complying
	19.01.2024	30.12.2023	1668 dt. 09.01.2024		19	120	7.2	38	380	5.2	Non complying	Non complying
		27.02.2024	2165 dt. 06.03.2024		55	224	6.78	96	400	4.1	Non complying	Non complying
		30.03.2024	2365 dt. 08.04.2024		52	208	6.24	86	330	5.6	Non complying	Non complying
		29.04.2024	106 dt. 06.05.2024		44	176	6.15	65	470	8.4	Non complying	Non complying
		30.05.2024	251 dt. 07.06.2024		18	80	6.76	32	330	7	Non complying	Non complying
		28.06.2024	451 dt. 10.07.2024		16	72	7.2	38	170	5.6	Non complying	Non complying
		30.07.2024	1000 dt. 08.08.2024		19	104	7.54	37	290	8.4	Non complying	Non complying
		29.08.2024	1254 dt. 05.09.2024		21	136	7.21	42	330	9.8	Non complying	Non complying
		25.09.2024	1417 dt. 01.10.2024		24	92	7.09	35	490	14.01	Non complying	Non complying
		21.11.2024	1757 dt. 28.11.2024		5	28	7.44	27	79	8.4	Complying	Complying
59	(GRN-STP-003) 50 MLD STP Dhanwapur, Gurgaon (North) by ULB/ MCG in 1.10.2018	13.02.2021	1965-1966 dt. 19.02.2021		8	44	7	9	370	2.8	Complying	Complying
		06.03.2021	2075-2076 dt. 12.03.2021	32.2	4	28	7.1	9	86	ND	Complying	Complying
		10.04.2021	35-36 dt. 17.04.2021	48.4	4	24	7.5	4	72	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		10.05.2021	97-98 dt. 17.05.2021	47.1	4	28	7.8	5	66	ND	Complying	Complying
		09.06.2021	199-200 dt. 15.06.2021	48.2	4	24	7.1	5	58	ND	Complying	Complying
		08.07.2021	385-386 dt. 17.07.2021	48.2	5	28	7	6	64	ND	Complying	Complying
		09.08.2021	637-638 dt. 16.08.2021	49.3	4	20	7.1	6	56	ND	Complying	Complying
		09.09.2021	798-799 dt. 16.09.2021	49.6	4	24	7.3	5	52	ND	Complying	Complying
		08.10.2021	1192-1193 dt. 19.10.2021		6	24	7.6	9	720		Complying	Complying
	23.11.2021	10.11.2021	1092-1093 dt. 16.11.2021	-	5	28	7.7	7	62	0.5	Complying	Complying
	15.12.2021	02.12.2021	1181-1182 dt. 09.12.2021	-	6	32	7.5	9	72	0.4	Complying	Complying
	04.02.2022	11.01.2022	1798-1799 dt. 21.01.2022		5	16	7.7	8	45		Complying	Complying
	06.04.2022	23.02.2022	4252 dt. 07.03.2022		13	64	7.45	29	80	1.03	Non complying	Non complying
	15.04.2022	22.03.2022	4663 dt. 31.03.2022		4.2	40	7.65	11	80	0.19	Complying	Complying
	20.05.2022	29.04.2022	5245 dt. 17.05.2022		16	68	7.54	37	600	2.47	Non complying	Non complying
	10.06.2022	18.05.2022	5473 dt. 29.05.2022		15	70	7.3	38	500	2.14	Non complying	Non complying
	12.07.2022	30.06.2022	120 dt. 11.07.2022		22	88	7.5	43	600	2.6	Non complying	Non complying
	09.08.2022	29.07.2022	427 dt. 08.08.2022		6	40	7.3	14	90	1.2	Complying	Complying
	08.09.2022	25.08.2022	553 dt. 02.09.2022		5	36	7.1	17	70	1.4	Complying	Complying
		28.09.2022	710 dt. 07.10.2022		7	40	7.3	16	80	1.6	Complying	Complying
	02.11.2022	26.10.2022	859 dt. 01.11.2022		8	44	6.8	18	88	1.9	Complying	Complying
	08.12.2022	28.11.2022	1200 dt. 08.12.2022		6	40.4	7.1	13	70	1.7	Complying	Complying
	30.12.2022	21.12.2022	1440 dt. 28.12.2022		9	48.9	7.4	17	90	2.1	Complying	Complying
	14.02.2023	28.01.2023	1823 dt. 04.02.2023		7	32.3	7.6	18	77	1.7	Complying	Complying
	07.03.2023	23.02.2023	2032 dt. 03.03.2023		8	40.4	7.4	15	88	1.9	Complying	Complying
	13.04.2023	22.03.2023	2260 dt. 31.03.2023		7	32.3	7.2	16	80	1.4	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	Feb, 2024											
	Mar, 2024											
65	(GRN-STP-010) 1 MLD STP, Bandwari (shifted from Sihi/ Khedki Daula), Gurugram by ULB in 31.10.2021											
	Jan, 2024											
	Feb, 2024											
	Mar, 2024											
66	(GRN-STP-011) 20 MLD STP, Jhazgarh, Gurugram by GMDA in 31.13.2023											
	Jan, 2024											
	Feb, 2024											
	Mar, 2024											
	NUH											
67	(NUH-STP-001) 4.5 MLD STP Punhana, Mewat by PHED in 31.12.2015	29.01.2021	515 dt. 08.02.2021		23	112	7.3	38	48000		Complying	Non complying
		18.02.2021	535 dt. 01.03.2021	2.44	26	120	6.9	44	51000		Complying	Non complying
		31.03.2021	9 dt. 09.04.2021	3	29	136	7.6	64	72000		Complying	Non complying
		27.04.2021	48 dt. 06.05.2021		38	176	7.7	78	86000		Non complying	Non complying
		27.05.2021	61 dt. 04.06.2021		27	128	7.2	48	74000		Complying	Non complying
		23.06.2021	107 dt. 01.07.2021		25	104	7.4	52	76000		Complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks	
	25.07.2021	245 dt. 03.08.2021	4.7	24	96	7.5	45	71000	7.2	Complying	Non complying	
	24.08.2021	353 dt. 31.08.2021		58	232	7.6	108	73000	7.6	Non complying	Non complying	
	24.09.2021	420 dt. 01.10.2021	2	92	368	7.4	138	68200	7.9	Non complying	Non complying	
	02.12.2021	30.10.2021	490 dt. 9.11.2021	1.4	72	288	7.9	152	52000	7.6	Non complying	Non complying
	15.12.2021	26.11.2021	536 dt. 03.12.2021	1.25	75	304	8	168	48000	7.9	Non complying	Non complying
	21.01.2022	21.12.2021	3432 dt. 31.12.2021		145	552	7.93	120	4800	3.14	Non complying	Non complying
	10.02.2022	28.01.2022	3956 dt. 08.02.2022	1.3 MLD	27	158	7.64	76	800	2.11	Non complying	Non complying
	06.04.2022	25.02.2022	4289 dt. 10.03.2022		28	104	7.64	46	1400	8.64	Non complying	Non complying
	15.04.2022	12.03.2022	4573 dt. 29.03.2022		24	132	7.47	47	2100	2.14	Non complying	Non complying
	04.05.2022	07.04.2022	4946 dt. 27.04.2022		52	196	7.56	98	1700	1.92	Non complying	Non complying
	10.06.2022	14.05.2022	5454 dt. 27.05.2022		52	212	7.76	148	2100	5.46	Non complying	Non complying
	30.06.2022	21.06.2022	35 dt. 29.06.2022		58	220	7.8	142	2000	3.4	Non complying	Non complying
	06.08.2022	27.07.2022	405 dt. 04.08.2022		50	208	7.6	48	1800	3.9	Non complying	Non complying
	08.09.2022	27.08.2022	566 dt. 03.09.2022		54	216	8.3	58	1700	2.7	Non complying	Non complying
	07.10.2022	28.09.2022	706 dt. 07.10.2022		13	64	7.6	45	1800	3.1	Non complying	Non complying
	07.11.2022	28.10.2022	886 dt. 04.11.2022		21	92	8.3	88	2100	3.6	Non complying	Non complying
	05.12.2022	25.11.2022	1156 dt. 05.12.2022		18	96.9	7.9	42	2900	4.1	Non complying	Non complying
	07.01.2023	22.12.2022	1461 dt. 02.01.2023		28	170.6	7.4	85	3500	6.9	Non complying	Non complying
	15.02.2023	31.01.2023	1875 dt. 08.02.2023		26	152.6	7.6	72	4500	7.2	Non complying	Non complying
	07.03.2023	25.02.2023	2046 dt. 06.03.2023		48	214.8	8.2	142	6700	9.6	Non complying	Non complying
	08.04.2023	23.03.2023	2270 dt. 31.03.2023		65	298.3	8.1	198	7500	10.2	Non complying	Non complying
	28.04.2023	20.04.2023	84 dt. 27.04.2023		42	177.7	8.1	85	6100	7.1	Non complying	Non complying
	13.06.2023	26.05.2023	218 dt. 02.06.2023		45	184.2	7.9	76	5100	6.2	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	15.07.2023	24.06.2023	398 dt. 03.07.2023		40	168.5	7.2	65	4700	5.4	Non complying	Non complying
	14.08.2023	27.07.2023	844 dt. 05.08.2023		29	123.6	6.9	56	5600	6.2	Non complying	Non complying
	15.09.2023	31.08.2023	1036 dt. 11.09.2023		27	112	7.1	62	4800	5.4	Non complying	Non complying
	17.10.2023	28.09.2023	1203 dt. 09.10.2023		24	96	7.5	58	4100	4.8	Non complying	Non complying
	08.11.2023	26.10.2023	1312 dt. 03.11.2023		27	124	7.8	66	5300	4.2	Non complying	Non complying
	12.12.2023	28.11.2023	1442 dt. 06.12.2023		25	108	7.2	48	4600	3.9	Non complying	Non complying
	Feb, 2024	26.02.2024	2147 dt. 06.03.2024	-	23	108	7.19	62	3600	2.8	Non complying	Non complying
	Mar, 2024	22.03.2024	2310 dt. 01.04.2024		25	120	7.41	46	2700	5.6	Non complying	Non complying
		27.04.2024	97 dt. 3.05.2024		29	168	7.7	85	3100	7	Non complying	Non complying
		28.05.2024	208 dt. 04.06.2024		27	152	7.04	70	3900	8.4	Non complying	Non complying
		29.06.2024	471 dt. 11.07.2024		29	176	7.36	65	2400	9.3	Non complying	Non complying
		26.07.2024	955 dt. 06.08.2024		23	96	7.47	45	1100	8.4	Non complying	Non complying
		30.08.2024	1276 dt. 05.09.2024		29	128	7.19	55	1400	7	Non complying	Non complying
		22.10.2024	1592 dt. 29.10.2024		28	184	8.15	80	1700	12.6	Non complying	Non complying
68	(NUH-STP-002) 3.6 MLD Nuh, Mewat by PHED in 25.11.2016	25.01.2021	506 dt. 02.02.2021		26	108	7.5	38	29000		Complying	Non complying
		18.02.2021	536 dt. 01.03.2021	2.4	23	92	7.1	46	34000		Complying	Non complying
		31.03.2021	8 dt. 09.04.2021	2.5	26	104	7.4	54	47000		Complying	Non complying
		27.04.2021	47 dt. 06.05.2021		27	112	7.6	48	54000		Complying	Non complying
		27.05.2021	64 dt. 04.6.2021		21	80	7.4	42	49000		Complying	Non complying
		23.06.2021	106 dt. 01.07.2021		19	72	7.8	38	42000		Complying	Non complying
		25.07.2021	244 dt. 3.08.2021	2	17	68	7.6	34	38000	5.4	Complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	24.08.2021	352 dt. 31.08.2021		19	84	7.7	38	31200	5.6	Non complying	Non complying
02.12.2021	30.10.2021	492 dt. 09.11.2021		18	76	7.7	48	21000	5.6	Non complying	Non complying
15.12.2021	26.11.2021	535 dt. 03.12.2021	2.4	24	96	7.3	56	16000	5.2	Non complying	Non complying
21.01.2022	21.12.2021	3434 dt. 31.12.2021	2.5 MLD	14	76	7.78	23	800	1.32	Non complying	Non complying
10.02.2022	28.01.2022	3955 dt. 08.02.2022	2.3 MLD	7.6	48	7.72	18	200	1.88	Complying	Complying
06.04.2022	25.02.2022	4288 dt. 10.03.2022		48	164	7.1	188	1700	8.5	Non complying	Non complying
15.04.2022	12.03.2022	4574 dt. 29.03.2022		17	120	7.51	35	1500	1.97	Non complying	Non complying
20.05.2022	30.04.2022	5250 dt. 17.05.2022		14	68	7.09	35	600	1.95	Non complying	Non complying
10.06.2022	14.05.2022	5453 dt. 27.05.2022	1.12m ³ /h	15	80	7.47	33	1200	1.46	Non complying	Non complying
30.06.2022	21.06.2022	33 dt. 29.06.2022		21	96	7.3	38	900	2.87	Non complying	Non complying
06.08.2022	27.07.2022	402 dt. 04.08.2022		25	112	7.2	32	1400	3.3	Non complying	Non complying
08.09.2022	27.08.2022	564 dt. 03.09.2022	330	35	144	7.7	42	1700	2.4	Non complying	Non complying
07.10.2022	28.09.2022	703 dt. 06.10.2022		7	24	7.9	46	1300	2.7	Complying	Complying
07.11.2022	28.10.2022	888 dt. 04.11.2022		19	88	7.8	36	1500	2.9	Non complying	Non complying
05.12.2022	25.11.2022	1155 dt. 05.12.2022		80	315.1	7.1	120	3500	4.7	Non complying	Non complying
07.01.2023	22.12.2022	1462 dt. 02.01.2023		88	357.6	7.2	145	4000	5.7	Non complying	Non complying
15.02.2023	31.01.2023	1876 dt. 08.02.2023		104	437.7	7.8	290	6300	8.6	Non complying	Non complying
07.03.2023	25.02.2023	2047 dt. 06.03.2023		98	395.9	8.1	248	7200	9.1	Non complying	Non complying
08.04.2023	23.03.2023	2269 dt. 31.03.2023		105	420.1	8.4	260	8100	9.8	Non complying	Non complying
21.04.2023	12.04.2023	60 dt. 19.04.2023		96	392.4	8.1	245	7300	8.6	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	13.06.2023	26.05.2023	215 dt. 02.06.2023		102	407.6	7.9	270	7000	9.1	Non complying	Non complying
	15.07.2023	24.06.2023	397 dt. 03.07.2023		38	160.7	7.5	92	6700	7.5	Non complying	Non complying
	14.08.2023	27.07.2023	845 dt. 05.08.2023		25	116.5	7.1	84	5200	6.8	Non complying	Non complying
	15.09.2023	31.08.2023	1039 dt. 11.09.2023		29	144	7.6	92	5800	6.2	Non complying	Non complying
	17.10.2023	28.09.2023	1201 dt. 09.10.2023		25	112	7.1	70	6500	5.4	Non complying	Non complying
	08.11.2023	26.10.2023	1314 dt. 03.11.2023		21	80	7.8	62	5800	4.6	Non complying	Non complying
	12.12.2023	28.11.2023	1444 dt. 06.12.2023		28	136	7.3	54	7200	3.5	Non	Non
	09.01.2024	22.12.2023	1603 dt. 02.01.2024		26	104	7.5	42	4900	3.7	Non complying	Non complying
		29.01.2024	1982 dt. 06.02.2024		25	116	7.26	60	4600	2.9	Non complying	Non complying
	Feb, 2024	26/02/2024	2148, 06/03/2024		28	124	7.89	47	3400	3.2	Non complying	Non complying
	Mar, 2024	27/03/2024	2322, 04/04/2024		29	176	7.4	72	4600	2.8	Non complying	Non complying
		27.04.2024	94 dt. 3.05.2024		27	152	6.89	80	4100	1.4	Non complying	Non complying
		29.06.2024	470 dt. 11.07.2024		28	168	6.26	75	3900	8.4	Non complying	Non complying
		26.07.2024	956 dt. 06.08.2024		24	136	7.5	50	1700	9.4	Non complying	Non complying
		29.08.2024	1251 dt. 04.09.2024		26	152	7.84	65	2100	9.8	Non complying	Non complying
		21.10.2024	1584 dt. 28.10.2024		25	152	7.39	75	1500	9.8	Non complying	Non complying
69	(NUH-STP-003) 4.5 MLD STP Tauru, Mewat by PHED in 30.6.2017	27.01.2021	507 dt. 04.02.2021		26	112	7.1	42	58000		Complying	Non complying
		18.02.2021	533 dt. 01.03.2021	2.7	21	96	6.9	44	59000		Complying	Non complying
		31.03.2021	6 dt. 09.04.2021	3	25	112	7.3	58	63000		Complying	Non complying
		27.04.2021	27.04.2021 dt. 06.05.2021	2.65	23	108	7.2	54	75000		Complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	19.05.2021	58 dt. 28.05.2021	2.3	21	96	7.4	28	68000		Complying	Non complying
	23.06.2021	104 dt. 01.07.2021	2.3	24	108	7.2	48	74000		Complying	Non complying
	25.07.2021	242 dt. 03.08.2021	2.3	20	80	7.1	32	61000	6.2	Complying	Non complying
	24.08.2021	355 dt. 31.08.2021	2.45	18	76	7.8	29	49200	5.8	Non complying	Non complying
	30.10.2021	493 dt. 09.11.2021		21	96	7.6	38	37000	6.3	Non complying	Non complying
02.12.2021	19.11.2021	526 dt. 26.11.2021	2.45	19	84	7.4	6.1	32000	6.1	Non complying	Non complying
21.01.2022	21.12.2021	3433 dt. 31.12.2021		72	248	7.54	124	1100	20.31	Non complying	Non complying
10.02.2022	28.01.2022	3954 dt. 08.02.2022	2.5 MLD	9	52	7.67	38	400	2.28	Complying	Complying
06.04.2022	25.02.2022	4290 dt. 10.03.2022		14	64	7.74	29	400	0.34	Complying	Complying
15.04.2022	12.03.2022	4571 dt. 29.03.2022		14	76	7.66	36	1700	1.08	Non complying	Non complying
04.05.2022	07.04.2022	4945 dt. 27.04.2022		15	80	7.26	32	800	1.02	Non complying	Non complying
10.06.2022	14.05.2022	5456 dt. 27.05.2022		14	72	7.39	27	1100	2.46	Non complying	Non complying
30.06.2022	21.06.2022	34 dt. 29.06.2022		23	104	7.2	38	1600	2.7	Non complying	Non complying
06.08.2022	27.07.2022	403 dt. 04.08.2022	229	72	296	7.4	48	2400	3.5	Non complying	Non complying
08.09.2022	27.08.2022	565 dt. 03.09.2022	184	46	188	7.8	42	1800	3.3	Non complying	Non complying
07.10.2022	28.09.2022	705 dt. 07.10.2022	150.7	24	96	8.4	29	1500	3.9	Non complying	Non complying
07.11.2022	28.10.2022	885 dt. 04.11.2022		42	168	7.6	78	3300	6.8	Non complying	Non complying
05.12.2022	25.11.2022	1153 dt. 05.12.2022	215	16	64.6	7.3	29	2900	4.8	Non complying	Non complying
07.01.2023	22.12.2022	1460 dt. 02.01.2023		26	150.3	7.1	52	3300	4.1	Non complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	15.02.2023	31.01.2023	1877 dt. 08.02.2023	34	138.7	8.2	122	4000	3.7	Non complying	Non complying
	07.03.2023	25.02.2023	2049 dt. 06.03.2023	38	150.4	7.9	136	4800	4.2	Non complying	Non complying
	08.04.2023	22.03.2023	2261 dt. 31.03.2023	48	197.9	7.6	142	5500	3.7	Non complying	Non complying
	21.04.2023	12.04.2023	61 dt. 19.04.2023	102	471.2	7.1	160	5900	4.4	Non complying	Non complying
	13.06.2023	26.05.2023	216 dt. 02.06.2023	72	301.9	8.3	125	5200	1.6	Non complying	Non complying
	15.07.2023	24.06.2023	400 dt. 03.07.2023	20	78.4	8.1	39	4100	1.2	Non complying	Non complying
	14.08.2023	27.07.2023	843 dt. 05.08.2023	22	84.5	7.7	46	4900	1.8	Non complying	Non complying
	15.09.2023	31.08.2023	1038 dt. 11.09.2023	26	104	7.5	58	4600	1.2	Non complying	Non complying
	17.10.2023	27.09.2023	1200 dt. 09.10.2023	27	124	7.3	46	4200	1.8	Non complying	Non complying
	08.11.2023	26.10.2023	1313 dt. 03.11.2023	28	136	7.1	52	3600	1.3	Non complying	Non complying
	12.12.2023	28.11.2023	1441 dt. 06.12.2023	24	112	7.5	65	4800	1.5	Non complying	Non complying
	09.01.2024	22.12.2023	1601 dt. 02.01.2024	27	144	7.2	84	2900	2.3	Non complying	Non complying
		29.01.2024	1981 dt. 06.02.2024	28	208	7.39	76	3400	3.2	Non complying	Non complying
	Feb, 2024	26.02.2024	2149 dt. 06.03.2024	27	176	7.4	66	3100	1.9	Non complying	Non complying
	Mar, 2024	27.03.2024	2321 dt. 04.04.2024	25	144	7.81	52	2700	4.2	Non complying	Non complying
		27.04.2024	96 dt. 3.05.2024	25	128	7.44	48	2000	5.6	Non complying	Non complying
		28.05.2024	209 dt. 04.06.2024	23	120	7.17	41	1700	4.2	Non complying	Non complying
		29.06.2024	471 dt. 11.07.2024	25	136	7.48	39	1300	7	Non complying	Non complying
		26.07.2024	954 dt. 06.08.2024	27	148	7.42	41	840	5.6	Non complying	Non complying
		29.08.2024	1252 dt. 04.09.2024	25	128	7.36	50	790	8.4	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		21.10.2024	407 ML dt. 29.10.2024		34	196	7.69	125	930	16.81	Non complying	Non complying
70	(NUH-STP-004) 5 MLD STP Ferozpur Jhirka, Nuh, by PHED in 20.11.2019	29.01.2021	516 dt. 08.02.2021		23	104	7.1	34	57000		Complying	Non complying
		18.02.2021	534 dt. 01.03.2021	1.5	25	108	7.2	38	61000		Complying	Non complying
		31.03.2021	7 dt. 09.04.2021	3.6	27	116	7.6	44	68000		Complying	Non complying
		27.04.2021	46 dt. 06.05.2021		25	112	7.7	68	82000		Complying	Non complying
		27.05.2021	62 dt. 04.06.2021		23	88	7.3	48	74000		Complying	Non complying
		23.06.2021	105 dt. 01.07.2021		26	112	7.1	42	78000		Complying	Non complying
		25.07.2021	243 dt. 03.08.2021	2.2	21	88	7.3	31	63000	6.6	Complying	Non complying
		24.08.2021	354 dt. 31.08.2021		20	84	7.7	33	59300	6.2	Non complying	Non complying
		24.09.2021	419 dt. 01.10.2021	0.51	23	96	7.5	42	47400	6.4	Non complying	Non complying
	02.12.2021	30.10.2021	491 dt. 09.11.2021	3	27	104	7.7	78	41000	6.6	Non complying	Non complying
	15.12.2021	26.11.2021	537 dt. 03.12.2021	2.1	28	112	7.9	72	33000	6.8	Non complying	Non complying
	21.01.2022	21.12.2021	3431 dt. 31.12.2021		18	72	7.8	48	1500	1.59	Non complying	Non complying
	10.02.2022	28.01.2022	3953 dt. 08.02.2022	2.5 MLD	14	76	7.83	48	600	2.26	Non complying	Non complying
	06.04.2022	25.02.2022	4291 dt. 10.03.2022		9	56	7.71	21	200	1.94	Complying	Complying
	15.04.2022	12.03.2022	4572 dt. 29.03.2022		18	108	7.52	48	1400	1.61	Non complying	Non complying
	04.05.2022	07.04.2022	4949 dt. 27.04.2022		13	80	7.37	60	1200	1.02	Non complying	Non complying
	10.06.2022	14.05.2022	5455 dt. 27.05.2022		16	88	7.72	46	1700	7.48	Non complying	Non complying
	30.06.2022	21.06.2022	36 dt. 29.06.2022		24	96	7.6	58	2900	1.38	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	06.08.2022	27.07.2022	404 dt. 04.08.2022		45	188	7.7	62	3300	2.1	Non complying	Non complying
	08.09.2022	27.08.2022	567 dt. 03.09.2022		34	132	7.5	52	2500	2.6	Non complying	Non complying
	07.10.2022	28.09.2022	704 dt. 06.10.2022		19	88	7.4	43	1700	2.9	Non complying	Non complying
	07.11.2022	28.10.2022	887 dt. 04.11.2022		28	120	7.2	58	2300	3.3	Non complying	Non complying
	05.12.2022	25.11.2022	1154 dt. 05.12.2022		52	218.1	7.7	58	2000	3.1	Non complying	Non complying
	07.01.2023	22.12.2022	1459 dt. 02.01.2023		65	272.2	7.5	78	2500	4.6	Non complying	Non complying
	15.02.2023	31.01.2023	1880 dt. 08.02.2023		28	156.6	7.2	65	3300	4.9	Non complying	Non complying
	07.03.2023	25.02.2023	2048 dt. 06.03.2023		39	169.6	7.7	92	4000	5.2	Non complying	Non complying
	13.04.2023	29.03.2023	2362 dt. 08.04.2023		45	192.7	7.9	110	4500	7.4	Non complying	Non complying
	28.04.2023	20.04.2023	85 dt. 27.04.2023		38	153.5	7.6	74	4100	6.2	Non complying	Non complying
	13.06.2023	26.05.2023	217 dt. 02.06.2023		28	133.2	7.1	61	2700	5.8	Non complying	Non complying
	15.07.2023	24.06.2023	399 dt. 03.07.2023		22	90.1	7.2	45	2100	3.7	Non complying	Non complying
	14.08.2023	27.07.2023	842 dt. 05.08.2023		17	70.2	6.8	52	2800	2.3	Non complying	Non complying
	15.09.2023	31.08.2023	1037 dt. 11.09.2023		22	96	7	43	3200	1.8	Non complying	Non complying
	17.10.2023	28.09.2023	1202 dt. 09.10.2023		24	108	7.4	56	3900	2.4	Non complying	Non complying
	08.11.2023	26.10.2023	1315 dt. 03.11.2023		27	128	7.9	74	4600	3.2	Non complying	Non complying
	12.12.2023	28.11.2023	1443 dt. 06.12.2023		29	144	7.2	68	4200	1.8	Non complying	Non complying
	09.01.2024	22.12.2023	1602 dt. 02.01.2024		25	112	7.4	50	3800	3.6	Non complying	Non complying
	Feb, 2024	27.02.2024	2150, 06.03.2024		24	96	7.05	40	2700	3.2	Non complying	Non complying
	Mar, 2024	23.03.2024	2312, 01.04.2024		27	108	7.36	48	2600	4.9	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		27.04.2024	95 dt. 3.05.2024		23	104	7.33	52	1700	4.2	Non complying	Non complying
		28.05.2024	210 dt. 04.06.2024		25	112	7.48	44	1400	5.6	Non complying	Non complying
		29.06.2024	469 dt. 11.07.2024		23	92	7.04	49	1100	8.4	Non complying	Non complying
		26.07.2024	953 dt. 06.08.2024		24	108	8.16	45	930	7	Non complying	Non complying
		30.08.2024	1277 dt. 05.09.2024		27	120	7.95	52	840	9.8	Non complying	Non complying
		22.10.2024	1593 dt. 29.10.2024		23	120	7.42	75	630	9.8	Non complying	Non complying
Gurgaon South												
71	(GRS-STP-005) 50 MLD STP at Behrampur , Gurugram by GMDA in August 2010	15.01.2021	1648-1649 dt. 21.01.2021		16	72	7	39	9000		Complying	Non complying
		26.02.2021	2049-2050 dt. 08.03.2021		18	92	7.2	43	12000		Complying	Non complying
		09.03.2021	2093-2094 dt. 17.03.2021	39.6	7	40	7.3	14	17000	1.1	Complying	Complying
		08.04.2021	23-24 dt. 17.04.2021	39.6	13	44	7.8	19	1100	2.8	Complying	Non complying
		12.05.2021	114-115 dt. 18.05.2021	37.5	15	48	7.8	17	780	2.1	Complying	Non complying
		02.06.2021	164-165 dt. 10.06.2021	32.5	12	44	7.6	15	920	1.8	Complying	Non complying
		30.07.2021	573-574 dt. 06.08.2021	34.9	9	48	7.4	18	740	1.1	Complying	Complying
		24.08.2021	697-698 dt. 01.09.2021	34.9	7	40	7.7	15	92	0.8	Complying	Complying
		19.10.2021	1031-1032 dt. 27.10.2021	--	7	32	7.4	8	78	1	Complying	Complying
	23.11.2021	10.11.2021	1098-1099 dt. 16.11.2021	-	8	40	7.1	9	94	2.1	Complying	Complying
	19.01.2022	15.12.2021	3377 dt. 29.12.2021		8	44	7.42	10	Absent	0.62	Complying	Complying
	08.02.2022	13.01.2022	3676 dt. 21.01.2022		7.6	48	6.17	14	80	N.D.	Complying	Complying
	05.04.2022	17.02.2022	4208 dt. 02.03.2022		7.5	48	7.8	11	90	2.26	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	15.04.2022	04.03.2022	4427 dt. 21.03.2022		7.2	44	7.41	17	200	1.67	Complying	Complying
	04.05.2022	04.04.2022	4853 dt. 20.04.2022		7.2	28	7.73	11	80	1.85	Complying	Complying
	08.06.2022	12.05.2022	5437 dt. 26.05.2022		7	44	7.32	13	80	N.D.	Complying	Complying
	14.07.2022	09.06.2022	5807 dt. 23.06.2022		7.2	44	7.78	15	90	1.32	Complying	Complying
	22.07.2022	09.07.2022	213 dt. 19.07.2022		16	72	8.7	18	130	0	Non complying	Non complying
	18.08.2022	09.08.2022	506 dt. 17.08.2022		8	44	7.4	19	90	3.8	Complying	Complying
	04.10.2022	19.09.2022	657 dt. 28.09.2022		5	32	7.4	8	13	2.1	Complying	Complying
	28.10.2022	19.10.2022	841 dt. 27.10.2022		7	36.3	7.6	14	21	2.6	Complying	Complying
	01.12.2022	18.11.2022	1076 dt. 29.11.2022		5	24	7.3	11	18	2.5	Complying	Complying
	14.12.2022	02.12.2022	1256 dt. 13.12.2022		4	20.2	7.1	13	15	2.1	Complying	Complying
	27.01.2023	17.01.2023	1733 dt. 24.01.2023		6	28.2	7.3	16	33	2.4	Complying	Complying
	20.02.2023	10.02.2023	1955 dt. 17.02.2023		7	32.6	7.1	14	27	2.1	Complying	Complying
	24.03.2023	06.03.2023	2122 dt. 14.03.2023		6	30.7	7.4	15	33	2.4	Complying	Complying
	20.04.2023	10.04.2023	52 dt. 18.04.2023		5	27.7	7.5	14	37	2.2	Complying	Complying
	26.05.2023	10.05.2023	156 dt. 19.05.2023		7	32.3	7.1	12	45	2.5	Complying	Complying
	23.06.2023	09.06.2023	330 dt. 19.06.2023		6	35.2	7.4	10	57	1.9	Complying	Complying
	09.08.2023	18.07.2023	717 dt. 27.07.2023		6	41.3	7.2	12	70	1.5	Complying	Complying
	01.09.2023	18.08.2023	951 dt. 28.08.2023		7	38	7.4	15	76	1.2	Complying	Complying
	15.09.2023	04.09.2023	1060 dt. 13.09.2023		5	32	7.1	13	62	1.8	Complying	Complying
	03.11.2023	10.10.2023	1268 dt. 23.10.2023		7	40	7.3	15	80	BDL	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	01.12.2023	21.11.2023	1406 dt. 29.11.2023		6	36	7.2	17	77	BDL	Complying	Complying
	20.12.2023	11.12.2023	1508 dt. 18.12.2023		7	40	7	14	60	1.2	Complying	Complying
		07.06.2024	291 dt. 15.06.2024		6	36	7.85	18	70	4.1	Complying	Complying
		07.08.2024	1063 dt. 14.08.2024		5	40	7.43	17	93	8.4	Complying	Complying
		05.09.2024	1320 dt. 12.09.2024		9	32	7.02	18	63	5.6	Complying	Complying
		11.10.2024	1530 dt. 18.10.2024		7	44	7.57	15	84	7	Complying	Complying
		05.11.2024	1687 dt. 13.11.2024		9	40	7.14	11	79	4.2	Complying	Complying
		03.12.2024	1854 dt. 09.12.2024		4	32	7.63	11	41	4.2	Complying	Complying
		10.01.2025	2143 dt. 17.01.2025		5.5	35.5	7.42	10	49	5.6	Complying	Complying
		10.02.2025	2425 dt. 19.02.2025		8.8	32.3	7.09	15	63	4.2	Complying	Complying
72	(GRS-STP-006) 120 MLD STP at Bahrapur , Gurugram by GMDA in July 2014	15.01.2021	1646-1647 dt. 21.02.2021		8	36	7	15	2100	5.2	Complying	Complying
		26.02.2021	2047-2048 dt. 08.02.2021		9	40	7.3	13	2700	4.8	Complying	Complying
		09.03.2021	2090-2091 dt. 17.03.2021	89.9	8	44	7.1	16	3200	3	Complying	Complying
		08.04.2021	20-21 dt. 17.04.2021	94.7	8	32	7.6	14	780	0.9	Complying	Complying
		12.05.2021	116-117 dt. 18.05.2021	97.8	7	36	7.5	16	620	0.8	Complying	Complying
		02.06.2021	162-163 dt. 10.06.2021	81.5	6	32	7.3	14	580	0.7	Complying	Complying
		30.07.2021	575-576 dt. 06.08.2021	86.9	7	40	7.7	16	420	0.9	Complying	Complying
		24.08.2021	699-700 dt. 1.09.2021	84.8	8	44	7.4	14	220	0.7	Complying	Complying
		19.10.2021	1029-1030 dt. 27.10.2021	--	9	44	7.7	14	190	1.4	Complying	Complying
	23.11.2021	10.11.2021	1096-1097 dt. 16.11.2021	-	8	36	7.4	15	210	2.1	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	19.01.2022	15.12.2021	3378 dt. 29.12.2021		5.5	28	7.17	9	70	0.91	Complying	Complying
	08.02.2022	13.01.2022	3677 dt. 21.01.2022		7	48	6.23	13	50	1.06	Complying	Complying
	05.04.2022	17.02.2022	4207 dt. 02.03.2022		6.8	40	7.48	11	80	2.03	Complying	Complying
	15.04.2022	04.03.2022	4428 dt. 21.03.2022		7.8	40	7.77	16	400	1.67	Complying	Complying
	04.05.2022	04.04.2022	4854 dt. 20.04.2022		7.5	36	7.28	15	90	2.14	Complying	Complying
	08.06.2022	12.05.2022	5436 dt. 26.05.2022		7.2	36	7.24	10	70	1.67	Complying	Complying
	14.07.2022	09.06.2022	5808 dt. 23.06.2022		7	40	7.42	16	80	0.77	Complying	Complying
	22.07.2022	09.07.2022	214 dt. 19.07.2022		19	80	8	17	140		Non complying	Non complying
	18.08.2022	09.08.2022	505 dt. 17.08.2022		14	68	7.8	16	120	2.4	Non complying	Non complying
	04.10.2022	19.09.2022	658 dt. 28.09.2022		2	12	7.4	6	12	1.8	Complying	Complying
	28.10.2022	19.10.2022	840 dt. 27.10.2022		6	23.7	8.2	16	25	2.2	Complying	Complying
	01.12.2022	18.11.2022	1077 dt. 29.11.2022		BDL	14.4	7.1	12	20	2.1	Complying	Complying
	14.12.2022	02.12.2022	1257 dt. 13.12.2022		BDL	19.4	7	10	17	1.8	Complying	Complying
	27.01.2023	17.01.2023	1732 dt. 24.01.2023		5	24.2	7.2	12	35	1.9	Complying	Complying
	20.02.2023	10.02.2023	1956 dt. 17.02.2023		7	28.5	7.5	16	47	1.4	Complying	Complying
	24.03.2023	06.03.2023	2121 dt. 14.03.2023		8	37.8	7.2	14	40	1.7	Complying	Complying
	20.04.2023	10.04.2023	53 dt. 18.04.2023		7	31.6	7.1	11	33	1.5	Complying	Complying
	26.05.2023	10.05.2023	157 dt. 19.05.2023		8	34.6	6.8	15	50	1.8	Complying	Complying
	23.06.2023	09.06.2023	335 dt. 19.06.2023		5	24.2	7.1	13	63	1.3	Complying	Complying
	09.08.2023	18.07.2023	716 dt. 27.07.2023		7	37.4	7.8	14	73	1.8	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	01.09.2023	18.08.2023	952 dt. 28.08.2023		6	32	7.1	17	60	1.2	Complying	Complying
	15.09.2023	04.09.2023	1061 dt. 13.09.2023		5	28	6.9	14	72	1.8	Complying	Complying
	03.11.2023	10.10.2023	1269 dt. 23.10.2023		6	36	7.1	17	60	1.2	Complying	Complying
	01.12.2023	21.11.2023	1405 dt. 29.11.2023		7	44	7.3	16	68	BDL	Complying	Complying
	20.12.2023	11.12.2023	1507 dt. 18.12.2023		5	36	7.1	17	65	BDL	Complying	Complying
		07.06.2024	290 dt. 15.06.2024		7	448	7.19	255	84	4.2	Complying	Complying
		07.08.2024	1064 dt. 14.08.2024		9	48	7.52	18	79	2.8	Complying	Complying
		11.10.2024	1531 dt. 18.10.2024		4	24	7.10	11	49	7.0	Complying	Complying
		03.12.2024	1855 dt. 09.12.2024		6	40	7.54	7	84	6.8	Complying	Complying
		10.01.2025	2142 dt. 17.01.2025		7.2	31.6	7.21	8	63	4.20	Complying	Complying
		10.02.2025	2426 dt. 19.02.2025		8.2	39.5	7.49	13	79	7.00	Complying	Complying
	Faridabad											
73	(FBD-STP-001) 45 MLD STP, Badshahpur Faridabad by ULB in 1.9.2011	08.01.2021	474 dt. 18.01.2021		37	136	7.5	82	53000		Non complying	Non complying
		05.02.2021	522 dt. 13.02.2021		40	172	7.4	136	58000		Non complying	Non complying
		08.03.2021	553 dt. 16.03.2021		35	136	7.2	86	64000		Non complying	Non complying
		06.04.2021	10 dt. 14.04.2021		42	152	7.7	92	76000		Non complying	Non complying
		03.05.2021	50 dt. 12.05.2021		39	144	7.5	82	72000		Non complying	Non complying
		08.06.2021	76 dt. 15.06.2021		38	136	7.7	56	68000		Non complying	Non complying
		10.07.2021	181 dt. 17.07.2021		42	168	7.5	124	72000		Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		09.08.2021	307 dt. 18.08.2021		45	184	7.2	138	32000	0	Non complying	Non complying
	30.09.2021	10.09.2021	389 dt. 18.09.2021	29.95	35	128	7.4	62	21000	0	Non complying	Non complying
		14.10.2021	462 dt. 22.10.2021		37	144	7.9	68	17000	0	Non complying	Non complying
	02.12.2021	10.11.2021	504 dt. 18.11.2021		41	168	7.7	74	11000	0	Non complying	Non complying
	18.01.2021	11.12.2021	3358 dt. 27.12.2021		7.5	48	7.11	20	800	1.95	Complying	Complying
	08.02.2022	07.01.2022	3641 dt. 19.01.2022		20	96	7.73	53	1200	2.57	Non complying	Non complying
	06.04.2022	10.02.2022	4152 dt. 17.02.2022		26	148	8.12	54	600	3.49	Non complying	Non complying
	15.04.2022	10.03.2022	4527 dt. 22.03.2022		48	160	7.86	78	1200	5.75	Non complying	Non complying
	04.05.2022	07.04.2022	4953 dt. 27.04.2022		78	292	7.3	148	2100	7.56	Non complying	Non complying
	31.05.2022	06.05.2022	5296 dt. 19.05.2022		64	248	7.32	50	1400	16.61	Non complying	Non complying
	09.07.2022	29.06.2022	81 dt. 07.07.2022		76	304	7.8	155	1600	1.78	Non complying	Non complying
	06.08.2022	28.07.2022	408 dt. 05.08.2022		95	372	7.9	172	2100	2.1	Non complying	Non complying
	08.09.2022	30.08.2022	581 dt. 06.09.2022		44	168	7.6	72	1900	3.4	Non complying	Non complying
	12.10.2022	29.09.2022	730 dt. 11.10.2022		52	216	7.5	80		3.2	Non complying	Non complying
	09.11.2022	28.10.2022	896 dt. 07.11.2022		72	296	7.1	118	2100	4.1	Non complying	Non complying
	14.12.2022	30.11.2022	1232 dt. 12.12.2022		78	315.1	7.7	142	2500	5.9	Non complying	Non complying
	19.01.2023	31.12.2022	1570 dt. 11.01.2023		72	297.2	7.9	115	2100	5.3	Non complying	Non complying
	14.02.2023	31.01.2023	1856 dt. 07.02.2023		84	337.3	7.3	109	3000	4.6	Non complying	Non complying
	10.03.2023	01.03.2023	2086 dt. 09.03.2023		88	387.8	7.4	120	3500	5.1	Non complying	Non complying
	19.05.2023	29.04.2023	123 dt. 10.05.2023		108	436.3	7.7	145	4300	6.5	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
75	(FBD-STP-004) 30 MLD STP, Faridabad by FMDA in 31.12.2023											
	03, 2024	13.03.2024	2256 dt 21.03.2024		5	20	7.1	15	26	4.67	Complying	Complying
	05, 2024	30.04.2024	119 dt 07.05.2024	24	7	28	7.43	11	33	4.2	Complying	Complying
		03.06.2024	256 dt. 11.06.2024	24	5	32	7.19	8	49	2.8	Complying	Complying
		04.07.2024	564 dt. 16.07.2024		6	40	7.54	14	63	5.6	Complying	Complying
76	(FBD-STP-004) 5 MLD STP, Faridabad by FSCL in 31.10.2024											
77	(FBD-STP-005) 2 MLD STP at Dushera ULBD in 31.08.2024											
78	(FBD-STP-006) 5 MLD at Golf Course ULBD in 30.09.2024											
79	(FBD-STP-006) 15 MLD at Partapgarh Sector-25 Faridabad (FSCL)											
	Ballabgarh											
80	(BLB-STP-003) 100 MLD STP Partapgarh , Ballabgarh by ULBD in 31.03.2024											
		31.07.2024	1017 dt 09.08.2024		130	504	7.03	265				Non Complying
		30.08.2024	1281 dt 06.09.2024		112	448	7.55	235				Non Complying
		24.09.2024	1403 dt 01.10.2024		105	392	7.84	205				Non Complying
		28.10.2024	1632 dt 05.11.2024		45	184	7.23	55				Non Complying
		29.11.2024	1825 dt 05.12.2024		38	165	7.93	42				Non Complying
		26.12.2024	1998 dt 03.01.2025		16	67.8	7.79	32				Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		24.01.2025	2256 dt 30.01.2025		14	63.2	7.4	32				Non Complying
		14.02.2025	2437 dt 20.02.2025		28	118.8	7.57	42				Non Complying
81	(BLB-STP-004) 80 MLD STP Mirjapur , Ballabgarh by ULBD in 31.03.2024											
		25.07.2024	917 dt 02.08.2024		85	376	7.39	190				Non Complying
		22.08.2024	1194 dt 29.08.2024		75	320	7.31	170				Non Complying
		30.09.2024	1466 dt 08.10.2024		62	296	7.59	135				Non Complying
		25.10.2024	1622 dt 04.11.2024		70	304	7.41	115				Non Complying
		29.11.2024	1823 dt 05.12.2024		7	40	7.32	15				complying
		19.12.2024	1949 dt 27.12.2024		8.4	31.8	7.42	18				complying
		20.01.2025	2215 dt 27.01.2025		7.8	36.2	7.26	15				complying
		27.02.2025	2517 dt 06.03.2025		8.4	44.3	7.79	19				complying
82	(BLB-STP-002) 7.5 MLD STP, Ballabgarh by HSPV in 31.03.2021				Trial Run							
	Palwal											
83	(PWL-STP-001) 3 MLD STP Hassanpur Palwal by PHED in 1.3.2016 (MBBR+dual filter)	11.01.2021	475 dt. 20.01.2021		16	64	7.9	38	29000		Non complying	Non complying
		17.02.2021	532 dt. 26.02.2021	1.5	14	56	7.3	46	27000		Non complying	Non complying
		31.03.2021	3 dt. 09.04.2021	1.2	24	96	7.7	72	36000	8.4	Non complying	Non complying
		28.04.2021	41 dt. 06.05.2021		19	72	7.9	58	29000	7.6	Non complying	Non complying
		27.05.2021	63 dt. 04.06.2021		17	68	7.6	52	25000	6.5	Non complying	Non complying
		16.06.2021	92 dt. 23.06.2021	1.4	18	72	7.2	43	23000	6.2	Non complying	Non complying
		23.07.2021	224 dt. 31.07.2021		19	76	7.1	28	21000	5.8	Non complying	Non complying
		19.08.2021	337 dt. 27.08.2021		18	72	7.4	26	18400	5.2	Non complying	Non complying
		20.09.2021	410 dt. 28.09.2021	1.8	19	84	7.1	48	17600	4.9	Non complying	Non complying
	02.12.2021	30.10.2021	494 dt. 09.11.2021	1.4	17	76	7.4	38	15200	4.7	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	21.01.2022	21.12.2021	3435 dt. 31.12.2021	1.7 MLD	21	112	8.1	28	600	1.41	Non complying	Non complying
	05.04.2022	07.02.2022	4043 dt. 15.02.2022		23	98	7.94	29	800	2.3	Non complying	Non complying
	15.04.2022	12.03.2022	4577 dt. 29.03.2022		20	124	8.03	38	2100	2.42	Non complying	Non complying
	04.05.2022	07.04.2022	4948 dt. 27.04.2022		12	68	7.17	24	1400	2.08	Non complying	Non complying
	10.06.2022	14.05.2022	5452 dt. 27.05.2022		13	68	8.02	28	1700	1.44	Non complying	Non complying
	06.07.2022	10.06.2022	5848 dt. 23.06.2022		18	92	7.66	42	1500	1.61	Non complying	Non complying
	02.08.2022	26.07.2022	394 dt. 02.08.2022		21	88	7.8	48	1700	3.7	Non complying	Non complying
	08.09.2022	30.08.2022	586 dt. 06.09.2022		19	80	8.1	26	1500	3.1	Non complying	Non complying
		27.09.2022	688 dt. 04.10.2022		21	88	7.9	24	1700	2.7	Non complying	Non complying
	09.11.2022	29.10.2022	903 dt. 07.11.2022		24	96	7.5	32	2000	3.1	Non complying	Non complying
	08.12.2022	29.11.2022	1205 dt. 08.12.2022		14	76.7	7.2	38	2400	3.7	Non complying	Non complying
	07.01.2023	23.12.2022	1488 dt. 03.01.2023		15	86.5	7.4	32	1800	3.2	Non complying	Non complying
	15.02.2023	31.01.2023	1873 dt. 08.02.2023		17	104.4	7.2	48	2100	3.6	Non complying	Non complying
	07.03.2023	27.02.2023	2056 dt. 06.03.2023		15	90.2	7.5	42	2700	4.5	Non complying	Non complying
	13.03.2023	01.03.2023	2095 dt. 10.03.2023		17	105.4	7.2	48	3300	4.1	Non complying	Non complying
	05.05.2023	27.04.2023	97 dt. 04.05.2023		48	194.4	7.4	132	4300	2.1	Non complying	Non complying
	13.06.2023	26.05.2023	225 dt. 02.06.2023		58	274.4	7.2	82	3700	2.5	Non complying	Non complying
	15.07.2023	24.06.2023	394 dt. 03.07.2023		52	246.9	7.1	65	4300	3.3	Non complying	Non complying
	11.08.2023	26.07.2023	818 dt. 03.08.2023		45	210.2	7.3	54	3800	5.9	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	15.09.2023	28.08.2023	1018 dt. 05.09.2023		58	236	7.6	44	4200	2.6	Non complying	Non complying
	10.10.2023	21.09.2023	1152 dt. 06.10.2023		45	184	7.8	62	5400	3.4	Non complying	Non complying
	09.11.2023	26.10.2023	1324 dt. 03.11.2023		54	216	7.1	78	6200	4.2	Non complying	Non complying
	12.12.2023	28.11.2023	1436 dt. 05.12.2023		44	176	7.3	72	3200	3.2	Non complying	Non complying
	08.01.2024	21.12.2023	1583 dt. 30.12.2023		28	104	7.5	58	2600	3.8	Non complying	Non complying
	Jan, 2024	29.01.2024	1964, 05.02.2024		48	192	7.14	64	2800	2.8	Non complying	Non complying
	Feb, 2024	29.02.2024	2198, 07.03.2024		26	120	7.47	55	2100	2.4	Non complying	Non complying
	Mar, 2024	13.03.2024	2249 dt. 20.03.2024		32	152	7.91	85	2600	7.05	Non complying	Non complying
		24.04.2024	80 dt. 01.05.2024		33	152	7.16	60	1700	4.2	Non complying	Non complying
		28.05.2024	235 dt. 06.06.2024		35	144	7.45	58	2100	5.6	Non complying	Non complying
		20.06.2024	356 dt. 28.06.2024		36	160	7.32	68	1300	7	Non complying	Non complying
		27.07.2024	927 dt. 05.08.2024		42	172	7.56	70	1700	11.2	Non complying	Non complying
84	(PWL-STP-002) 4.5 MLD STP Hathin Palwal by PHED in 31.12.2015	28.01.2021	513 dt. 08.02.2021		29	128	7.7	94	44000		Complying	Non- Complying
		31.03.2021	4 dt. 09.04.2021	3.2	28	120	7.4	65	53000		Complying	Non- Complying
		28.04.2021	42 dt. 06.05.2021		56	232	7.3	82	68000	8.9	Non- Complying	Non- Complying
		27.05.2021	60 dt. 04.06.2021		28	136	7.5	58	54000	7.2	Complying	Non- Complying
		16.06.2021	93 dt. 23.06.2021		29	144	7.9	68	62000	7.6	Complying	Non- Complying
		09.07.2021	166 dt. 17.07.2021	2.8	26	128	7.7	42	65000	6.8	Complying	Non- Complying
		24.08.2021	349 dt. 31.08.2021		25	112	8.1	46	58000	6.6	Non- Complying	Non- Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks	
	20.09.2021	411 dt. 28.09.2021	2	17	68	8.3	35	37000	6.1	Non-Complying	Non-Complying	
	22.10.2021	477 dt. 02.11.2021	2.8	18	72	8.2	44	27000	5.9	Non-Complying	Non-Complying	
	21.01.2022	21.12.2021	3436 dt. 31.12.2021	2.5 MLD	9	56	8.03	21	500	1.32	Complying	Complying
	05.04.2022	07.02.2022	4044 dt. 15.02.2022		14	72	7.88	30	600	2.26	Non-Complying	Non-Complying
	15.04.2022	12.03.2022	4578 dt. 29.03.2022		16	104	7.73	26	1700	2.3	Non-Complying	Non-Complying
	04.05.2022	07.04.2022	4950 dt. 27.04.2022		16	92	7.37	34	1400	1.32	Non-Complying	Non-Complying
	10.06.2022	14.05.2022	5458 dt. 27.05.2022		13	64	7.43	31	1500	1.16	Non-Complying	Non-Complying
	06.07.2022	10.06.2022	5849 dt. 23.06.2022		20	104	7.5	56	1200	1.85	Non-Complying	Non-Complying
	02.08.2022	26.07.2022	393 dt. 02.08.2022		27	112	7.8	43	1400	2.6	Non-Complying	Non-Complying
	08.09.2022	30.08.2022	587 dt. 06.09.2022		25	104	7.5	36	1300	1.8	Non-Complying	Non-Complying
		27.09.2022	686 dt. 04.10.2022		23	92	7.6	28	1500	2.4	Non-Complying	Non-Complying
	09.11.2022	29.10.2022	904 dt. 07.11.2022		29	128	7.4	46	2100	2.9	Non-Complying	Non-Complying
	14.12.2022	30.11.2022	1225 dt. 09.12.2022		23	105.1	7.6	39	1700	2.7	Non-Complying	Non-Complying
	07.01.2023	23.12.2022	1489 dt. 03.01.2023		25	120.1	7.3	31	2100	2.5	Non-Complying	Non-Complying
	15.02.2023	31.01.2023	1871 dt. 08.02.2023		27	144.5	7.5	36	2400	2.9	Non-Complying	Non-Complying
	07.03.2023	27.02.2023	2051 dt. 06.03.2023		15	56.5	8.2	42	1700	2.2	Non-Complying	Non-Complying
	13.04.2023	28.03.2023	2338 dt. 07.04.2023		48	189.1	7.6	90	2300	5.9	Non-Complying	Non-Complying
	05.05.2023	27.04.2023	96 dt. 04.05.2023		36	142.5	7.3	48	1700	2.3	Non-Complying	Non-Complying
	13.06.2023	26.05.2023	227 dt. 02.06.2023		28	125.4	7.8	52	900	2.1	Non-Complying	Non-Complying
	15.07.2023	24.06.2023	395 dt. 03.07.2023		36	156.8	7.5	49	1700	2.6	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	11.08.2023	26.07.2023	819 dt. 03.08.2023		28	139.6	7.1	56	2200	3.2	Non-Complying	Non-Complying
	15.09.2023	28.08.2023	1019 dt. 05.09.2023		42	192	7.5	64	2600	3.8	Non-Complying	Non-Complying
	10.10.2023	21.09.2023	1151 dt. 06.10.2023		48	216	7.3	76	3800	3.2	Non-Complying	Non-Complying
	09.11.2023	26.10.2023	1327 dt. 03.11.2023		42	176	7.1	64	3200	2.8	Non-Complying	Non-Complying
	12.12.2023	28.11.2023	1434 dt. 05.12.2023		27	116	7.5	56	1700	2.3	Non-Complying	Non-Complying
	08.01.2024	21.12.2023	1581 dt. 30.12.2023		22	96	7.2	40	1300	1.4	Non-Complying	Non-Complying
	Jan, 2024	29.01.2024	1965 dt 05.02.2024		26	128	7.48	52	1600	3.4	Non-Complying	Non-Complying
	Feb, 2024	29.02.2024	2197 dt 07.03.2024		28	136	7.32	45	920	2.9	Non-Complying	Non-Complying
	Mar, 2024	13.03.2024	2251 dt 20.03.2024		26	128	7.86	52	840	9.34	Non-Complying	Non-Complying
		24.04.2024	78 dt. 01.05.2024		34	168	7.68	65	630	8.4	Non-Complying	Non-Complying
		28.05.2024	231 dt. 06.06.2024		44	176	7.25	80	770	9.8	Non-Complying	Non-Complying
		24.07.2024	892 dt. 01.08.2024		42	176	7.18	68	840	9.4	Non-Complying	Non-Complying
85	(PWL-STP-003) 9 MLD STP, Hodal, Palwal by PHED in May, 2013 (MBBR & TT)	17.02.2021	531 dt. 26.02.2021	7.9	26	128	7.5	72	75000		Non-Complying	Non-Complying
		31.03.2021	5 dt. 09.04.2021	4.9	24	116	7.3	64	64000		Non-Complying	Non-Complying
		28.04.2021	44 dt. 06.05.2021		27	136	7.5	78	74000		Non-Complying	Non-Complying
		27.05.2021	65 dt. 04.06.2021		24	96	7.4	58	65000		Non-Complying	Non-Complying
		16.06.2021	95 dt. 23.06.2021	4	26	104	7.1	52	68000		Non-Complying	Non-Complying
		23.07.2021	225 dt. 31.07.2021		23	88	7.3	46	65000	5.2	Non-Complying	Non-Complying
		24.08.2021	351 dt. 31.08.2021		24	96	8.1	44	62000	5.6	Non-Complying	Non-Complying
		03.09.2021	374 dt. 13.09.2021	4	28	144	8	46	68000	5.8	Non-Complying	Non-Complying
		22.10.2021	479 dt. 02.11.2021	3.5	15	68	7.6	34	59400	6.1	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	21.01.2022	21.12.2021	3429 dt. 31.12.2021	3.4 MLD	20	108	7.88	33	1500	1.09	Non-Complying	Non-Complying
	05.04.2022	07.02.2022	4045 dt. 15.02.2022		12	60	7.76	26	400	1.99	Non-Complying	Non-Complying
	15.04.2022	12.03.2022	4576 dt. 29.03.2022	181.4m3/h	25	112	7.85	56	1400	2.17	Non-Complying	Non-Complying
	04.05.2022	07.04.2022	4951 dt. 27.04.2022		26	124	7.2	66	1700	2.83	Non-Complying	Non-Complying
	10.06.2022	14.05.2022	5457 dt. 27.05.2022		25	144	7.73	76	1700	10	Non-Complying	Non-Complying
	06.07.2022	10.06.2022	5846 dt. 23.06.2022		22	152	7.3	46	2100	4.13	Non-Complying	Non-Complying
	02.08.2022	26.07.2022	395 dt. 02.08.2022		23	100	7.5	40	2400	4.5	Non-Complying	Non-Complying
	08.09.2022	30.08.2022	588 dt. 06.09.2022		21	80	8.5	35	1400	3.4	Non-Complying	Non-Complying
		27.09.2022	687 dt. 04.10.2022		19	72	7.9	48	1800	4.6	Non-Complying	Non-Complying
	09.11.2022	29.10.2022	901 dt. 07.11.2022		52	218.1	7.5	65	2400	5.6	Non-Complying	Non-Complying
	08.12.2022	29.11.2022	1206 dt. 08.12.2022		60	243.8	7.2	75	2900	6.4	Non-Complying	Non-Complying
	07.01.2023	23.12.2022	1490 dt. 03.01.2023		68	280.9	7.6	82	3300	7.9	Non-Complying	Non-Complying
	15.02.2023	31.01.2023	1872 dt. 08.02.2023		36	137.3	7.5	70	3000	6.5	Non-Complying	Non-Complying
	07.03.2023	27.02.2023	2057 dt. 06.03.2023		45	218.1	7.3	208	3900	7.6	Non-Complying	Non-Complying
	13.03.2023	01.03.2023	2094 dt. 10.03.2023		32	159.5	7.1	145	3300	4.7	Non-Complying	Non-Complying
	05.05.2023	27.04.2023	95 dt. 04.05.2023		45	182.1	7.3	168	3900	4.1	Non-Complying	Non-Complying
	13.06.2023	26.05.2023	226 dt. 02.06.2023		42	160.7	7.6	130	3300	3.5	Non-Complying	Non-Complying
	15.07.2023	24.06.2023	396 dt. 03.07.2023		38	145.4	7.2	75	5000	4.2	Non-Complying	Non-Complying
	11.08.2023	26.07.2023	820 dt. 03.08.2023		42	172.4	7.6	84	5600	6.4	Non-Complying	Non-Complying
	15.09.2023	28.08.2023	1017 dt. 05.09.2023		52	208	7.4	70	4800	4.8	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
87	(PWL-STP-006) 2.5 MLD STP, Ferozpur, Palwal by ULBD in 31.05.2023	30.04.2024	128 dt. 08.05.2024		8	40	7.95	13	77	4.2	Complying	Complying
		28.05.2024	232 dt. 06.06.2024		5	28	7.3	14	48	1.4	Complying	Complying
		31.07 2024	1001 dt. 09.08.2024		9	60	7.46	28	93	9.8	Complying	Complying
88	(PWL-STP-007) 10 MLD STP, Kithwari/Agwanpur, Palwal by ULBD in 31.08.2023	30.04.2024	129 dt. 08.05.2024		6	28	7.56	15	41	2.8	Complying	Complying
		28.05.2024	233 dt. 06.06.2024		8	40	7.12	18	84	4.2	Complying	Complying
		31.07 2024	1018 dt. 09.08.2024		8	48	7.29	17	63	5.6	Complying	Complying
	Kurukshetra											
89	(KUK-STP-001) 7 MLD STP Ladwa Kurukshetra by PHED in 31.10.2016	18.01.2021	137 dt. 29.01.2021		14	76	7.61	29	1100	0.92	Non-Complying	Non-Complying
		15.02.2021	406 dt. 24.02.2021		7.4	40	7.55	44	700	8.07	Complying	Complying
		17.03.2021	672 dt. 25.03.2021		7.4	32	6.87	23	580	2.26	Complying	Complying
		23.04.2021	972 dt. 05.05.2021		7.8	36	7.85	6	70	0.46	Complying	Complying
		21.05.2021	1189 dt. 03.06.2021	4.72 MLD	6.2	32	7.05	11	Absent	0.14	Complying	Complying
	26.07.2021	23.06.2021	1437 dt. 05.07.2021		7.4	36	7.83	12	70	1.67	Complying	Complying
	07.09.2021	15.07.2021	1664 dt. 27.07.2021	1.5 MLD	7.8	36	7.1	6	70	0.46	Complying	Complying
	24.09.2021	12.08.2021	2062 dt. 30.08.2021	45 MLD	6.5	32	7.19	10	70	2.16	Complying	Complying
	25.10.2021	14.09.2021	2400 dt. 30.09.2021	3.5 MLD	6	40	7.58	8	80	0.87	Complying	Complying
	25.11.2021	12.10.2021	2753 dt. 29.10.2021	3.5 MLD	6	32	8.1	8	Absent	2.03	Complying	Complying
	09.12.2021	16.11.2021	3046 dt. 29.11.2021	2 MLD	7.8	46	7.62	13	90	2.13	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	18.01.2022	07.12.2021	3193 dt. 15.12.2021	3.5 MLD	7.2	44	7.28	14	80	0.77	Complying	Complying
	10.02.2022	06.01.2022	3567 dt. 17.01.2022	3.8 MLD	5.8	40	7.18	16	20	N.D.	Complying	Complying
	06.04.2022	17.02.2022	4184 dt. 24.02.2022		8	48	7.53	16	90	1.67	Complying	Complying
	15.04.2022	22.03.2022	4658 dt. 31.03.2022		7.5	36	7.18	11	50	N.D.	Complying	Complying
	17.05.2022	14.04.2022	5075 dt. 03.05.2022		7.8	32	7.56	13	80	0.92	Complying	Complying
	20.06.2022	21.05.2022	5506 dt. 01.06.2022		15	64	7.65	25	200	2.36	Non-Complying	Non-Complying
	18.07.2022	22.06.2022	5927 dt. 01.07.2022		13	56	7.01	31	400	3.49	Non-Complying	Non-Complying
	09.09.2022	26.08.2022	6624 dt. 06.09.2022		8.5	44	7.09	15	200	1.31	Complying	Complying
	11.10.2022	17.09.2022	6912 dt. 30.09.2022		7.5	36	7.52	15	80	1.62	Complying	Complying
	25.10.2022	05.10.2022	7070 dt. 17.10.2022		8	44	7.23	16	50	1.17	Complying	Complying
	23.11.2022	02.11.2022	7339 dt. 09.11.2022		13	60	7	28	400	0.22	Non-Complying	Non-Complying
	13.01.2023	27.12.2022	8088 dt. 10.01.2023		5.8	24	7.52	13	90	ND	Complying	Complying
	31.01.2023	13.01.2023	167 dt. 24.01.2023		7.8	48	7.89	12	80	ND	Complying	Complying
	02.03.2023	15.02.2023	531 dt. 27.02.2023		7.8	48	7.34	15	90	ND	Complying	Complying
	17.04.2023	29.03.2023	1042 dt. 10.04.2023		7.8	48	7.13	15	90	ND	Complying	Complying
	09.05.2023	24.04.2023	1319 dt. 04.05.2023		6.5	28	7.66	12	70	ND	Complying	Complying
	14.06.2023	26.05.2023	1694 dt.02.06.2023		8.5	48	7.22	16	90	ND	Complying	Complying
	24.06.2023	07.06.2023	1780 dt. 15.06.2023		7.5	40	7.25	15	50	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
1	(AMB-STP-001) 3.00 MLD STP Naya Gaon , Unit.I , Ambala City by PHED in January, 2011	21.01.2021	161 dt. 03.02.2021		5.8	36	7.57	12	700	0.98	Complying	Complying
		23.02.2021	441 dt. 04.03.2021		7	36	7.56	17	760	0.98	Complying	Complying
		19.03.2021	709 dt. 30.03.2021		5.4	28	7.92	12	790	0.63	Complying	Complying
		09.04.2021	888 dt. 23.04.2021		5.4	24	7.32	7	880	1.02	Complying	Complying
		25.05.2021	1200 dt. 08.06.2021	0.43 MLD	6.5	36	7.45	11	700	N.D.	Complying	Complying
	09.08.2021	22.06.2021	1400 dt. 05.07.2021		3.2	16	7.57	8	400	N.D.	Complying	Complying
	07.09.2021	29.07.2021	1866 dt. 18.08.2021		6.8	32	7.24	9	700	0.12	Complying	Complying
	30.09.2021	16.08.2021	2121 dt. 2.09.2021		9.5	48	7.28	23	24000	2.42	Complying	Complying
	25.10.2021	20.09.2021	2471 dt. 05.10.2021	2 MLD	5.5	44	7.81	10	6300	0.46	Complying	Complying
	30.11.2021	27.10.2021	2835 dt. 11.11.2021	0.36 MLD	16	60	8.57	18	600	5.4	Non-Complying	Non-Complying
	24.12.2021	22.11.2021	3107 dt. 02.12.2021	0.39 MLD	12	56	7.06	12	200	1.06	Non-Complying	Non-Complying
	18.01.2021	21.12.2021	3427 dt. 31.12.2021		7.6	40	7.48	14	700	9.36	Complying	Complying
		30.01.2022	3963 dt. 08.02.2022		8	36	7.42	15	200	1.95	Complying	Complying
	05.04.2022	28.02.2022	4353 dt. 15.03.2022		3.2	28	7.35	8	Absent	N.D.	Complying	Complying
		31.03.2022	4810 dt. 13.04.2022		13	60	7.5	27	400	1.03	Non-Complying	Non-Complying
	18.05.2022	27.04.2022	5176 dt. 11.05.2022		8	48	7.09	22	300	1.67	Non-Complying	Non-Complying
	22.06.2022	26.05.2022	5569 dt. 07.06.2022		16	72	6.8	33	400	1.95	Non-Complying	Non-Complying
	18.07.2022	27.06.2022	5978 dt. 06.07.2022		17	88	7.02	28	1200	2.83	Non-Complying	Non-Complying
	18.08.2022	29.07.2022	6368 dt. 09.08.2022		13	64	7.13	27	200	1.09	Non-Complying	Non-Complying
	09.09.2022	25.08.2022	6609 dt. 06.09.2022		19	72	6.82	41	600	ND	Non-Complying	Non-Complying
	17.10.2022	24.09.2022	6999 dt. 10.10.2022		18	76	7.2	37	500	3.22	Non-Complying	Non-Complying
	09.11.2022	14.10.2022	7240 dt. 26.10.2022		15	88	7.25	32	500	2.17	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	23.12.2022	30.11.2022	7657 dt. 13.12.2022		16	76	7.12	31	400	1.28	Non-Complying	Non-Complying
	13.01.2023	22.12.2022	8016 dt. 03.01.2023		15	68	8.24	28	200	1.25	Non-Complying	Non-Complying
	10.02.2023	30.01.2023	292 dt. 08.02.2023		15	76	7.45	35	400	ND	Non-Complying	Non-Complying
	13.03.2023	24.02.2023	631 dt. 07.03.2023		16	80	7.2	31	500	2.52	Non-Complying	Non-Complying
	16.03.2023	03.03.2023	747 dt. 15.03.2023		17	80	7.1	34	200	2.35	Non-Complying	Non-Complying
	12.05.2023	27.04.2023	1395 dt. 09.05.2023		13	64	6.65	26	200	ND	Non-Complying	Non-Complying
	14.06.2023	29.05.2023	1710 dt. 06.06.2023		13	68	7.03	29	500	1.84	Non-Complying	Non-Complying
	12.09.2023	28.08.2023	2607 dt. 05.09.2023		32	128	7.3	46	600	1.36	Non-Complying	Non-Complying
	19.10.2023	29.09.2023	3073 dt. 14.10.2023		24	120	7.54	41	200	1.62	Non-Complying	Non-Complying
	29.11.2023	31.10.2023	3417 dt. 10.11.2023		25	116	6.7	69	600	1.48	Non-Complying	Non-Complying
	11.12.2023	20.11.2023	3620 dt. 23.11.2023		26	124	7.08	64	600	1.27	Non-Complying	Non-Complying
	18.01.2024	29.12.2023	4091 dt. 09.01.2024		22	108	7	37	200	ND	Non-Complying	Non-Complying
	12.02.2024	25.01.2024	4334 dt. 31.01.2024		13	76	7.49	28	400	ND	Non-Complying	Non-Complying
		19.04.2024	80 dt. 25.04.2024		5.8	32	7.47	12	60	ND	Complying	Complying
		06.05.2024	221 dt. 15.05.2024		5	32	6.96	10	60	ND	Complying	Complying
		18.06.2024	389 dt. 27.06.2024		6.4	36	7.13	12		1.08	Complying	Complying
		19.07.2024	689 dt. 29.07.2024		7.2	44	6.93	16		ND	Complying	Complying
		21.08.2024	906 dt. 28.08.2024		8.2	44	7.03	15		ND	Complying	Complying
		10.09.2024	1069 dt. 18.09.2024		7.5	40	6.88	13		ND	Complying	Complying
		11.10.2024	1254 dt. 22.10.2024		7.2	44	7.6	12		ND	Complying	Complying
		08.11.2024	1415 dt. 18.11.2024		7.4	36	7.08	13		ND	Complying	Complying
		19.12.2024	1715 dt. 30.12.2024		7	40	6.79	13		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		14.01.2025	1911 dt. 22.01.2025		7	44	7.01	16		ND	Complying	Complying
2	(AMB-STP-002) 3.25 MLD STP Naya Gaon, Unit.II Ambala City by PHED in 1.4.2016	21.01.2021	160 dt. 03.02.2021		6.5	32	7.52	9	900	1.85	Complying	Complying
		23.02.2021	444 dt. 04.03.2021		7.4	32	7.58	9	630	1.04	Complying	Complying
		26.03.2021	744 dt. 07.04.2021	0.68	8	48	7.33	13	580	0.78	Complying	Complying
		09.04.2021	885 dt. 23.04.2021		6	28	7.27	9	940	1.11	Complying	Complying
		26.05.2021	1204 dt. 08.06.2021	0.79 KLD	6.6	36	7.26	13	400	N.D.	Complying	Complying
	09.08.2021	22.06.2021	1393 dt. 05.07.2021		3.5	12	7.35	9	390	1.14	Complying	Complying
	07.09.2021	29.07.2021	1863 dt. 18.08.2021		7	32	7.48	9	580	1.32	Complying	Complying
	30.09.2021	16.08.2021	2119 dt. 2.09.2021		11	56	7.26	20	2300	1.97	Non-Complying	Non-Complying
	25.10.2021	20.09.2021	2472 dt. 05.10.2021	1.5 MLD	8	40	8.02	16	4100	1.59	Complying	Complying
	30.11.2021	27.10.2021	2836 dt. 11.11.2021	0.30 MLD	7.8	40	7.95	13	400	4.28	Complying	Complying
	24.12.2021	22.11.2021	3106 dt. 02.12.2021	0.17 MLD	12	54	7.06	13	400	2.82	Non-Complying	Non-Complying
	18.01.2021	21.12.2021	3425 dt. 31.12.2021		12	60	7.42	29	600	5.46	Non-Complying	Non-Complying
	11.02.2022	29.01.2022	3965 dt. 08.02.2022		18	76	7.34	30	600	1.97	Non-Complying	Non-Complying
	05.04.2022	28.02.2022	4357 dt. 15.03.2022		3.8	32	7.25	12	60	0.33	Complying	Complying
		31.03.2022	4808 dt. 13.04.2022		13	56	7.35	27	400	1.12	Non-Complying	Non-Complying
	18.05.2022	27.04.2022	5175 dt. 11.05.2022		13	64	7.15	15	400	1.47	Non-Complying	Non-Complying
	22.06.2022	26.05.2022	5570 dt. 07.06.2022		14	76	6.76	29	600	4.04	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	18.07.2022	27.06.2022	5983 dt. 06.07.2022		14	64	7	29	1600	3.9	Non-Complying	Non-Complying
	18.08.2022	29.07.2022	6372 dt. 09.08.2022		14	64	7	29	1600	3.9	Non-Complying	Non-Complying
	09.09.2022	25.08.2022	6607 dt. 06.09.2022		15	64	6.82	35	500	ND	Non-Complying	Non-Complying
	17.10.2022	24.09.2022	7001 dt. 10.10.2022		16	80	7.52	31	400	1.86	Non-Complying	Non-Complying
	09.11.2022	14.10.2022	7239 dt. 26.10.2022		16	80	6.85	34	400	1.28	Non-Complying	Non-Complying
	23.12.2022	30.11.2022	7658 dt. 13.12.2022		15	80	7.06	29	600	1.24	Non-Complying	Non-Complying
	13.01.2023	22.12.2022	8017 dt. 03.01.2023		14	64	7.34	33	500	1.32	Non-Complying	Non-Complying
	10.02.2023	30.01.2023	291 dt. 08.02.2023		16	80	7.26	31	200	1.38	Non-Complying	Non-Complying
	13.03.2023	24.02.2023	632 dt. 07.03.2023		17	84	7.22	28	600	2.24	Non-Complying	Non-Complying
	16.03.2023	03.03.2023	748 dt. 15.03.2023		17	76	7.15	26	400	ND	Non-Complying	Non-Complying
	12.05.2023	27.04.2023	1392 dt. 09.05.2023		13	68	6.9	32	400	1.25	Non-Complying	Non-Complying
	14.07.2023	30.06.2023	2092 dt. 10.07.2023		18	72	6.46	37	200	ND	Non-Complying	Non-Complying
	12.09.2023	28.08.2023	2608 dt. 05.09.2023		25	112	7.3	41	400	2.62	Non-Complying	Non-Complying
	19.10.2023	29.09.2023	3074 dt. 14.10.2023		32	128	7.48	47	600	2.62	Non-Complying	Non-Complying
	29.11.2023	31.10.2023	3420 dt. 10.11.2023		24	128	7.06	71	700	1.47	Non-Complying	Non-Complying
	12.02.2024	25.01.2024	4335 dt. 31.01.2024		13	76	7.2	28	400	ND	Non-Complying	Non-Complying
		19.04.2024	79 dt. 25.04.2024		5.8	32	7.47	12	60	ND	Complying	Complying
		06.05.2024	222 dt. 15.05.2024		5	32	6.96	10	60	ND	Complying	Complying
		18.06.2024	390 dt. 27.06.2024		6.4	36	7.13	12		1.08	Complying	Complying
		19.07.2024	690 dt. 29.07.2024		7.2	44	6.93	16		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		21.08.2024	911 dt. 28.08.2024		8.2	44	7.03	15		ND	Complying	Complying
		10.09.2024	1070 dt. 18.09.2024		7.5	40	6.88	13		ND	Complying	Complying
		11.10.2024	1255 dt. 22.10.2024		7.2	44	7.6	12		ND	Complying	Complying
		08.11.2024	1414 dt. 18.11.2024		7.4	36	7.08	13		ND	Complying	Complying
		19.12.2024	1714 dt. 30.12.2024		7	40	6.79	13		ND	Complying	Complying
		14.01.2025	1912 dt. 22.01.2025		7	44	7.01	16		ND	Complying	Complying
3	(AMB-STP-003) 2 MLD STP Sec.7 , Urban Estate , Ambala City Ambala by HUDA in 10.9.2015	18.01.2021	139 dt. 29.01.2021		7	40	7	9	170	1.84	Complying	Complying
		26.02.2021	480 dt. 08.03.2021		5.4	24	7.62	15	34800	1.19	Complying	Complying
		26.03.2021	747 dt. 07.04.2021	31 m3/hr	13	64	7.21	21	480	1.96	Complying	Non-Complying
		28.04.2021	988 dt. 10.05.2021		7.5	40	7.4	12	840	1.12	Complying	Complying
		26.05.2021	1196 dt. 08.06.2021	0.63 MLD	12	68	7.68	24	2600	N.D.	Complying	Non-Complying
	02.09.2021	30.06.2021	1483 dt. 14.07.2021		10	40	8.28	12	2600	N.D.	Complying	Complying
	07.09.2021	30.07.2021	1867 dt. 18.08.2021		6.2	28	7.15	8	400	2.82	Complying	Non-Complying
	24.09.2021	09.08.2021	2004 dt. 20.08.2021		11	52	6.95	23	3400	5.46	Non-Complying	Non-Complying
	25.10.2021	27.09.2021	2523 dt. 11.10.2021		5.4	28	7.5	6	4800	1.04	Complying	Complying
	30.11.2021	28.10.2021	2873 dt. 12.11.2021		46	152	7.82	123	800	2.16	Non-Complying	Non-Complying
	24.12.2021	30.11.2021	3167 dt. 13.12.2021		72	244	6.89	168	4100	15.38	Non-Complying	Non-Complying
	18.01.2022	30.12.2021	3519 dt. 10.01.2022	14m3/hr	6.8	44	7.7	16	80	N.D.	Complying	Complying
	09.02.2022	24.01.2022	3882 dt. 02.02.2022		7	48	7.98	11	20	0.04	Complying	Complying
	05.04.2022	28.02.2022	4355 dt. 15.03.2022		8.2	48	7.03	15	40	0.24	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	29.11.2023	27.11.2023	3387 dt. 07.11.2023		7.5	44	6.75	14	70	ND	Complying	Complying
	11.12.2023	20.11.2023	3621 dt. 30.11.2023		5.2	28	7.02	10	50	ND	Complying	Complying
	18.01.2024	13.12.2023	3893 dt. 22.12.2023		6.4	36	6.81	11	70	ND	Complying	Complying
	12.02.2024	25.01.2024	4337 dt. 31.01.2024		8.2	48	7.43	13	90	ND	Complying	Complying
		18.06.2024	385 dt. 27.06.2024		5.8	32	6.76	9		0.36	Complying	Complying
		08.07.2024	556 dt. 19.07.2024		7.5	48	6.96	14		1.12	Complying	Complying
		22.08.2024	937 dt. 30.08.2024		7.2	44	7.05	13		ND	Complying	Complying
		05.09.2024	1043-B dt. 13.09.2024		7.6	40	6.36	15		ND	Complying	Complying
		07.10.2024	1189 dt. 15.10.2024		6.8	44	7.89	13		3.48	Complying	Complying
		08.11.2024	1412 dt. 18.11.2024		6	28	7.32	11		ND	Complying	Complying
		18.12.2024	1721 dt. 30.12.2024		7.2	40	6.68	13		ND	Complying	Complying
		08.01.2025	1821 dt. 16.01.2025		5.8	28	6.36	9		ND	Complying	Complying
4	(AMB-STP-004) 5 MLD Baldev Nagar , Unit.I , Ambala City by PHED 1.12.2012	25.01.2021	188 dt. 03.02.2021	1.37	10	52	7.72	21	1700	1.86	Complying	Complying
		26.02.2021	474 dt. 08.03.2021		6.8	32	7.62	14	210	1.44	Complying	Complying
		26.03.2021	743 dt. 07.04.2021	0.25	7.5	40	7.04	16	480	0.68	Complying	Complying
		09.04.2021	887 dt. 23.04.2021		5	24	7.23	7	830	1.04	Complying	Complying
		25.05.2021	1206 dt. 08.06.2021	0.32 MLD	5.2	20	7.32	15	490	N.D.	Complying	Complying
	09.08.2021	22.06.2021	1394 dt. 05.07.2021		6.2	28	7.13	18	900	1.04	Complying	Complying
	07.09.2021	29.07.2021	1864 dt. 18.08.2021		7.5	40	7.58	11	340	2.83	Complying	Complying
	30.09.2021	16.08.2021	2117 dt. 02.09.2021		10	52	7.25	19	4800	2.26	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	29.08.2023	16.08.2023	2513 dt. 24.08.2023		17	80	7.03	42	400	0.78	Non-Complying	Non-Complying
	29.11.2023	31.10.2023	3414 dt. 10.11.2023		24	112	6.79	64	200	1.48	Non-Complying	Non-Complying
		08.07.2024	559 dt. 19.07.2024		6	32	6.78	12		N.D.	Complying	Complying
		22.08.2024	933 dt. 30.08.2024		13	64	6.09	29		N.D.	Non-Complying	Non-Complying
		05.09.2024	1044 dt. 13.09.2024		14	76	6.86	29		N.D.	Non-Complying	Non-Complying
		07.10.2024	1187 dt. 15.10.2024		14	72	6.87	35		5.24	Non-Complying	Non-Complying
		08.11.2024	1410 dt. 18.11.2024		15	76	7.02	28		N.D.	Non-Complying	Non-Complying
		18.12.2024	1716 dt. 30.12.2024		16	80	7.86	31		N.D.	Non-Complying	Non-Complying
		08.01.2025	1818 dt. 16.01.2025		22	128	6.56	76		7.28	Non-Complying	Non-Complying
5	(AMB-STP-005) 3.25 Baldev Nagar , Unit.II ,Ambala City by PHED in 1.4.2016	25.01.2021	185 dt. 03.02.2021	0.91	6.4	32	7.6	11	1100	2.87	Complying	Complying
		26.02.2021	475 dt. 08.03.2021		5.2	20	7.67	8	400	1.01	Complying	Complying
		19.03.2021	705 dt. 30.03.2021		3.4	20	7.82	6	490	0.59	Complying	Complying
		09.04.2021	892 dt. 23.04.2021		7.2	36	7.4	8	760	1.22	Complying	Complying
		25.05.2021	1207 dt. 08.06.2021	0.15 MLD	5.8	28	7.32	13	700	2.3	Complying	Complying
	09.08.2021	22.06.2021	1393 dt. 05.07.2021		3.5	12	7.35	9	390	1.14	Complying	Complying
	07.09.2021	29.07.2021	1860 dt. 18.08.2021		5.8	36	7.5	13	760	N.D.	Complying	Complying
	30.09.2021	16.08.2021	2122 dt. 02.09.2021		9	52	7.25	18	7600	1.88	Complying	Complying
	25.10.2021	20.09.2021	2467 dt. 05.10.2021		14	52	7.61	12	8400	N.D.	Non-Complying	Non-Complying
	30.11.2021	27.10.2021	2838 dt. 11.11.2021	0.05 MLD	11	56	7.83	16	800	4.34	Non-Complying	Non-Complying
	24.12.2021	22.11.2021	3105 dt. 02.12.2021	0.12 MLD	12	52	7.36	12	200	0.68	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	18.01.2022	20.12.2021	3420 dt. 30.12.2021		7.5	48	7.36	13	500	1.04	Complying	Complying
	10.02.2022	28.01.2022	3925 dt. 08.02.2022		12	60	7.49	25	600	2.16	Non-Complying	Non-Complying
	05.04.2022	25.02.2022	4275 dt. 09.03.2022		18	70	8.01	24	600	1.32	Non-Complying	Non-Complying
	15.04.2022	29.03.2022	4732 dt. 07.04.2022		14	56	7.56	30	400	1.32	Non-Complying	Non-Complying
	18.05.2022	28.04.2022	5183 dt. 11.05.2022		12	56	6.98	23	400	2.17	Non-Complying	Non-Complying
	20.06.2022	20.05.2022	5508 dt. 01.06.2022		16	76	7.29	26	400	2.12	Non-Complying	Non-Complying
	18.07.2022	27.06.2022	5984 dt. 06.07.2022		16	72	7.4	31	900	2.12	Non-Complying	Non-Complying
	18.08.2022	29.07.2022	6371 dt. 09.08.2022		23	100	7.5	39	900	2.46	Non-Complying	Non-Complying
	09.09.2022	25.08.2022	6613 dt. 06.09.2022		14	64	7.03	35	400	2.96	Non-Complying	Non-Complying
	13.10.2022	19.09.2022	6975 dt. 07.10.2022		18	96	7.29	36	500	2.21	Non-Complying	Non-Complying
	09.11.2022	14.10.2022	7234 dt. 26.10.2022		16	72	6.78	52	500	2.35	Non-Complying	Non-Complying
	05.12.2022	18.11.2022	7513 dt. 30.11.2022		17	88	7.18	28	400	1.25	Non-Complying	Non-Complying
	13.01.2023	22.12.2022	8019 dt. 03.01.2023		15	80	7.36	35	500	1.37	Non-Complying	Non-Complying
	10.02.2023	30.01.2023	299 dt. 08.02.2023		17	84	7.61	32	700	1.53	Non-Complying	Non-Complying
	02.03.2023	17.02.2023	540 dt. 27.02.2023		15	68	7.54	27	400	1.38	Non-Complying	Non-Complying
	16.03.2023	02.03.2023	714 dt. 14.03.2023		21	96	7.3	38	600	1.74	Non-Complying	Non-Complying
	12.05.2023	27.04.2023	1397 dt. 09.05.2023		14	72	6.75	28	400	1.26	Non-Complying	Non-Complying
	14.06.2023	29.05.2023	1713 dt. 07.06.2023		16	92	7.11	36	200	2.64	Non-Complying	Non-Complying
	13.07.2023	27.06.2023	2008 dt. 05.07.2023		18	76	7.36	42	400	1.43	Non-Complying	Non-Complying
	29.08.2023	16.08.2023	2515 dt. 24.08.2023		17	68	7.09	31	500	1.56	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	29.11.2023	31.10.2023	3416 dt. 10.11.2023		24	108	6.75	51	200	2.62	Non-Complying	Non-Complying
	15.12.2023	29.11.2023	3695 dt. 08.12.2023		25	124	7.52	67	600	1.46	Non-Complying	Non-Complying
	18.01.2024	29.12.2023	4090 dt. 09.01.2024		26	128	6.87	56	800	ND	Non-Complying	Non-Complying
	25.01.2024	08.01.2024	4188-A dt. 17.01.2024		20	120	7.2	61	600	2.67	Non-Complying	Non-Complying
	Feb, 2024	08.02.2024	4550 dt. 19.02.2024		21	128	7.24	36	600	2.47	Non-Complying	Non-Complying
	Mar, 2024	22.04.2024	106 dt. 29.04.2024		24	132	7.18	51	3300	3.81	Non-Complying	Non-Complying
		06.05.2024	226 dt. 15.05.2024		11.2	60	7.39	147	800	2.87	Non-Complying	Non-Complying
		12.06.2024	350 dt. 24.06.2024		42	196	6.88	87		2.86	Non-Complying	Non-Complying
		08.07.2024	561 dt. 19.07.2024		18	88	6.3	35		2.53	Non-Complying	Non-Complying
		22.08.2024	934 dt. 30.08.2024		14	68	6.96	31		ND	Non-Complying	Non-Complying
		05.09.2024	1045 dt. 13.09.2024		13	68	6.83	28		ND	Non-Complying	Non-Complying
		07.10.2024	1188 dt. 15.10.2024		14	72	6.87	35		5.24	Non-Complying	Non-Complying
		8.11.2024	1411 dt. 18.11.2024		15	68	7.68	35		ND	Non-Complying	Non-Complying
		18.12.2024	1717 dt. 30.12.2024		16	80	7.86	31		ND	Non-Complying	Non-Complying
		08.01.2025	1819 dt. 16.01.2025		22	128	6.56	76		7.28	Non-Complying	Non-Complying
6	(AMB-STP-006) 5 MLD Moti Nagar, Unit.I , Ambala City by PHED in June 2010	21.01.2021	162 dt. 03.02.2021		7.5	36	7.48	19	290	0.06	Complying	Complying
		23.02.2021	442 dt. 04.03.2021		8	48	7.52	15	840	1.11	Complying	Complying
		26.03.2021	745 dt. 07.04.2021	0.29	11	64	7.17	27	840	0.59	Complying	Non-Complying
		09.04.2021	886 dt. 23.04.2021		4	24	7.36	8	1040	1.16	Complying	Complying
		25.05.2021	1208 dt. 08.06.2021	0.27 MLD	2.6	28	7.26	14	630	2.42	Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
09.08.2021	22.06.2021	1392 dt. 02.07.2021		4.6	20	7.6	11	630	1.73	Complying	Complying
07.09.2021	29.07.2021	1858 dt. 18.08.2021		3.6	16	7.4	12	760	12	Complying	Complying
24.09.2021	13.08.2021	2047 dt. 27.08.2021	0.99 MLD	8	40	7.43	18	400	2.03	Complying	Complying
25.10.2021	20.09.2021	2469 dt. 05.10.2021	2.5 MLD	7.5	28	8.18	13	2300	0.98	Complying	Complying
25.11.2021	19.10.2021	2794 dt. 03.11.2021		14	46	8.01	15	700	2.12	Non-Complying	Non-Complying
24.12.2021	22.11.2021	3112 dt. 02.12.2021		14	56	6.9	13	40	0.64	Non-Complying	Non-Complying
18.01.2022	21.12.2021	3424 dt. 31.01.2022		13	68	7.45	28	900	1.29	Non-Complying	Non-Complying
11.02.2022	29.01.2022	3966 dt. 08.02.2022		16	68	7.53	42	800	1.88	Non-Complying	Non-Complying
05.04.2022	25.02.2022	4278 dt. 09.03.2022		17	68	8.12	26	400	N.D.	Non-Complying	Non-Complying
	31.03.2022	4803 dt. 13.04.2022		14	60	8.1	26	700	1.21	Non-Complying	Non-Complying
18.05.2022	27.04.2022	5171 dt. 11.05.2022		15	60	6.96	18	600	2.83	Non-Complying	Non-Complying
22.06.2022	26.05.2022	5567 dt. 07.06.2022		13	68	7.06	32	400	1.42	Non-Complying	Non-Complying
18.07.2022	27.06.2022	5980 dt. 06.07.2022		16	72	6.89	27	1400	2.37	Non-Complying	Non-Complying
18.08.2022	29.07.2022	6365 dt. 09.08.2022		14	68	7.65	34	600	1.99	Non-Complying	Non-Complying
09.09.2022	25.08.2022	6606 dt. 06.09.2022		17	72	6.89	39	400	ND	Non-Complying	Non-Complying
17.10.2022	24.09.2022	7005 dt. 10.10.2022		18	96	7.23	33	200	1.21	Non-Complying	Non-Complying
09.11.2022	14.10.2022	7242 dt. 26.10.2022		16	72	7.05	42	500	1.52	Non-Complying	Non-Complying
23.12.2022	30.11.2022	7654 dt. 13.12.2022		13	60	7	28	200	ND	Non-Complying	Non-Complying
13.01.2023	22.12.2022	8014 dt. 03.01.2023		15	80	7.42	36	400	1.25	Non-Complying	Non-Complying
10.02.2023	30.01.2023	296 dt. 08.02.2023		15	80	7.7	36	500	1.36	Non-Complying	Non-Complying
13.03.2023	24.02.2023	628 dt. 07.03.2023		16	76	7.2	39	500	2.48	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	11.04.2023	22.03.2023	950 dt. 03.04.2023		14	72	7.48	28	500	1.46	Non-Complying	Non-Complying
	April	STP was not in Operation as same were under upgradation and total discharge was diverted STP Moti Nagar unit-II.										
	May	STP was not in Operation as same were under upgradation and total discharge was diverted STP Moti Nagar unit-II.										
	14.07.2023	30.06.2023	2090 dt. 10.07.2023		15	68	6.59	37	400	2.58	Complying	Complying
	12.09.2023	28.08.2023	2632 dt. 06.09.2023		7.6	40	6.83	13	80	ND	Complying	Complying
	18.10.2023	27.09.2023	3040 dt. 14.10.2023		25	116	7.18	40	600	BDL	Complying	Complying
		19.04.2024	81 dt. 25.04.2024		7	40	7.26	10	70	ND	Complying	Complying
		06.05.2024	219 dt. 15.05.2024		6.6	40	7.76	12	70	ND	Complying	Complying
		18.06.2024	387 dt. 27.06.2024		6.8	40	7.01	12		1.23	Complying	Complying
		19.07.2024	687 dt. 29.07.2024		6.8	36	7.78	14		ND	Complying	Complying
		21.08.2024	910 dt. 28.08.2024		7	44	6.97	13		ND	Complying	Complying
		10.09.2024	1067 dt. 18.09.2024		5.8	36	7.68	15		ND	Complying	Complying
		11.10.2024	1252 dt. 22.10.2024		7.4	44	7.2	13		ND	Complying	Complying
		08.11.2024	1418 dt. 18.11.2024		6.8	40	6.95	10		ND	Complying	Complying
		19.12.2024	1713 dt. 30.12.2024		7.2	40	6.75	13		ND	Complying	Complying
		14.01.2025	1913 dt. 22.01.2025		7.2	40	6.38	15		ND	Complying	Complying
7	(AMB-STP-007) 5 MLD STP Moti Nagar , Unit.II , Ambala City by PHED Ambala in 1.8.2016	21.01.2021	164 dt. 03.02.2021	0.55	6.2	24	7.51	11	1100	0.86	Complying	Complying
		23.02.2021	443 dt. 04.03.2021		10	52	7.58	17	940	1.16	Complying	Complying
		19.03.2021	708 dt. 30.03.2021		6.2	32	7.88	11	840	0.69	Complying	Complying
		09.04.2021	891 dt. 22.04.2021		6.8	24	7.21	9	940	0.97	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		26.05.2021	1205 dt. 08.06.2021	0.35 MLD	4.8	24	7.25	11	900	N.D.	Complying	Complying
	09.08.2021	22.06.2021	1395 dt. 05.07.2021		4.2	16	7.73	8	630	1.44	Complying	Complying
	07.09.2021	29.07.2021	1859 dt. 18.08.2021		7.5	44	7.4	11	840	N.D.	Complying	Complying
	24.09.2021	13.08.2021	2046 dt. 27.08.2021	0.95 MLD	11	52	7.32	19	4800	9.4	Non-Complying	Non-Complying
	25.10.2021	20.09.2021	2470 dt. 05.10.2021	2.5 MLD	6	36	8.2	12	4600	1.24	Complying	Complying
	25.11.2021	19.10.2021	2795 dt. 03.11.2021		12	40	7.97	12	800	1.22	Non-Complying	Non-Complying
	24.12.2021	22.11.2021	3113 dt. 02.12.2021		12	56	7.02	11	400	N.D.	Non-Complying	Non-Complying
	18.01.2022	21.12.2021	3428 dt. 31.01.2022		9.5	56	7.34	19	600	2.92	Complying	Complying
	11.02.2022	29.01.2022	3969 dt. 08.02.2022		12	54	7.22	22	400	N.D.	Non-Complying	Non-Complying
	05.04.2022	25.02.2022	4279 dt. 09.03.2022		13	76	7.55	34	600	0.51	Non-Complying	Non-Complying
		31.03.2022	4809 dt. 13.04.2022		13	72	7.39	24	600	1.09	Non-Complying	Non-Complying
	18.05.2022	27.04.2022	5172 dt. 11.05.2022		15	76	7	19	800	1.04	Non-Complying	Non-Complying
	22.06.2022	26.05.2022	5568 dt. 07.06.2022		12	64	7.04	28	600	2.32	Non-Complying	Non-Complying
	18.08.2022	29.07.2022	6364 dt. 09.08.2022		16	84	7.37	32	500	1.31	Non-Complying	Non-Complying
	09.09.2022	25.08.2022	6610 dt. 06.09.2022		16	68	7.12	43	500	2.76	Non-Complying	Non-Complying
	17.10.2022	24.09.2022	7004 dt. 10.10.2022		16	88	7.25	32	400	1.38	Non-Complying	Non-Complying
	09.11.2022	14.10.2022	7241 dt. 26.10.2022		15	68	6.67	38	200	1.02	Non-Complying	Non-Complying
	23.12.2022	30.11.2022	7655 dt. 13.12.2022		14	68	7.03	33	400	1.52	Non-Complying	Non-Complying
	13.01.2023	22.12.2022	8015 dt. 03.01.2023		17	76	7.49	28	400	1.27	Non-Complying	Non-Complying
	10.02.2023	30.01.2023	295 dt. 08.02.2023		15	72	7.87	34	500	1.33	Non-Complying	Non-Complying
	12.05.2023	27.04.2023	1393 dt. 09.05.2023		15	80	7.15	25	500	1.56	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	14.06.2023	31.05.2023	1740 dt. 09.06.2023		15	76	7.69	24	200	1.87	Non-Complying	Non-Complying
	14.07.2023	30.06.2023	2091 dt. 10.07.2023		16	76	6.89	43	600	3.62	Non-Complying	Non-Complying
	12.09.2023	28.08.2023	2609 dt. 05.09.2023		30	128	7.96	51	600	1.62	Non-Complying	Non-Complying
	18.10.2023	27.09.2023	3042 dt. 14.10.2023		16	76	7.42	28	400	2.23	Non-Complying	Non-Complying
		19.04.2024	82 dt. 25.04.2024		7	40	7.26	10	70	ND	Complying	Complying
		06.05.2024	220 dt. 15.05.2024		6.6	40	7.76	12	70	ND	Complying	Complying
		18.06.2024	388 dt. 27.06.2024		6.8	40	7.01	12		1.23	Complying	Complying
		19.07.2024	688 dt. 29.07.2024		6.8	36	7.78	14		ND	Complying	Complying
		21.08.2024	907 dt. 28.08.2024		7	44	6.97	13		ND	Complying	Complying
		10.09.2024	1068 dt. 18.09.2024		5.8	36	7.68	15		ND	Complying	Complying
		11.10.2024	1253 dt. 22.10.2024		7.4	44	7.2	13		ND	Complying	Complying
		08.11.2024	1417 dt. 18.11.2024		6.8	40	6.95	10		ND	Complying	Complying
		19.12.2024	1712 dt. 30.12.2024		7.2	40	6.75	13		ND	Complying	Complying
		14.01.2025	1914 dt. 22.01.2025		7.2	40	6.38	15		ND	Complying	Complying
8	(AMB-STP-008) 6 MLD STP Modal Town, Ambala City by PHED in 1.7.2012	21.01.2021	163 dt. 03.02.2021		7	28	7.52	18	1770	0.56	Complying	Complying
		23.02.2021	446 dt. 04.03.2021		5.6	28	7.45	9	940	1.15	Complying	Complying
		26.03.2021	748 dt. 07.04.2021	0.86	12	64	7.45	18	700	0.88	Complying	Non-Complying
		09.04.2021	884 dt. 23.04.2021		4.5	32	7.15	6	760	0.98	Complying	Complying
		26.05.2021	1202 dt. 08.06.2021	0.76 MLD	5.6	28	7.28	13	390	N.D.	Complying	Complying
	09.08.2021	22.06.2021	1398 dt. 05.07.2021		4.8	16	7.5	8	400	1.44	Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
07.09.2021	29.07.2021	1865 dt. 18.08.2021		7.2	36	7.48	12	500	3.9	Complying	Complying
30.09.2021	16.08.2021	2120 dt. 02.09.2021		9	52	7.21	22	3400	2.11	Complying	Complying
25.10.2021	20.09.2021	2468 dt. 05.10.2021	4.5 MLD	6.5	20	7.67	18	7000	N.D.	Complying	Complying
30.11.2021	27.10.2021	2840 dt. 11.11.2021		14	56	7.58	18	400	3.93	Non-Complying	Non-Complying
24.12.2021	23.11.2021	3108 dt. 02.12.2021	No data	10	48	7.17	11	400	2.37	Complying	Complying
18.01.2022	22.12.2021	3442 dt. 31.01.2022		13	60	7.45	26	400	0.77	Non-Complying	Non-Complying
11.02.2022	29.01.2022	3967 dt. 08.02.2022		14	64	7.55	32	300	1.97	Non-Complying	Non-Complying
05.04.2022	28.02.2022	4352 dt. 15.03.2022		5	42	7.61	12	Absent	N.D.	Complying	Complying
	31.03.2022	4806 dt. 13.04.2022		14	56	7.53	24	300	1.06	Non-Complying	Non-Complying
18.05.2022	27.04.2022	5172 dt. 11.05.2022		15	80	7.31	16	900	0.64	Non-Complying	Non-Complying
23.06.2022	27.05.2022	5607 dt. 09.06.2022		13	64	7.07	25	400	3.28	Non-Complying	Non-Complying
18.07.2022	29.06.2022	6020 dt. 12.07.2022		18	88	7.2	42	1200	2.42	Non-Complying	Non-Complying
18.08.2022	29.07.2022	6366 dt. 09.08.2022		15	72	7.22	35	500	1.31	Non-Complying	Non-Complying
13.09.2022	31.08.2022	6656 dt. 08.09.2022		13	64	6.8	28	200	2.16	Non-Complying	Non-Complying
17.10.2022	24.09.2022	7003 dt. 10.10.2022		17	84	7.7	34	600	2.18	Non-Complying	Non-Complying
09.11.2022	14.10.2022	7232 dt. 26.10.2022		17	76	6.78	114	400	1.95	Non-Complying	Non-Complying
14.12.2022	28.11.2022	7604 dt. 12.12.2022		17	72	6.85	34	500	2.27	Non-Complying	Non-Complying
13.01.2023	22.12.2022	8013 dt. 03.01.2022		16	72	7.33	31	400	ND	Non-Complying	Non-Complying
10.02.2023	30.01.2023	294 dt. 08.02.2023		14	64	7.68	28	500	1.28	Non-Complying	Non-Complying
02.03.2023	17.02.2023	537 dt. 27.02.2023		21	108	7.27	79	600	3.48	Non-Complying	Non-Complying
11.04.2023	22.03.2023	949 dt. 03.04.2023		15	76	7.01	29	400	2.76	Non-Complying	Non-Complying
12.05.2023	27.04.2023	1394 dt. 09.05.2023		16	76	6.86	32	400	1.92	Non-Complying	Non-Complying
14.06.2023	29.05.2023	1709 dt. 06.06.2023		15	76	7.18	32	500	2.24	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	13.07.2023	27.06.2023	2009 dt. 05.07.2023		7.2	24	7.06	11	90	ND	Complying	Complying
	08.08.2023	24.07.2023	2324 dt. 01.08.2023		7.4	40	7.17	13	80	ND	Complying	Complying
	12.09.2023	28.08.2023	2605 dt. 05.09.2023		7.5	40	7.14	12	60	0.34	Complying	Complying
	18.10.2023	27.09.2023	3039 dt. 14.10.2023		6.2	32	7.22	11	60	BDL	Complying	Complying
	29.11.2023	31.10.2023	3415 dt. 10.11.2023		7.8	44	6.3	14	80	ND	Complying	Complying
	11.12.2023	20.11.2023	3622 dt. 30.11.2023		6.4	32	7.02	12	70	ND	Complying	Complying
	18.01.2024	13.12.2023	3894 dt. 22.12.2023		5.8	32	7	10	50	ND	Complying	Complying
	07.02.2024	24.01.2024	4283 dt. 30.01.2024		8.6	48	7.4	10	90	ND	Complying	Complying
	Feb, 2024	08.02.2024	4554 dt 19.02.2024		7.6	44	7.42	10	60	ND	Complying	Complying
		22.04.2024	105 dt. 29.04.2024		8	48	7.09	13	80	ND	Complying	Complying
		06.05.2024	225 dt. 15.05.2024		6	36	6.96	10	50	ND	Complying	Complying
		18.06.2024	383 dt. 28.06.2024		6.4	48	7.05	13		ND	Complying	Complying
		08.07.2024	555 dt. 19.07.2024		6.4	44	6.68	15		1.07	Complying	Complying
		21.08.2024	909 dt. 28.08.2024		6.6	36	6.89	11		ND	Complying	Complying
		05.09.2024	1043 dt. 13.09.2024		8	48	6.65	15		ND	Complying	Complying
		07.10.2024	1190 dt. 15.10.2024		7	40	6.89	12		ND	Complying	Complying
		08.11.2024	1413 dt. 18.11.2024		7	36	7.84	14		ND	Complying	Complying
		18.12.2024	1722 dt. 30.12.2024		7	44	6.56	15		ND	Complying	Complying
		08.01.2025	1817 dt. 16.01.2025		5.8	36	6.39	11		ND	Complying	Complying
9	(AMB-STP-009) 3.25 Nasirpur Ambala City by PHED in 31.9.2016	25.01.2021	187 dt. 03.02.2021	0.4	3.8	24	7.7	9	200	2.15	Complying	Complying
		23.02.2021	445 dt. 04.03.2021		7	40	7.49	21	580	1.02	Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	26.03.2021	746 dt. 07.04.2021	0.32	14	72	7.28	24	630	0.91	Complying	Non-Complying
	09.04.2021	883 dt. 23.04.2021		5.8	32	7.14	7	670	0.97	Complying	Complying
	25.05.2021	1203 dt. 08.06.2021	0.38 MLD	5.2	20	7.25	14	200	N.D.	Complying	Complying
09.08.2021	22.06.2021	1397 dt. 05.07.2021		6.8	28	7.58	11	700	1.29	Complying	Complying
07.09.2021	29.07.2021	1862 dt. 18.08.2021		6.5	40	7.56	10	840	N.D.	Complying	Complying
30.09.2021	16.08.2021	2118 dt. 02.09.2021		8.5	48	7.2	18	3300	2.26	Complying	Complying
25.10.2021	20.09.2021	2473 dt. 05.10.2021	2 MLD	6	36	7.92	12	4300	1.04	Complying	Complying
30.11.2021	27.10.2021	2841 dt. 11.11.2021	0.42 MLD	18	64	8.76	21	600	N.D.	Non-Complying	Non-Complying
24.12.2021	23.11.2021	3110 dt. 02.12.2021	0.20 MLD	12	54	6.97	10	400	1.04	Non-Complying	Non-Complying
18.01.2022	23.12.2021	3467 dt. 31.01.2022	0.38	12	68	7.03	18	600	0.25	Non-Complying	Non-Complying
11.02.2022	29.01.2022	3964 dt. 08.02.2022		14	60	7.38	29	800	2.3	Non-Complying	Non-Complying
05.04.2022	28.02.2022	4356 dt. 15.03.2022		3	24	7.32	9	Absent	N.D.	Complying	Complying
	31.03.2022	4802 dt. 13.04.2022		13	56	7.4	31	600	1.08	Non-Complying	Non-Complying
18.05.2022	27.04.2022	5177 dt. 11.05.2022		12	56	7	19	400	2.03	Non-Complying	Non-Complying
23.06.2022	26.05.2022	5571 dt. 07.06.2022		16	80	7.06	34	600	2.17	Non-Complying	Non-Complying
18.07.2022	29.06.2022	6021 dt. 12.07.2022		16	84	7.24	38	1500	2.11	Non-Complying	Non-Complying
18.08.2022	29.07.2022	6373 dt. 09.08.2022		17	84	7.06	41	800	1.85	Non-Complying	Non-Complying
09.09.2022	25.08.2022	6611 dt. 06.09.2022		18	76	6.92	42	600	2.14	Non-Complying	Non-Complying
17.10.2022	24.09.2022	7000 dt. 10.10.2022		19	88	7.72	39	500	2.37	Non-Complying	Non-Complying
09.11.2022	14.10.2022	7237 dt. 26.10.2022		7.8	44	7.15	16	80	1.08	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	23.12.2022	30.11.2022	7656 dt. 13.12.2022		15	72	7.03	27	500	1.22	Non-Complying	Non-Complying
	13.01.2023	22.12.2022	8011 dt. 03.01.2022		18	80	7.46	32	400	2.46	Non-Complying	Non-Complying
	10.02.2023	30.01.2023	293 dt. 08.02.2023		13	60	7.5	28	80	1.22	Non-Complying	Non-Complying
	02.03.2023	17.02.2023	539 dt. 27.02.2023		13	60	7.23	38	400	1.36	Non-Complying	Non-Complying
	16.03.2023	03.03.2023	750 dt. 15.03.2023		15	72	7.16	28	400	ND	Non-Complying	Non-Complying
	12.05.2023	27.04.2023	1396 dt. 09.05.2023		12	64	6.68	27	200	ND	Non-Complying	Non-Complying
	14.06.2023	29.05.2023	1711 dt. 07.06.2023		16	88	7	34	500	2.48	Non-Complying	Non-Complying
	12.09.2023	28.08.2023	2606 dt. 05.09.2023		28	120	7.52	59	400	1.46	Non-Complying	Non-Complying
	29.11.2023	31.10.2023	3413 dt. 10.11.2023		26	120	6.7	57	400	2.61	Non-Complying	Non-Complying
	11.12.2023	20.11.2023	3625 dt. 30.11.2023		22	120	7.05	57	600	1.79	Non-Complying	Non-Complying
	18.01.2024	29.12.2023	4088 dt. 09.01.2024		23	116	6.62	41	400	ND	Non-Complying	Non-Complying
	12.02.2024	25.01.2024	4338 dt. 31.01.2024		15.4	92	7.43	29	600	ND	Non-Complying	Non-Complying
		08.02.2024	4555 dt. 19.02.2024		19	108	7.28	37	400	ND	Non-Complying	Non-Complying
		22.04.2024	103 dt. 29.04.2024		6.8	40	7.01	10	60	ND	Complying	Complying
		06.05.2024	218 dt. 15.05.2024		8	48	6.65	13	90	ND	Complying	Complying
		18.06.2024	386 dt. 27.06.2024		5.2	28	7.06	11		2.76	Complying	Complying
		19.07.2024	686 dt. 29.07.2024		6.5	32	6.68	13		ND	Complying	Complying
		21.08.2024	908 dt. 28.08.2024		5.8	36	6.78	13		ND	Complying	Complying
		10.09.2024	1066 dt. 18.09.2024		7.6	40	6.89	15		ND	Complying	Complying
		11.10.2024	1251 dt. 22.10.2024		6.2	32	6.87	10		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		08.11.2024	1416 dt. 18.11.2024		7.5	40	7.12	13		ND	Complying	Complying
		19.12.2024	1718 dt. 30.12.2024		7.5	40	6.93	16		ND	Complying	Complying
		14.01.2025	1915 dt. 22.01.2025		6.5	36	6.57	9		ND	Complying	Complying
10	(AMB-STP-010) 0.25 MLD Sadopur , Ambala PHED in 31.12.2016	25.01.2021	186 dt. 03.02.2021	0.08	4.6	20	7.82	13	700	2.87	Complying	Complying
		23.02.2021	440 dt. 04.03.2021		9	48	7.85	20	70	0.97	Complying	Complying
		19.03.2021	706 dt. 30.03.2021		4.2	24	7.82	8	40	0.54	Complying	Complying
		09.04.2021	890 dt. 23.04.2021		4	32	7.16	11	80	1.2	Complying	Complying
		26.05.2021	1198 dt. 08.06.2021	0.05 MLD	5.8	20	7.32	21	80	N.D.	Complying	Complying
	09.08.2021	22.06.2021	1401 dt. 05.07.2021		3.8	16	7.87	7	80	1.41	Complying	Complying
	07.09.2021	29.07.2021	1855 dt. 18.08.2021		3.8	16	7.73	11	Absent	N.D.	Complying	Complying
	24.09.2021	09.08.2021	2005 dt. 20.08.2021		12	56	7.53	25	70	7.48	Non-Complying	Non-Complying
	25.10.2021	20.09.2021	2475 dt. 05.10.2021	0.10 MLD	6.5	40	8.22	12	Absent	1.04	Complying	Complying
	30.11.2021	27.10.2021	2834 dt. 11.11.2021		7.5	40	8.88	14	Absent	6.93	Complying	Complying
	24.12.2021	22.11.2021	3114 dt. 02.12.2021		6	24	7.64	14	80	N.D.	Complying	Complying
	18.01.2022	22.12.2021	3443 dt. 31.01.2022		4.5	44	8.02	12	40	1.42	Complying	Complying
	11.02.2022	29.01.2022	3968 dt. 08.02.2022		7	32	7.5	12	70	1.99	Complying	Complying
	05.04.2022	28.02.2022	4354 dt. 15.03.2022		8	48	7.3	17	Absent	0.98	Complying	Complying
		31.03.2022	4807 dt. 13.04.2022		8	48	7.48	15	60	0.87	Complying	Complying
	18.05.2022	28.04.2022	5182 dt. 11.05.2022		8	48	7.48	18	70	2.26	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	23.06.2022	27.05.2022	5608 dt. 09.06.2022		7.8	40	7.27	18	90	2.83	Complying	Complying
	18.07.2022	27.06.2022	5981 dt. 06.07.2022		7	40	7.6	14	90	2.85	Complying	Complying
	18.08.2022	29.07.2022	6367 dt. 09.08.2022		7.2	28	7.65	12	80	1.31	Complying	Complying
	09.09.2022	25.08.2022	6614 dt. 06.09.2022		7.2	44	7.49	13	90	ND	Complying	Complying
	17.10.2022	24.09.2022	7002 dt. 10.10.2022		7.5	36	8.11	15	90	1.63	Complying	Complying
	09.11.2022	14.10.2022	7235 dt. 26.10.2022		7.5	48	7.5	18	80	1.15	Complying	Complying
	05.12.2022	16.11.2022	7490 dt. 29.11.2022		5.2	20	7.04	11	70	ND	Complying	Complying
	13.01.2023	22.12.2022	8009 dt. 03.01.2022		8.5	44	7.92	16	80	ND	Complying	Complying
	10.02.2023	30.01.2023	302 dt. 08.02.2023		7.5	40	7.8	12	90	ND	Complying	Complying
	02.03.2023	17.02.2023	538 dt. 27.02.2023		7.2	48	7.24	13	90	1.21	Complying	Complying
	16.03.2023	03.03.2023	749 dt. 15.03.2023		8	48	7.26	18	90	ND	Complying	Complying
	12.05.2023	27.04.2023	1390 dt. 09.05.2023		8	44	8.1	13	90	ND	Complying	Complying
	07.06.2023	18.05.2023	1570 dt. 29.05.2023		7	28	7.68	11	90	ND	Complying	Complying
	14.07.2023	30.06.2023	2088 dt. 10.07.2023		7	32	7.14	12	80	ND	Complying	Complying
	18.10.2023	28.09.2023	3043 dt. 14.10.2023		7.5	44	7.85	15	90	ND	Complying	Complying
	29.11.2023	26.10.2023	3385 dt. 07.11.2023		7.06	40	7.03	13	90	ND	Complying	Complying
	11.12.2023	20.11.2023	3623 dt. 30.11.2023		7.6	40	7.29	13	60	1.48	Complying	Complying
	18.01.2024	13.12.2023	3891 dt. 22.12.2023		8.4	48	7.05	13	80	ND	Complying	Complying
	Jan, 2024	08.01.2024	4188 dt 17.01.2024		7.6	40	7.1	11	80	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	Feb, 2024	18.02.2024	4553 dt. 19.02.2024		7	40	7.4	12	60	ND	Complying	Complying
		22.04.2024	104 dt. 29.04.2024		17	96	8.3	37	1500	2.86	Non-Complying	Non-Complying
		06.05.2024	223 dt. 15.05.2024		12	64	7.4	26	600	1.77	Non-Complying	Non-Complying
		18.06.2024	384 dt. 28.06.2024		6.5	36	7.32	10		0.48	Complying	Complying
		19.07.2024	691 dt. 29.07.2024		5.8	28	7.47	13		ND	Complying	Complying
		22.08.2024	935 dt. 30.08.2024		6.8	36	6.8	12		ND	Complying	Complying
		06.09.2024	1046 dt. 13.09.2024		7.4	36	7.09	12		ND	Complying	Complying
		11.10.2024	1256 dt. 22.10.2024		7	32	7.07	11		ND	Complying	Complying
		14.11.2024	1443 dt. 20.11.2024		6.5	32	7.16	12		ND	Complying	Complying
		18.12.2024	1719 dt. 30.12.2024		6.8	44	6.83	15		ND	Complying	Complying
		09.01.2025	1823 dt. 16.01.2025		11	60	6.6	27		1.08	Non-Complying	Non-Complying
11	(AMB-STP-011) 3.25 MLD Devi Nagar , Ambala City by PHED on 31.5.2013	25.01.2021	184 dt. 03.02.2021	0.15	7.4	40	7.81	17	400	1.44	Complying	Complying
		23.02.2021	447 dt. 04.03.2021		4.2	24	7.52	13	840	1.2	Complying	Complying
		19.03.2021	707 dt. 30.03.2021		5.8	36	7.85	9	790	0.89	Complying	Complying
		09.04.2021	889 dt. 23.04.2021		5.4	38	7.21	10	940	1.15	Complying	Complying
		26.05.2021	1201 dt. 08.06.2021	0.07 MLD	7.4	32	7.35	12	1100	N.D.	Complying	Complying
	09.08.2021	22.06.2021	1399 dt. 05.07.2021		4.5	20	7.52	9	630	1.32	Complying	Complying
	07.09.2021	29.07.2021	1861 dt. 18.08.2021		7.8	44	7.28	13	700	3.93	Complying	Complying
	24.09.2021	09.08.2021	2003 dt. 20.08.2021		8	48	7.97	18	2600	1.44	Complying	Complying
	25.10.2021	20.09.2021	2474 dt. 05.10.2021	2.1 MLD	6.4	44	8.24	12	3300	1.02	Complying	Complying
	30.11.2021	27.10.2021	2839 dt. 11.11.2021	0.03 MLD	14	68	7.32	26	400	4.12	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	23.12.2021	22.11.2021	3111 dt. 02.12.2021	0.09 MLD	14	56	7.59	11	400	N.D.	Non-Complying	Non-Complying
	18.01.2022	21.12.2021	3426 dt. 31.01.2022		8.5	48	7.55	18	500	2.36	Complying	Complying
	10.02.2022	28.01.2022	3924 dt. 08.02.2022		14	68	7.53	28	800	2.04	Non-Complying	Non-Complying
	05.04.2022	25.02.2022	4277 dt. 09.03.2022		14	68	8.02	23	600	N.D.	Non-Complying	Non-Complying
		31.03.2022	4808 dt. 13.04.2022		12	56	7.54	24	200	1.02	Non-Complying	Non-Complying
	18.05.2022	28.04.2022	5179 dt. 11.05.2022		13	60	7.73	18	500	1.99	Non-Complying	Non-Complying
	23.06.2022	27.05.2022	5609 dt. 09.06.2022		13	56	7.21	26	200	4.42	Non-Complying	Non-Complying
	18.07.2022	27.06.2022	5979 dt. 06.07.2022		15	64	7.23	22	1600	1.41	Non-Complying	Non-Complying
	18.08.2022	29.07.2022	6370 dt. 09.08.2022		16	80	7.69	34	400	ND	Non-Complying	Non-Complying
	09.09.2022	25.08.2022	6608 dt. 06.09.2022		15	60	8.09	38	500	ND	Non-Complying	Non-Complying
	18.10.2022	28.09.2022	7040 dt. 11.10.2022		20	96	7.24	31	500	1.74	Non-Complying	Non-Complying
	09.11.2022	14.10.2022	7238 dt. 26.10.2022		8	44	7.02	17	90	0.68	Complying	Complying
	05.12.2022	16.11.2022	7491 dt. 29.11.2022		18	72	7.5	31	500	2.96	Non-Complying	Non-Complying
	13.01.2023	22.12.2022	8012 dt. 03.01.2022		15	76	7.46	25	500	1.45	Non-Complying	Non-Complying
	10.02.2023	30.01.2023	298 dt. 08.02.2023		14	68	7.82	38	400	ND	Non-Complying	Non-Complying
	13.03.2023	24.02.2023	629 dt. 07.03.2023		15	72	7.27	33	400	2.32	Non-Complying	Non-Complying
	16.03.2023	03.03.2023	751 dt. 15.03.2023		18	84	7.3	38	500	1.34	Non-Complying	Non-Complying
	12.05.2023	27.04.2023	1398 dt. 09.05.2023		13	68	7.3	27	200	1.95	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
12	(AMB-STP-012) 3 MLD STP Naraingarh, Ambala by PHED in 1.7.2014	28.01.2021	215 dt. 04.02.2021		8	52	7.57	43	260	1.34	Complying	Complying
		26.02.2021	477 dt. 08.03.2021		7.4	40	7.78	34	54200	3.14	Complying	Complying
		25.03.2021	729 dt. 02.04.2021		14	80	7.32	5	3480	0.54	Complying	Complying
		28.04.2021	989 dt. 10.05.2021		14	60	7.8	12	630	N.D.	Complying	Complying
		26.05.2021	1199 dt. 08.06.2021	1.2 MLD	7.5	32	7.58	10	700	N.D.	Complying	Complying
	26.07.2021	23.06.2021	1440 dt. 05.07.2021		7	36	8.44	11	270	1.32	Complying	Complying
	07.09.2021	30.07.2021	1856 dt. 18.08.2021		2.8	12	7.74	10	940	N.D.	Complying	Complying
	30.09.2021	26.08.2021	2214 dt.10.09.2021		12	56	7.34	10	7900	0.77	Non-Complying	Non-Complying
	25.10.2021	21.09.2021	2479 dt. 06.10.2021	1.5 MLD	6.2	28	7.8	10	4100	2.37	Complying	Complying
	30.11.2021	27.10.2021	2842 dt. 11.11.2021		12	56	8.12	15	600	N.D.	Non-Complying	Non-Complying
	24.12.2021	25.11.2021	3134 dt. 07.12.2021		12	56	7.4	15	400	0.25	Non-Complying	Non-Complying
	18.01.2022	24.12.2021	3469 dt. 31.01.2022		12	56	7.54	18	400	2.37	Non-Complying	Non-Complying
	09.02.2022	24.01.2022	3883 dt. 02.02.2022		6.8	44	7.75	12	200	1.87	Complying	Complying
	05.04.2022	24.02.2022	4274 dt. 09.03.2022		13	60	8.04	25	400	0.85	Non-Complying	Non-Complying
	15.04.2022	29.03.2022	4750 dt. 07.04.2022		13	56	7.22	28	200	1.84	Non-Complying	Non-Complying
	18.05.2022	28.04.2022	5180 dt. 11.05.2022		14	72	7.09	24	300	1.93	Complying	Complying
	22.06.2022	25.05.2022	5562 dt. 07.06.2022		15	76	7.3	32	400	4.85	Non-Complying	Non-Complying
	18.07.2022	29.06.2022	6022 dt. 12.07.2022		17	80	7.3	33	1400	2.99	Non-Complying	Non-Complying
	05.08.2022	13.07.2022	6242 dt. 21.07.2022		15	72	7.18	32	500	1.02	Non-Complying	Non-Complying
	06.09.2022	23.08.2022	6584 dt. 01.09.2022		14	68	7.16	27	500	2.77	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	25.10.2022	08.10.2022	7127 dt. 19.10.2022		15	80	6.89	33	500	2.92	Non-Complying	Non-Complying
	05.12.2022	18.11.2022	7515 dt. 30.11.2022		19	88	6.89	37	400	1.42	Non-Complying	Non-Complying
	27.12.2022	02.12.2022	7684 dt. 19.12.2022		17	76	7.1	30	400	1.25	Non-Complying	Non-Complying
	31.01.2023	30.01.2023	184 dt. 17.01.2023		19	80	7.33	28	400	2.18	Non-Complying	Non-Complying
	16.03.2023	03.03.2023	878 dt. 28.03.2023		17	80	7.42	38	400	0.32	Non-Complying	Non-Complying
	09.05.2023	24.04.2023	1313 dt. 04.05.2023		17	96	7.35	37	500	1.29	Non-Complying	Non-Complying
	14.06.2023	29.05.2023	1714 dt. 07.06.2023		15	80	7.32	30	400	2.84	Non-Complying	Non-Complying
	14.07.2023	30.06.2023	2095 dt. 10.07.2023		18	84	6.68	38	500	2.86	Non-Complying	Non-Complying
	14.08.2023	27.07.2023	2363 dt. 03.08.2023		17	88	6.93	36	400	2.76	Non-Complying	Non-Complying
	29.08.2023	16.08.2023	2512 dt. 24.08.2023		22	108	7.03	92	700	6.72	Non-Complying	Non-Complying
	29.11.2023	31.10.2023	3419 dt. 10.11.2023		36	148	6.6	56	900	2.86	Non-Complying	Non-Complying
	14.12.2023	21.11.2023	3627 dt. 01.12.2023		38	150	7.12	61	800	2.81	Non-Complying	Non-Complying
	20.12.2023	04.12.2023	3728 dt. 13.12.2023		25	120	6.94	57	400	2.41	Non-Complying	Non-Complying
	Jan, 2024	08.01.2024	4186 dt. 17.01.2024		18	108	7.09	51	200	1.8	Non-Complying	Non-Complying
	Feb, 2024	06.02.2024	4499 dt. 15.02.2024		13	88	7.66	26	200	ND	Non-Complying	Non-Complying
	Mar, 2024	19.04.2024	83 dt. 25.04.2024		23	128	7.76	51	2100	3.6	Non-Complying	Non-Complying
		06.05.2024	228 dt. 15.05.2024		16	92	7.39	31	1200	2.8	Non-Complying	Non-Complying
		12.06.2024	348 dt. 24.06.2024		14	88	6.74	39		0.76	Non-Complying	Non-Complying
		08.07.2024	560 dt. 19.07.2024		17	76	8.19	32		2.78	Non-Complying	Non-Complying
		22.08.2024	937 dt. 30.08.2024		18	96	6.83	28		1.93	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		09.09.2024	1062 dt. 18.09.2024		13	64	7.05	24		ND	Non-Complying	Non-Complying
		11.10.2024	1250 dt. 22.10.2024		6.5	36	6.75	11		ND	Complying	Complying
		07.11.2024	1403 dt. 14.11.2024		15	60	7.03	32		ND	Non-Complying	Non-Complying
		24.12.2024	1742 dt. 31.12.2024		5.8	32	6.49	12		ND	Complying	Complying
		15.01.2025	1916-A dt. 22.01.2025		7.2	44	6.82	11		ND	Complying	Complying
13	(AMB-STP-014) 5 MLD STP Ambala by HSVP in 31.03.2021	28.11.2022 (Uploading Date 14.12.2022)	7606 dt. 12.12.2022		5.6	24	7.05	8	50	ND	Complying	Complying
	13.01.2023	22.12.2022	8020 dt. 03.01.2023		7	28	7.84	13	80	1.52	Complying	Complying
	10.02.2023	30.01.2023	297 dt. 08.02.2023		6.5	24	7.85	12	70	ND	Complying	Complying
	02.03.2023	17.02.2023	542 dt. 27.02.2023		7.6	32	7.68	12	80	ND	Complying	Complying
	16.03.2023	02.03.2023	715 dt. 14.03.2023		7.2	44	7.08	12	50	0.23	Complying	Complying
	04.05.2023	20.04.2023	1268 dt. 01.05.2023		6.5	28	7.4	10	80	ND	Complying	Complying
	07.06.2023	18.05.2023	1571 dt. 29.05.2023		8.2	44	7.46	17	80	ND	Complying	Complying
	13.07.2023	27.06.2023	2010 dt. 05.07.2023		7	28	6.87	12	70	ND	Complying	Complying
	08.08.2023	24.07.2023	2323 dt. 01.08.2023		7.8	44	7.42	15	90	1.22	Complying	Complying
	28.08.2023	14.08.2023	2499 dt. 22.08.2023		8.2	40	7.1	12	80	0.68	Complying	Complying
	18.10.2023	27.09.2023	3038 dt. 14.10.2023		7	36	7.2	10	80	BDL	Complying	Complying
	29.11.2023	27.11.2023	3386 dt. 07.11.2023		7	36	6.78	14	80	ND	Complying	Complying
	11.12.2023	20.11.2023	3619 dt. 30.11.2023		8.2	44	7.03	13	80	ND	Complying	Complying
	18.01.2024	13.12.2023	3892 dt. 22.12.2023		7.6	40	6.89	11	60	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	12.02.2024	25.01.2024	4336 dt. 31.01.2024		7	40	7.1	12	80	ND	Complying	Complying
		22.04.2024	102 dt. 29.04.2024		7.8	44	7.09	10	80	ND	Complying	Complying
		06.05.2024	224 dt. 15.05.2024		4.8	28	7.01	11	50	ND	Complying	Complying
		18.06.2024	392 dt. 27.06.2024		5.2	28	6.82	11		0.37	Complying	Complying
		08.07.2024	558 dt. 19.07.2024		7.2	36	7.1	15		ND	Complying	Complying
		22.08.2024	932 dt. 30.08.2024		5.4	28	6.56	9		0.84	Complying	Complying
		05.09.2024	1043-A dt. 13.09.2024		7.5	44	7.02	15		ND	Complying	Complying
		07.10.2024	1191 dt. 15.10.2024		7.2	44	6.89	13		ND	Complying	Complying
		08.11.2024	1419 dt. 18.11.2024		5.8	36	6.48	10		ND	Complying	Complying
		18.12.2024	1723 dt. 30.12.2024		7	36	6.52	15		ND	Complying	Complying
		08.01.2025	1820 dt. 16.01.2025		7.2	44	6.26	13		ND	Complying	Complying
14	(AMB-STP-015) 10 MLD STP, Babyal, Ambala by ULBD in 31.03.2023		No discharge									
	Kurukshetra											
15	(KUK-STP-002) 25 MLD STP Thanesar, Kurukshetra by PHED in 31.03.2020	18.01.2021	140 dt. 29.01.2021		10	52	7.48	19	2100	2.14	Complying	Complying
		15.02.2021	404 dt. 24.02.2021		8.5	52	7.42	39	500	0.6	Complying	Complying
		17.03.2021	670 dt. 25.03.2021		14	76	6.98	22		2.19	Complying	Complying
		23.04.2021	969 dt. 05.05.2021		7.4	36	8.6	10	80	1.06	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		21.05.2021	1192 dt. 04.06.2021	17.55 MLD	5.5	28	7.05	14	Absent	N.D.	Complying	Complying
	26.07.2021	23.06.2021	1434 dt. 05.07.2021		7	32	7.39	7	80	N.D.	Complying	Complying
	07.09.2021	15.07.2021	1662 dt. 27.07.2021		7.4	36	7.16	10	80	1.06	Complying	Complying
	24.09.2021	10.08.2021	2001 dt. 20.08.2021	17.5 MLD	6.8	24	7.28	13	BDL	N.D.	Complying	Complying
	25.10.2021	14.09.2021	2403 dt. 30.09.2021	4.16 MLD	6	36	7.92	8	Absent	2.05	Complying	Complying
	25.11.2021	12.10.2021	2751 dt. 29.10.2021	21.91 MLD	6.8	40	8.52	14	30	1.87	Complying	Complying
	09.12.2021	16.11.2021	3047 dt. 29.11.2021	17.5 MLD	7.4	40	7.38	12	90	1.2	Complying	Complying
	18.01.2022	07.12.2021	3191 dt. 15.12.2021	17 MLD	7.4	48	7.83	13	90	0.64	Complying	Complying
	10.02.2022	06.01.2022	3569 dt. 17.01.2022	17.5 MLD	6.5	40	7.48	13	20	N.D.	Complying	Complying
	06.04.2022	16.02.2022	4182 dt. 24.02.2022		7	40	7.32	12	70	1.04	Complying	Complying
	15.04.2022	21.03.2022	4656 dt. 31.03.2022		8	48	7.43	8	70	N.D.	Complying	Complying
	17.05.2022	13.04.2022	5068 dt. 03.05.2022		7	40	7.17	13	70	0.17	Complying	Complying
	08.06.2022	11.05.2022	5399 dt. 25.05.2022		7.8	48	7.4	17	70	1.04	Complying	Complying
	18.07.2022	22.06.2022	5929 dt. 01.07.2022		7.8	40	8.02	13	90	2.87	Complying	Complying
	05.08.2022	13.07.2022	6261 dt. 25.07.2022		7.5	36	7.91	12	70	2.79	Complying	Complying
	09.09.2022	26.08.2022	6628 dt. 06.09.2022		7.8	44	7.25	16	90	1.03	Complying	Complying
	11.10.2022	16.09.2022	6911 dt. 30.09.2022		7	40	7.05	8	90	1.22	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	25.10.2022	04.10.2022	7073 dt. 17.10.2022		7	36	6.79	12	70	ND	Complying	Complying
	23.11.2022	01.11.2022	7330 dt. 09.11.2022		7.5	48	7.06	13	90	0.82	Complying	Complying
	13.01.2023	23.12.2022	8006 dt. 03.01.2023		6.2	24	7.33	13	70	ND	Complying	Complying
	09.02.2023	25.01.2023	275 dt. 06.02.2023		7.8	40	7.4	14	90	ND	Complying	Complying
	21.02.2023	08.02.2023	391 dt. 17.02.2023		7.5	40	7.17	11	90	ND	Complying	Complying
	28.03.2023	11.03.2023	859 dt. 22.03.2023		6.8	44	7.07	15	80	ND	Complying	Complying
	09.05.2023	25.04.2023	1317 dt. 04.05.2023		7.6	36	7	13	90	ND	Complying	Complying
	06.06.2023	10.05.2023	1474 dt. 23.05.2023		7.6	44	7.48	15	90	ND	Complying	Complying
	12.07.2023	20.06.2023	1969 dt. 28.06.2023		7.5	48	7	12	90	ND	Complying	Complying
	14.08.2023	27.07.2023	2375 dt. 04.08.2023		8.6	40	7.35	14	90	ND	Complying	Complying
	12.09.2023	24.08.2023	2595 dt. 04.09.2023		8	40	7.02	14	60	ND	Complying	Complying
	21.09.2023	06.09.2023	2781 dt. 14.09.2023		7.4	48	7.04	13	80	ND	Complying	Complying
	03.11.2023	10.10.2023	3159 dt. 28.10.2023		7.2	40	7.03	13	80	ND	Complying	Complying
	23.11.2023	03.11.2023	3439 dt. 14.11.2023		7.4	36	7.34	15	80	ND	Complying	Complying
	18.01.2024	11.12.2023	3837 dt. 21.12.2023		6.4	36	6.84	12	70	ND	Complying	Complying
	Jan, 2024	05-01-2024	4160-16/01/2024		6.8	36	7.06	12	70	ND	Complying	Complying
	Feb, 2024	07-02-2024	4509-16/02/2024		5.6	32	7.8	10	60	ND	Complying	Complying
	Mar, 2024	13/03/2024	4918-22/03/2024		7	40	7.28	12	80	ND	Complying	Complying
	Apr, 2024	25/04/2024	152-03/05/2024		6.8	40	7.2	12	70	ND	Complying	Complying
		10.07.2024	588 dt. 22.07.2024		7.5	44	6.78	15		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		09.08.2024	846 dt. 20.08.2024		7	40	7.24	13		ND	Complying	Complying
		06.09.2024	1049 dt. 13.09.2024		6.2	36	6.47	10		ND	Complying	Complying
		16.10.2024	1285 dt. 24.10.2024		6.2	40	7.02	11		ND	Complying	Complying
		22.11.2024	1494 dt. 29.11.2024		7.2	36	6.78	12		ND	Complying	Complying
		19.12.2024	1709 dt. 30.12.2024		5.8	32	6.89	11		ND	Complying	Complying
		16.01.2025	1932 dt. 24.01.2025		6	28	7.15	8		1.08	Complying	Complying
		07.02.2025	2081 dt. 14.02.2025		6.2	36	6.76	8		ND	Complying	Complying
16	(KUK-STP-003) 15 MLD STP, Sector-6, Urban Estate, Thanesar, Kurukshetra by HUDA in 2020	18.01.2021	139 dt. 29.01.2021		7	40	7	9	170	1.84	Complying	Complying
		15.02.2021	405 dt. 24.02.2021		8	44	7.31	18	400	2.92	Complying	Complying
		17.03.2021	671 dt. 25.03.2021		4.5	20	6.97	6	430	2.11	Complying	Complying
		23.04.2021	971 dt. 05.05.2021		6.8	32	8.4	8	80	0.98	Complying	Complying
		21.05.2021	1193 dt. 04.06.2021	10.6 MLD	4.8	20	7.4	12	Absent	N.D.	Complying	Complying
	26.07.2021	23.06.2021	1435 dt. 05.07.2021		7.2	28	7.44	8	70	N.D.	Complying	Complying
	07.09.2021	15.07.2021	1663 dt. 27.07.2021	13.5 MLD	6.8	32	7.4	8	800	0.98	Complying	Complying
	24.09.2021	10.08.2021	2002 dt. 20.08.2021	14.5 MLD	4.2	16	7.48	10	BDL	2.16	Complying	Complying
	25.10.2021	14.09.2021	2402 dt. 30.09.2021	10 MLD	4	24	7.47	10	Absent	N.D.	Complying	Complying
	25.11.2021	12.10.2021	2750 dt. 29.10.2021		6.2	28	7.74	11	Absent	2.04	Complying	Complying
	09.12.2021	16.11.2021	3048 dt. 29.11.2021	13 MLD	6.4	28	7.25	14	40	1.15	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks	
		18.01.2022	07.12.2021	3192 dt. 15.12.2021	13.5 MLD	6.8	40	7.43	11	10	1.95	Complying	Complying
		10.02.2022	06.01.2022	3568 dt. 17.01.2022	11.5 MLD	3.5	12	6.74	8	Absent	N.D.	Complying	Complying
		06.04.2022	16.02.2022	4180 dt. 24.02.2022		6	28	7.25	9	30	N.D.	Complying	Complying
		15.04.2022	22.03.2022	4659 dt. 31.03.2022		6.8	32	7.32	10	60	1.47	Complying	Complying
		17.05.2022	13.04.2022	5066 dt. 03.05.2022		6.2	28	7.97	9	60	0.78	Complying	Complying
		08.06.2022	11.05.2022	5400 dt. 25.05.2022		5.8	24	8.33	11	90	1.85	Complying	Complying
		18.07.2022	22.06.2022	5926 dt. 01.07.2022		6	24	7.7	13	80	0.87	Complying	Complying
		05.08.2022	13.07.2022	6263 dt. 25.07.2022		8.5	48	7.94	16	80	1.58	Complying	Complying
		09.09.2022	26.08.2022	6627 dt. 06.09.2022		7	36	7.01	15	80	ND	Complying	Complying
		11.10.2022	16.09.2022	6910 dt. 30.09.2022		4.6	44	7.49	16	90	2.18	Complying	Complying
		25.10.2022	04.10.2022	7072 dt. 17.10.2022		7.2	44	7.3	12	70	ND	Complying	Complying
		23.11.2022	01.11.2022	7340 dt. 09.11.2022		8	44	7.01	15	80	ND	Complying	Complying
		13.01.2023	23.12.2022	8004 dt. 03.01.2023		7.8	28	7.43	11	80	ND	Complying	Complying
		09.02.2023	25.01.2023	278 dt. 06.02.2023		7.6	32	7.53	13	90	1.35	Complying	Complying
		21.02.2023	08.02.2023	392 dt. 17.02.2023		7.2	32	7.17	12	80	ND	Complying	Complying
		28.03.2023	11.03.2023	860 dt. 22.03.2023		7	36	7.5	11	70	ND	Complying	Complying
		09.05.2023	25.04.2023	1321 dt. 04.05.2023		6	24	7.69	9	80	ND	Complying	Complying
		06.06.2023	10.05.2023	1476 dt. 23.05.2023		7.8	36	7.82	14	80	ND	Complying	Complying
		24.06.2023	07.06.2023	1778 dt. 15.06.2023		8	48	8	17	80	ND	Complying	Complying
		21.07.2023	06.07.2023	2156 dt. 17.07.2023		8	44	7.2	16	80	ND	Complying	Complying
		12.09.2023	29.08.2023	2702 dt. 06.09.2023		7.8	30	7.49	14	80	ND	Complying	Complying
		03.11.2023	10.10.2023	3158 dt. 28.10.2023		6.5	36	7.22	12	70	ND	Complying	Complying
		23.11.2023	03.11.2023	3440 dt. 14.11.2023		8	44	7.07	16	80	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	18.01.2024	11.12.2023	3836 dt. 21.12.2023		5.8	32	6.8	10	50	ND	Complying	Complying
	Jan, 2024	24/01/2024	4316-31/01/2024		4.8	28	7.27	10	50	ND	Complying	Complying
	Feb, 2024	16/02/2024	4594-23/02/2024		5	28	7.24	10	60	ND	Complying	Complying
	Mar, 2024	13/03/2024	4917-22/03/2024		5.6	32	7.28	10	50	ND	Complying	Complying
	Apr, 2024	25/04/2024	150-03/05/2024		4.8	28	6.96	10	40	ND	Complying	Complying
	May, 2024	21.06.2024	457 dt. 05.07.2024									
		10.07.2024	587 dt. 22.07.2024		5.6	36	6.89	15		ND	Complying	Complying
		09.08.2024	847 dt. 20.08.2024		4.8	28	7.15	11		ND	Complying	Complying
		06.09.2024	1048 dt. 13.09.2024		4.6	28	6.82	11		ND	Complying	Complying
		16.10.2024	1286 dt. 24.10.2024		4.8	40	6.87	10		ND	Complying	Complying
		22.11.2024	1495 dt. 29.11.2024		6.2	32	6.7	11		ND	Complying	Complying
		19.12.2024	1711 dt. 30.12.2024		6.8	40	6.66	12		ND	Complying	Complying
		17.01.2025	1934 dt. 24.01.2025		8	48	6.79	16		ND	Complying	Complying
		06.02.2025	2080 dt. 14.02.2025		4.8	36	6.49	11		ND	Complying	Complying
17	(KUK-STP-004) 8 MLD STP Model Town , Pehowa Kurukshetra by PHED in May, 2015	18.01.2021	141 dt. 29.01.2021		8.5	48	7.52	21	490	2.26	Complying	Complying
		15.02.2021	403 dt. 24.02.2021		5.6	24	7.68	45	4800	0.31	Complying	Complying
		17.03.2021	669 dt. 25.03.2021		12	60	7.22	26	2700	2.38	Complying	Complying
		23.04.2021	970 dt. 05.05.2021		9	52	7.65	8	490	0.97	Complying	Complying
		21.05.2021	1190 dt. 04.06.2021	4.50 MLD	6.5	36	7.2	13	1300	1.58	Complying	Complying
	26.07.2021	23.06.2021	1436 dt. 05.07.2021		6.8	32	7.39	13	480	1.84	Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
07.09.2021	15.07.2021	1661 dt. 27.07.2021	3.5 MLD	9	52	7.15	8	490	0.97	Complying	Complying
24.09.2021	12.08.2021	2061 dt. 30.08.2021	5 MLD	12	56	7.28	19	3400	2.04	Non-Complying	Non-Complying
25.10.2021	14.09.2021	2404 dt. 30.09.2021	4 MLD	6	36	7.75	14	90	1.57	Complying	Complying
25.11.2021	12.10.2021	2754 dt. 29.10.2021	2.5 MLD	7.2	36	8.42	10	Absent	2.16	Complying	Complying
09.12.2021	16.11.2021	3049 dt. 29.11.2021	5 MLD	14	62	7.04	17	400	N.D.	Non-Complying	Non-Complying
18.01.2022	07.12.2021	3195 dt. 15.12.2021	4.5 MLD	7	32	7.39	12	400	N.D.	Complying	Complying
10.02.2022	06.01.2022	3570 dt. 17.01.2022	3.5 MLD	16	108	7.47	41	400	0.24	Non-Complying	Non-Complying
06.04.2022	16.02.2022	4181 dt. 24.02.2022		6.5	40	7.06	12	300	0.72	Non-Complying	Non-Complying
18.04.2022	10.03.2022	4518 dt. 22.03.2022		8	48	7.5	18	400	2.37	Non-Complying	Non-Complying
17.05.2022	14.04.2022	5076 dt. 03.05.2022		7.8	36	7.49	17	200	1.02	Non-Complying	Non-Complying
08.06.2022	11.05.2022	5401 dt. 25.05.2022		7.5	40	7.68	13	400	2.14	Complying	Complying
18.07.2022	22.06.2022	5928 dt. 01.07.2022		14	68	7.47	42	500	4.39	Non-Complying	Non-Complying
05.08.2022	13.07.2022	6262 dt. 25.07.2022	300	13	64	7.52	29	300	2.79	Non-Complying	Non-Complying
09.09.2022	26.08.2022	6625 dt. 06.09.2022		15	60	6.98	37	500	2.37	Non-Complying	Non-Complying
10.10.2022	16.09.2022	6908 dt. 30.09.2022		14	60	7.3	28	200	2.42	Non-Complying	Non-Complying
25.10.2022	04.10.2022	7071 dt. 17.10.2022		7.8	40	7.1	13	400	0.51	Non-Complying	Non-Complying
23.11.2022	01.11.2022	7329 dt. 09.11.2022		14	68	7.1	33	200	1.32	Non-Complying	Non-Complying
13.01.2023	23.12.2022	8005 dt. 03.01.2023		14	60	7.4	32	200	1.23	Non-Complying	Non-Complying
09.02.2023	25.01.2023	276 dt. 06.02.2023		8	32	7.43	13	80	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	28.03.2023	11.03.2023	861 dt. 22.03.2023		28	120	7.15	75	500	2.23	Non-Complying	Non-Complying
	09.05.2023	25.04.2023	1320 dt. 04.05.2023		18	92	7.52	38	600	2.23	Non-Complying	Non-Complying
	06.06.2023	10.05.2023	1475 dt. 23.05.2023		28	124	7.94	66	500	4.85	Non-Complying	Non-Complying
	12.07.2023	20.06.2023	1968 dt. 28.06.2023		16	84	7.11	27	500	1.86	Non-Complying	Non-Complying
	14.08.2023	27.07.2023	2376 dt. 04.08.2023		14	68	7.03	31	400	2.83	Non-Complying	Non-Complying
	12.09.2023	24.08.2023	2594 dt. 04.09.2023		28	120	7.04	38	600	3.16	Non-Complying	Non-Complying
	21.09.2023	06.09.2023	2782 dt. 14.09.2023		18	76	7.16	24	400	1.08	Non-Complying	Non-Complying
	03.11.2023	10.10.2023	3160 dt. 28.10.2023		23	124	7.56	56	500	3.72	Non-Complying	Non-Complying
	23.11.2023	02.11.2023	3437 dt. 14.11.2023		14	76	7.44	31	400	2.44	Non-Complying	Non-Complying
	18.01.2024	11.12.2023	3835 dt. 21.12.2023		14	80	6.96	36	200	ND	Non-Complying	Non-Complying
	Jan, 2024	45413	4159-16/01/2024		20	112	7.18	41	400	3.48	Non-Complying	Non-Complying
	Feb, 2024	45475	4508-16/02/2024		13	84	7.37	31	400	ND	Non-Complying	Non-Complying
	Mar, 2024	20/03/2024	5087-28/03/2024		25	128	6.89	54	3300	2.64	Non-Complying	Non-Complying
	Apr, 2024	25/04/2024	151-03/05/2024		19	116	6.79	54	2100	2.61	Non-Complying	Non-Complying
		21.06.2024	457 dt. 05.07.2024		7.6	48	8.4	13		ND	Complying	Complying
		05.07.2024	521 dt. 12.07.2024		15	96	7.1	32		2.84	Non-Complying	Non-Complying
		16.08.2024	882 dt. 23.08.2024		72	268	7.24	145		8.72	Non-Complying	Non-Complying
		10.09.2024	1060 dt. 18.09.2024		72	252	7.12	175		2.76	Non-Complying	Non-Complying
		16.10.2024	1287 dt. 24.10.2024		16	80	6.97	32		ND	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		07.11.2024	1396 dt. 13.11.2024		18	68	6.92	32		0.26	Non-Complying	Non-Complying
		19.12.2024	1708 dt. 30.12.2024		14	88	6.98	35		3.42	Non-Complying	Non-Complying
		09.01.2025	1852 dt. 17.01.2025		12	60	7.05	27		ND	Non-Complying	Non-Complying
		06.02.2025	2082 dt. 14.02.2025		25	144	6.64	58		ND	Non-Complying	Non-Complying
18	(KUK-STP-005) 11.5 MLD STP Ladwa Road, Shahbad Kurukshetra by PHED in May, 2016	18.01.2021	138 dt. 29.01.2021		12	72	7.19	33	330	0.88	Complying	Complying
		15.02.2021	407 dt. 24.02.2021		6.8	40	7.76	35	4000	1.86	Complying	Complying
		17.03.2021	673 dt. 25.03.2021		12	60	7.14	19	2700	2.35	Complying	Complying
		23.04.2021	973 dt. 5.5.2021		8	48	7.68	11	70	0.78	Complying	Complying
		21.05.2021	1191 dt. 04.06.2021	7.15 MLD	7.5	40	7.1	13	Absent	N.D.	Complying	Complying
	26.07.2021	23.06.2021	1438 dt. 05.07.2021		5.6	24	7.83	9	80	N.D.	Complying	Complying
	07.09.2021	15.07.2021	1665 dt. 27.07.2021	7.5 MLD	8	48	7.15	11	70	0.78	Complying	Complying
	24.09.2021	12.08.2021	2063 dt. 30.08.2021	6.5 MLD	4.8	20	7.34	9	70	1.87	Complying	Complying
	25.10.2021	14.09.2021	2401 dt. 30.09.2021	6.5 MLD	4	32	7.58	8	80	0.78	Complying	Complying
	25.11.2021	12.10.2021	2752 dt. 29.10.2021	7.5 MLD	4.8	24	8.52	12	40	1.85	Complying	Complying
	09.12.2021	16.11.2021	3050 dt. 29.11.2021	7.5 MLD	7	32	6.95	9	70	0.54	Complying	Complying
	18.01.2022	07.12.2021	3194 dt. 15.12.2021	8 MLD	6.5	40	7.37	15	70	2.37	Complying	Complying
	10.02.2022	06.01.2022	3566 dt. 17.01.2022	7.5 MLD	6.8	44	7.12	15	40	N.D.	Complying	Complying
	06.04.2022	16.02.2022	4183 dt. 24.02.2022		7.2	44	7.1	13	Absent	0.12	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	15.04.2022	22.03.2022	4657 dt. 31.03.2022		7.8	44	7.29	9	Absent	N.D	Complying	Complying
	17.05.2022	14.04.2022	5067 dt. 03.05.2022		7.2	44	7.49	14	40	1.34	Complying	Complying
	10.06.2022	20.05.2022	5505 dt. 01.06.2022		7.6	40	7.73	13	80	1.47	Complying	Complying
	18.07.2022	22.06.2022	5925 dt. 01.07.2022		7.5	40	7.12	15	50	1.86	Complying	Complying
	05.08.2022	13.07.2022	6260 dt. 25.07.2022		8	44	7.38	17	90	3.64	Complying	Complying
	09.09.2022	26.08.2022	6626 dt. 06.09.2022		7.6	48	7.2	14	90	0.34	Complying	Complying
	11.10.2022	16.09.2022	6909 dt. 30.09.2022		8	40	7.19	13	80	1.24	Complying	Complying
	25.10.2022	04.10.2022	7069 dt. 17.10.2022		8.5	48	7.27	15	90	1.95	Complying	Complying
	23.11.2022	02.11.2022	7341 dt. 09.11.2022		9	48	6.78	15	90	1.08	Complying	Complying
	13.01.2023	27.12.2022	8087 dt. 10.01.2023		6.8	44	7.44	12	50	1.12	Complying	Complying
	09.02.2023	25.01.2023	277 dt. 06.02.2023		8.2	48	8	15	80	1.22	Complying	Complying
	02.03.2023	15.02.2023	532 dt. 27.02.2023		7.5	36	7.32	13	80	ND	Complying	Complying
	17.04.2023	29.03.2023	1041 dt. 10.04.2023		8.2	44	7	16	90	ND	Complying	Complying
	09.05.2023	24.04.2023	1318 dt. 04.05.2023		7	40	7.09	12	80	ND	Complying	Complying
	14.06.2023	25.05.2023	1693 dt. 02.06.2023		3.8	16	7.08	8	80	ND	Complying	Complying
	24.06.2023	07.06.2023	1779 dt. 15.06.2023		7.6	44	7.12	16	90	ND	Complying	Complying
	21.07.2023	06.07.2023	2155 dt. 17.07.2023		7.8	40	6.8	15	80	ND	Complying	Complying
	12.09.2023	24.08.2023	2593 dt. 04.09.2023		8	44	7.17	13	80	ND	Complying	Complying
	10.11.2023	20.10.2023	3301 dt. 31.10.2023		7.8	40	7.23	13	80	ND	Complying	Complying
	23.11.2023	03.11.2023	3441 dt. 14.11.2023		7.5	40	7.55	13	80	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	05.01.2024	19.12.2023	4001 dt. 29.12.2023		6	32	7.24	11	70	ND	Complying	Complying
	Jan, 2024	24/01/2024	4317-31/01/2024		5	32	7.5	10	60	ND	Complying	Complying
	Feb, 2024	29/02/2024	4796-15/03/2024		6	36	7.33	10	50	ND	Complying	Complying
	Mar, 2024	20/03/2024	5086-28/03/2024		5.8	32	7.25	10	50	ND	Complying	Complying
	Apr, 2024	26/04/2024	153-03/05/2024		7.6	44	7.01	13	80	ND	Complying	Complying
		28.06.2024	496 dt. 09.07.2024		6.5	40	6.5	10		ND	Complying	Complying
		09.07.2024	586 dt. 22.07.2024		7.6	36	6.98	13		ND	Complying	Complying
		08.08.2024	844 dt. 20.08.2024		8.5	48	6.49	17		ND	Complying	Complying
		09.08.2024	844 dt. 20.08.2024		8.5	48	8.49	17		ND	Complying	Complying
		18.09.2024	1117 dt. 01.10.2024		7.8	40	7.16	15		ND	Complying	Complying
		16.10.2024	1284 dt. 24.10.2024		6.8	44	6.63	15		ND	Complying	Complying
		22.11.2024	1496 dt. 29.11.2024		6.8	40	6.87	12		ND	Complying	Complying
		19.12.2024	1710 dt. 30.12.2024		5.8	36	7.06	14		ND	Complying	Complying
		29.01.2025	1993 dt. 05.02.2025		6.8	40	6.76	14		ND	Complying	Complying
		24.02.2025	2169 dt. 10.03.2025		6.2	36	6.79	11		ND	Complying	Complying
	Panchkula											
19	(PKL-STP-001) 18 MLD STP Panchkula by HUDA in 31.12.2002	14.01.2021	112 dt. 22.01.2021		7.5	34	7.56	21	3480	0.64	Complying	Complying
		12.02.2021	380 dt. 22.02.2021		6	32	7.14	2	1720	1.58	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		08.03.2021	601 dt. 24.03.2021		10	56	7.16	51	1480	0.33	Complying	Complying
		12.04.2021	914 dt. 27.04.2021		11	64	7.02	13	500	0.78	Complying	Complying
		10.05.2021	1096 dt. 24.05.2021		9.5	48	7.55	7	400	0.22	Complying	Complying
		17.06.2021	1380 dt. 28.06.2021		5.6	28	8.02	13	800	0.23	Complying	Complying
	07.09.2021	13.07.2021	1625 dt. 22.07.2021		11	64	7.2	13	500	0.78	Non-Complying	Non-Complying
	30.09.2021	18.08.2021	2138 dt. 03.09.2021		8	48	7.39	19	17200	1.99	Complying	Complying
	25.10.2021	08.09.2021	2298 dt. 24.09.2021		10	64	7.36	16	Absent	2.16	Complying	Complying
	25.11.2021	18.10.2021	2785 dt. 29.10.2021		7.8	48	7.2	15	500	1.32	Complying	Complying
	09.12.2021	15.11.2021	3031 dt. 26.11.2021		7.4	44	6.72	10	500	1.32	Complying	Complying
	19.01.2022	14.12.2021	3368 dt. 28.12.2021		7.8	48	7.7	20	200	1.32	Complying	Complying
	08.02.2022	21.01.2022	3851 dt. 01.02.2022		10	68	7.52	28	600	1.24	Complying	Complying
	06.04.2022	08.02.2022	4049 dt. 15.02.2022		13	76	7.88	38	800	1.92	Non-Complying	Non-Complying
	15.04.2022	09.03.2022	4514 dt. 22.03.2022		7.2	40	7.62	11	200	0.92	Complying	Complying
	17.05.2022	12.04.2022	4992 dt. 28.04.2022		8	40	7.09	16	90	1.41	Complying	Complying
	28.06.2022	19.05.2022	5503 dt. 01.06.2022		12	56	7.11	28	400	1.28	Non-Complying	Non-Complying
	14.07.2022	20.06.2022	5915 dt. 30.06.2022		7	36	2.87	13	absent	1.82	Complying	Complying
	05.08.2022	25.07.2022	6309 dt. 03.08.2022		13	60	6.48	31	400	2.57	Non-Complying	Non-Complying
	05.09.2022	17.08.2022	6548 dt. 25.08.2022		14	92	2.42	31	200	2.32	Non-Complying	Non-Complying
	10.10.2022	13.09.2022	6820 dt. 21.09.2022		15	80	8.38	26	200	2.24	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	25.10.2022	11.10.2022	7131 dt. 20.10.2022		9	56	7.25	18	400	1.47	Non-Complying	Non-Complying
	02.12.2022	11.11.2022	7445 dt. 23.11.2022		7	28.8	7.5	12	70	0.92	Complying	Complying
	04.01.2023	09.12.2022	7843 dt. 21.12.2022		16	72	2.74	28	200	2.24	Non-Complying	Non-Complying
	27.01.2023	13.01.2023	97 dt. 23.01.2023		14	64	5.26	29	400	1.38	Non-Complying	Non-Complying
	03.03.2023	20.02.2023	573 dt. 01.03.2023		7.8	48	7.73	16	200	2.14	Complying	Complying
	28.03.2023	13.03.2023	871dt. 24.03.2023		15	68	7.52	27	200	2.64	Non-Complying	Non-Complying
	28.04.2023	19.04.2023	1254 dt. 28.04.2023		7.5	36	6.33	14	70	ND	Complying	Complying
	06.06.2023	15.05.2023	1544 dt. 24.05.2023		15	76	6.35	33	400	ND	Non-Complying	Non-Complying
	22.06.2023	08.06.2023	1777 dt. 15.06.2023		7.2	40	6.29	14	90	ND	Complying	Complying
	08.08.2023	20.07.2023	2296 dt. 28.07.2023		7.6	44	6.89	16	80	ND	Complying	Complying
	29.08.2023	17.08.2023	2516 dt. 25.08.2023		6.8	36	7.01	11	80	ND	Complying	Complying
	29.08.2023	17.08.2023	2517 dt. 25.08.2023		7	32	7	14	90	ND	Complying	Complying
	29.09.2023	12.09.2023	2822 dt. 29.09.2023		6.8	36	7.09	12	70	ND	Complying	Complying
	03.11.2023	09.10.2023	3172 dt. 28.10.2023		7.4	44	7.18	15	90	ND	Complying	Complying
	18.01.2024	13.12.2023	3855 dt. 22.12.2023		4	24	5.7	10	Absent	ND	Complying	Complying
		15.01.2024	4259 dt. 22.01.2024		4.6	28	7.67	11	50	ND	Complying	Complying
		10.04.2024	54 dt. 19.04.2024		6	40	6.12	11	60	ND	Complying	Complying
		3.05.2024	189 dt. 09.05.2024		4.6	28	7.01	124	40	ND	Complying	Complying
		12.07.2024	635 dt. 24.07.2024		6.8	32	5.98	11		ND	Complying	Complying
		22.08.2024	914 dt. 29.08.2024		5.8	32	7.36	13		ND	Complying	Complying
		11.09.2024	1074 dt. 19.09.2024		7.4	36	7.65	14		ND	Complying	Complying
		18.10.2024	1296 dt. 29.10.2024		6.2	32	7.45	11		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		07.11.2024	1401 dt. 13.11.2024		6.8	40	7.08	12		ND	Complying	Complying
20	(PKL-STP-002) 39 MLD STP Panchkula by HUDA in Nov. 2011	14.01.2021	114 dt. 22.01.2021		7.2	32	7.66	6	110	1.47	Complying	Complying
		12.02.2021	381 dt. 22.02.2021		7	40	7.62	11	Absent	1.31	Complying	Complying
		08.03.2021	602 dt. 24.03.2021		7	48	7.4	11	Absent	0.37	Complying	Complying
		12.04.2021	915 dt. 27.04.2021		6.2	36	7.69	11	200	0.53	Complying	Complying
		11.05.2021	1098 dt. 24.05.2021		6.5	40	6.95	8	1700	0.14	Complying	Complying
	07.09.2021	13.07.2021	1624 dt. 22.07.2021		6.2	36	7.1	11	200	0.53	Complying	Complying
	30.09.2021	18.08.2021	2137 dt. 03.09.2021		9	52	7.71	21	14100	1.88	Complying	Complying
	25.10.2021	08.09.2021	2299 dt. 24.09.2021		9	56	7.33	9	Absent	1.85	Complying	Complying
	25.11.2021	18.10.2021	2786 dt. 29.10.2021		7.2	44	8.42	12	Absent	2.83	Complying	Complying
	09.12.2021	15.11.2021	3030 dt. 26.11.2021		7	40	7.15	9	50	N.D.	Complying	Complying
	19.01.2022	14.12.2021	3367 dt. 28.12.2021		7.2	32	7.57	16	40	1.41	Complying	Complying
	08.02.2022	21.01.2022	3852 dt. 01.02.2022		6.2	28	7.57	9	80	N.D.	Complying	Complying
	06.04.2022	08.02.2022	4047 dt. 15.02.2022		14	72	7.36	33	20	2.17	Non-Complying	Non-Complying
	15.04.2022	09.03.2022	4515 dt. 22.03.2022		3.2	16	7.57	9	80	N.D.	Complying	Complying
	17.05.2022	12.04.2022	4993 dt. 28.04.2022		7.6	40	7.07	11	70	1.06	Complying	Complying
	10.06.2022	19.05.2022	5502 dt. 01.06.2022		7	32	7.9	12	70	1.04	Complying	Complying
	14.07.2022	20.06.2022	5914 dt. 30.06.2022		8	44	7.28	14	90	1.24	Complying	Complying
	05.08.2022	25.07.2022	6310 dt. 03.08.2022		7	44	7.04	17	80	1.17	Complying	Complying
	05.09.2022	17.08.2022	6549 dt. 25.08.2022		7.2	36	7.07	17	50	1.08	Complying	Complying
	10.10.2022	13.09.2022	6819 dt. 21.09.2022		7.6	40	7.29	10	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
21	(PKL-STP-003) 15 MLD STP Sector- 28, Panchkula by HUDA in 2012	14.01.2021	113 dt. 22.01.2021		6.4	22	7.63	8	790	0.92	Complying	Complying
		12.02.2021	382 dt. 22.02.2021		3.6	20	7.22	9	210	1.99	Complying	Complying
		02.03.2021	484 dt. 12.03.2021		7	44	7.66	9	40	0.54	Complying	Complying
		15.04.2021	937 dt. 27.04.2021		6.8	32	7.51	10	1100	1.24	Complying	Complying
		11.05.2021	1097 dt. 24.05.2021		6.8	44	7.62	13	400	0.22	Complying	Complying
		17.06.2021	1386 dt. 28.06.2021		7.2	32	8.01	9	900	1.12	Complying	Complying
	07.09.2021	13.07.2021	1623 dt. 22.07.2021		6.8	32	7.6	10	1100	1.24	Complying	Complying
	30.09.2021	18.08.2021	2139 dt. 03.09.2021		25	88	7.62	31	13000	1.61	Non-Complying	Non-Complying
	25.10.2021	09.09.2021	2361 dt. 27.09.2021		6	32	7.49	10	3400	0.92	Complying	Complying
	25.11.2021	18.10.2021	2788 dt. 29.10.2021		4.6	20	8.42	12	300	1.04	Complying	Complying
	09.12.2021	15.11.2021	3044 dt. 29.11.2021		7.6	48	7.7	15	600	N.D.	Complying	Complying
	19.01.2022	13.12.2021	3370 dt. 28.12.2021		8	48	7.1	19	600	1.04	Complying	Complying
	10.02.2022	19.01.2022	3835 dt. 31.01.2022		7	48	7.55	11	400	1.18	Complying	Complying
	06.04.2022	09.02.2022	4132 dt. 18.02.2022		7.2	44	7.28	189	400	N.D.	Complying	Complying
	15.04.2022	09.03.2022	4516 dt. 22.03.2022		5.2	28	7.85	13	200	0.12	Complying	Complying
	18.05.2022	18.04.2022	5111 dt. 06.05.2022		8.5	48	7.3	28	200	0.98	Complying	Complying
	20.06.2022	24.05.2022	5518 dt. 06.06.2022		6.5	32	6.96	15	200	0.51	Complying	Complying
	14.07.2022	20.06.2022	5912 dt. 30.06.2022		7.6	40	7.49	12	90	1.18	Complying	Complying
	05.08.2022	25.07.2022	6311 dt. 03.08.2022		7.2	40	7.11	15	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	13.10.2022	13.09.2022	6972 dt. 10.10.2022		7.2	32	7.18	15	90	0.98	Complying	Complying
	09.11.2022	13.10.2022	7227 dt. 21.10.2022		7.6	44	7.01	17	90	0.92	Complying	Complying
	02.12.2022	10.11.2022	7446 dt. 23.11.2022		6.6	28.8	6.79	11	80	ND	Complying	Complying
	13.01.2023	26.12.2022	8026 dt. 09.01.2023		7.2	28	7.4	11	70	ND	Complying	Complying
	10.03.2023	23.02.2023	605 dt. 03.03.2023		7.5	44	7.8	14	90	ND	Complying	Complying
	11.04.2023	21.03.2023	893 dt. 29.03.2023		14	64	7.36	28	200	1.24	Non-Complying	Non-Complying
	09.05.2023	25.04.2023	1334 dt. 08.05.2023		7.5	44	7.52	13	90	ND	Complying	Complying
	17.08.2023	31.07.2023	2397 dt. 09.08.2023		7.2	40	7.28	15	80	ND	Complying	Complying
	06.09.2023	18.08.2023	2549 dt. 28.08.2023		6.8	28	7.2	11	80	ND	Complying	Complying
	29.09.2023	12.09.2023	2820 dt. 29.09.2023		7.2	40	7.18	14	90	ND	Complying	Complying
	03.11.2023	16.10.2023	3232 dt. 28.10.2023		7.8	36	7.3	15	90	ND	Complying	Complying
	07.12.2023	17.11.2023	3578 dt. 29.11.2023		4.8	20	7.12	9	70	ND	Complying	Complying
	05.01.2024	18.12.2023	3996 dt. 29.12.2023		7	40	7	14	80	ND	Complying	Complying
		29.01.2024	4413 dt. 06.02.2024		8.4	48	7.61	13	70	ND	Complying	Complying
		10.04.2024	56 dt. 19.04.2024		7	36	7.27	13	70	ND	Complying	Complying
		3.05.2024	188 dt. 09.05.2024		6	36	7.58	12	50	ND	Complying	Complying
		23.07.2024	711 dt. 30.07.2024		7.2	48	7.32	12		ND	Complying	Complying
		27.08.2024	938 dt. 04.09.2024		6.2	32	6.74	13		ND	Complying	Complying
		20.09.2024	1122 dt. 01.10.2024		6.8	40	7.22	13		ND	Complying	Complying
		18.10.2024	1297 dt. 29.10.2024		6.5	40	7.84	13		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		07.11.2024	1397 dt. 13.11.2024		6	32	7.03	12		ND	Complying	Complying
22	(PKL-STP-004) 4.5 MLD Kalka Panchkula by PHED in 30.3.2015	08.01.2021	85 dt. 21.01.2021		20	104	7.32	43	1100	0.38	Complying	complying
		11.02.2021	375 dt. 22.02.2021		8.5	36	7.46	16	400	1.43	Complying	Complying
		08.03.2021	603 dt. 24.03.2021		5.8	28	7.25	31	340	0.33	Complying	Complying
		12.04.2021	919 dt. 27.04.2021		6.2	36	8.03	8	200	0.38	Complying	Complying
		10.05.2021	1093 dt. 24.05.2021		10	52	7.5	17	800	0.23	Complying	Complying
		16.06.2021	1376 dt. 28.06.2021		7	32	8.09	11	1400	0.68	Complying	Complying
	07.09.2021	14.07.2021	1654 dt. 26.07.2021		6.2	36	7.36	8	200	0.38	Complying	Complying
	30.09.2021	17.08.2021	2115 dt. 02.09.2021		7.6	36	7.48	12	7000	2.11	Complying	Complying
	25.10.2021	09.09.2021	2363 dt. 28.09.2021		4	28	7.35	16	7900	0.36	Complying	Complying
	25.11.2021	18.10.2021	2787 dt. 29.10.2021		5.6	28	7.58	14	200	0.77	Complying	Complying
	09.12.2021	12.11.2021	3017 dt. 26.11.2021		26	140	7.8	14	500	2.17	Non-Complying	Non-Complying
	19.01.2022	09.12.2021	3277 dt. 20.12.2021		23	282	10.57	180	Absent	1.67	Non-Complying	Non-Complying
	10.02.2022	19.01.2022	3830 dt. 31.01.2022		8.5	68	7.38	14	400	2.12	Complying	Complying
	06.04.2022	09.02.2022	4134 dt. 18.02.2022		12	60	7.6	24	70	1.95	Non-Complying	Non-Complying
	15.04.2022	08.03.2022	4442 dt. 21.03.2022		20	100	7.81	35	600	1.67	Non-Complying	Non-Complying
	04.05.2022	08.04.2022	4964 dt. 22.04.2022		16	84	7.55	38	400	1.43	Non-Complying	Non-Complying
	07.06.2022	13.05.2022	5431 dt. 25.05.2022		15	72	7.62	29	200	2.3	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	14.07.2022	13.06.2022	5852 dt. 24.06.2022		15	84	7.61	27	400	2.83	Non-Complying	Non-Complying
	05.08.2022	14.07.2022	6235 dt. 21.07.2022		28	112	7.6	56	500	1.67	Non-Complying	Non-Complying
	02.09.2022	16.08.2022	6530 dt. 25.08.2022		15	76	7.79	35	500	2.75	Non-Complying	Non-Complying
	10.10.2022	13.09.2022	6824 dt. 21.09.2022		16	72	8.93	38	500	2.18	Non-Complying	Non-Complying
	25.10.2022	10.10.2022	7128 dt. 20.10.2022		7.5	48	8.23	18	200	1.19	Complying	Complying
	02.12.2022	15.11.2022	7453 dt. 28.11.2022		48	172	11.49	122	800	5.84	Non-Complying	Non-Complying
	05.01.2023	16.12.2022	7931 dt. 26.12.2022		21	96	9.87	29	400	1.44	Non-Complying	Non-Complying
	18.01.2023	04.01.2023	25 dt. 13.01.2023		260	912	6.99	468	1100	11.72	Non-Complying	Non-Complying
	02.03.2023	17.02.2023	536 dt. 27.02.2023		14	72	7.48	28	500	2.85	Non-Complying	Non-Complying
	11.04.2023	21.03.2023	883 dt. 29.03.2023		17	76	7.36	35	500	2.63	Non-Complying	Non-Complying
	28.04.2023	18.04.2023	1248 dt. 27.04.2023		21	88	7.4	57	500	2.76	Non-Complying	Non-Complying
	06.06.2023	16.05.2023	1558 dt. 26.05.2023		21	96	7.6	52	500	2.53	Non-Complying	Non-Complying
	08.08.2023	20.07.2023	2293 dt. 28.07.2023		20	96	6.85	32	400	2.84	Non-Complying	Non-Complying
	29.08.2023	14.08.2023	2506 dt. 22.08.2023		15	76	7.01	32	500	2.06	Non-Complying	Non-Complying
	29.09.2023	12.09.2023	2824 dt. 29.09.2023		68	260	7.65	110	400	5.64	Non-Complying	Non-Complying
	03.11.2023	12.10.2023	3192 dt. 28.10.2023		48	176	7.2	110	400	4.76	Non-Complying	Non-Complying
	23.11.2023	15.11.2023	3481 dt. 22.11.2023		46	180	7.18	129	700	7.56	Non-Complying	Non-Complying
	05.01.2024	19.12.2023	3997 dt. 29.12.2023		7.8	44	6.99	13	70	ND	Complying	Complying
		24.01.2024	4282 dt. 30.01.2024		5.8	32	7.27	12	60	ND	Complying	Complying
		23.04.2024	109 dt. 30.04.2024		7	44	7.37	12	80	ND	Complying	Complying
		7.05.2024	230 dt. 15.05.2024		6	36	7.66	10	70	ND	Complying	Complying
		10.07.2024	598 dt. 22.07.2024		8	44	7.02	15		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		12.08.2024	850 dt. 21.08.2024		7.6	44	7.25	17		ND	Complying	Complying
		16.09.2024	1113 dt. 30.09.2024		7.5	40	6.69	13		ND	Complying	Complying
		15.10.2024	1275 dt. 24.10.2024		7.2	44	7.45	12		ND	Complying	Complying
		21.11.2024	1479 dt. 27.11.2024		7.2	48	7.27	12		ND	Complying	Complying
23	(PKL-STP-005) 0.25 MLD Kalka Panchkula by PHED in 28.5. 2017	08.01.2021	84 dt. 21.01.2021		6.8	26	7.51	8	900	0.44	Complying	Complying
		11.02.2021	374 dt. 22.02.2021		2.2	36	7.46	5	20	4.13	Complying	Complying
		08.03.2021	600 dt. 24.03.2021		9	56	7.14	26	370	0.38	Complying	Complying
		12.04.2021	918 dt. 27.04.2021		4.4	28	7.94	12	1700	0.98	Complying	Complying
		10.05.2021	1094 dt. 24.05.2021		7.4	40	7.36	18	1100	0.36	Complying	Complying
		16.06.2021	1378 dt. 28.06.2021		6.8	32	8.44	17	1700	0.64	Complying	Complying
	07.09.2021	14.07.2021	1655 dt. 26.07.2021		4.4	28	7.76	12	110	0.98	Complying	Complying
	24.09.2021	17.08.2021	2114 dt. 2.09.2021		5.6	20	7.84	22	4900	2.17	Complying	Complying
	25.10.2021	09.09.2021	2362 dt. 28.09.2021		6	28	8.27	8	4900	2.12	Complying	Complying
	25.11.2021	05.10.2021	2591 dt. 19.10.2021		6.2	24	8.07	11	600	1.06	Complying	Complying
	09.12.2021	12.11.2021	3016 dt. 26.11.2021		5.8	28	7.65	9	600	1.97	Complying	Complying
	19.01.2022	09.12.2021	3278 dt. 20.12.2021		7.8	48	7.2	16	400	1.47	Complying	Complying
	09.02.2022	19.01.2022	3833 dt. 31.01.2022		6.5	28	8.62	11	600	N.D.	Complying	Complying
	06.04.2022	09.02.2022	4133 dt. 18.02.2022		6.4	28	7.84	11	300	N.D.	Complying	Complying
	15.04.2022	08.03.2022	4443 dt. 21.03.2022		7.6	48	8.19	9	200	1.84	Complying	Complying
	04.05.2022	08.04.2022	4961 dt. 22.04.2022		9.2	60	7.82	17	400	2.04	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	07.06.2022	13.05.2022	5432 dt. 25.05.2022		15	76	8.79	33	400	2.17	Non-Complying	Non-Complying
	14.07.2022	13.06.2022	5853 dt. 24.06.2022		14	80	7.65	28	500	2.37	Non-Complying	Non-Complying
	05.08.2022	14.07.2022	6238 dt. 21.07.2022		25	104	9.17	48	400	2.36	Non-Complying	Non-Complying
	02.09.2022	16.08.2022	6528 dt. 25.08.2022		15	96	8.18	32	400	2.23	Non-Complying	Non-Complying
	10.10.2022	13.09.2022	6823 dt. 21.09.2022		15	68	9.68	35	400	2.46	Non-Complying	Non-Complying
	25.10.2022	10.10.2022	7129 dt. 20.10.2022		7	44	7.28	14	400	1.12	Complying	Complying
	02.12.2022	15.11.2022	7455 dt. 28.11.2022		19	88	9.73	31	200	2.76	Non-Complying	Non-Complying
	05.01.2023	16.12.2022	7930 dt. 26.12.2022		26	128	10.48	56	500	1.25	Non-Complying	Non-Complying
	18.01.2023	04.01.2023	24 dt. 13.01.2023		15	76	8.53	31	400	2.17	Non-Complying	Non-Complying
	02.03.2023	17.02.2023	535 dt. 27.02.2023		52	188	9.69	96	700	8.85	Non-Complying	Non-Complying
	31.04.2023	17.03.2023	885 dt. 28.03.2023		17	88	8.72	42	400	2.66	Non-Complying	Non-Complying
	28.04.2023	18.04.2023	1249 dt. 27.04.2023		20	92	7.54	52	400	1.87	Non-Complying	Non-Complying
	06.06.2023	16.05.2023	1559 dt. 26.05.2023		18	88	8.9	37	400	1.56	Non-Complying	Non-Complying
	13.07.2023	23.06.2023	2005 dt. 03.07.2023		15	64	7.45	35	200	2.46	Non-Complying	Non-Complying
	08.08.2023	20.07.2023	2297 dt. 28.07.2023		82	292	7.17	135	800	8.78	Non-Complying	Non-Complying
	29.08.2023	14.08.2023	2505 dt. 22.08.2023		52	184	10.76	126	700	6.18	Non-Complying	Non-Complying
	29.09.2023	12.09.2023	2825 dt. 29.09.2023		70	272	9.24	120	600	9.26	Non-Complying	Non-Complying
	03.11.2023	12.10.2023	3191 dt. 28.10.2023		52	184	8.8	109	500	3.48	Non-Complying	Non-Complying
	23.11.2023	15.11.2023	3480 dt. 22.11.2023		36	132	7.49	103	900	8.23	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	05.01.2024	19.12.2023	3999 dt. 29.12.2023		40	184	9.78	87	600	2.89	Non-Complying	Non-Complying
		24.01.2024	4280 dt. 30.01.2024		14	92	7.8	35	200	2.16	Non-Complying	Non-Complying
		23.04.2024	111 dt. 30.04.2024		17	96	7.54	31	800	1.38	Non-Complying	Non-Complying
		17.05.2024	229 dt. 15.05.2024		7	48	7.7	10	80	ND	Complying	Complying
		11.07.2024	599 dt. 22.07.2024		5.2	60	5.52	37		ND	Complying	Complying
		20.08.2024	905 dt. 28.08.2024		8.4	48	7.16	17		ND	Complying	Complying
		25.09.2024	1130 dt. 07.10.2024		13	64	7.87	56		2.46	Complying	Complying
		15.10.2024	1274 dt. 24.10.2024		7	48	7.47	13		0.23	Complying	Complying
		21.11.2024	1477 dt. 27.11.2024		7.5	36	7.33	13		ND	Complying	Complying
	Pinjore											
24	(PKL-STP-006) 5 MLD STP Nalagarh Road, Manakpur, Pinjore Panchkula by PHED 31.1.2015	08.01.2021	82 dt. 21.01.2021		7	44	7.43	16	1700	0.94	Complying	Complying
		11.02.2021	376 dt. 22.02.2021		6	52	7.3	6	Absent	0.28	Complying	Complying
		08.03.2021	604 dt. 24.03.2021		4.2	24	7.43	7	Absent	0.51	Complying	Complying
		12.04.2021	917 dt. 27.04.2021		8.5	44	7.23	7	130	0.97	Complying	Complying
		10.05.2021	1095 dt. 24.05.2021		2.4	28	6.65	6	Absent	0.51	Complying	Complying
		16.06.2021	1377 dt. 28.06.2021		5.8	28	7.32	8	1100	0.12	Complying	Complying
	07.09.2021	14.07.2021	1653 dt. 30.07.2021		8.5	44	7.75	7	130	0.97	Complying	Complying
	30.09.2021	17.08.2021	2116 dt. 02.09.2021		6.2	24	7.28	15	13000	2.3	Complying	Complying
	25.10.2021	09.09.2021	2364 dt. 28.09.2021		8	44	7.13	10	Absent	0.76	Complying	Complying
	25.11.2021	05.10.2021	2592 dt. 19.10.2021		7.6	40	7.71	15	BDL	1.24	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	09.12.2021	12.11.2021	3015 dt. 26.11.2021		7.6	48	7.2	10	200	2.26	Complying	Complying
	19.01.2022	09.12.2021	3279 dt. 20.12.2021		7.2	44	7.41	14	600	2.36	Complying	Complying
	09.02.2022	19.01.2022	3831 dt. 31.01.2022		3.5	28	7.06	12	Absent	N.D.	Complying	Complying
	06.04.2022	09.02.2022	4135 dt. 18.02.2022		8	48	7.57	16	500	1.04	Complying	Complying
	15.04.2022	08.03.2022	4445 dt. 21.03.2022		6.8	44	7.65	15	80	1.84	Complying	Complying
	04.05.2022	08.04.2022	4963 dt. 27.04.2022		7.8	40	7.19	14	70	1.31	Complying	Complying
	08.06.2022	13.05.2022	5430 dt. 24.05.2022		7.2	40	7.1	11	90	1.17	Complying	Complying
	14.07.2022	13.06.2022	5854 dt. 24.06.2022		13	60	7.14	25	200	1.38	Non-Complying	Non-Complying
	05.08.2022	14.07.2022	6237 dt. 21.07.2022		7.8	36	7.58	13	50	0.12	Complying	Complying
	02.09.2022	16.08.2022	6529 dt. 25.08.2022		8	36	7.38	14	80	1.17	Complying	Complying
	06.10.2022	13.09.2022	6822 dt. 21.09.2022		7.5	36	7.34	12	50	1.02	Complying	Complying
	25.10.2022	10.10.2022	7130 dt. 20.10.2022		7.8	32	7.09	15	70	1.37	Complying	Complying
	02.12.2022	15.11.2022	7454 dt. 28.11.2022		7.8	40	7.39	13	90	ND	Complying	Complying
	05.01.2023	16.12.2022	7929 dt. 26.12.2022		4.5	20	6.97	11	80	1.35	Complying	Complying
	24.01.2023	12.01.2023	78 dt. 23.01.2023		4.5	16	8.1	8	50	ND	Complying	Complying
	02.03.2023	17.02.2023	534 dt. 27.02.2023		7.8	48	7.98	15	70	ND	Complying	Complying
	31.04.2023	17.03.2023	884 dt. 28.03.2023		7.5	36	7.74	13	400	ND	Complying	Complying
	28.04.2023	18.04.2023	1250 dt. 27.04.2023		6.8	24	7.52	10	70	ND	Complying	Complying
	06.06.2023	15.05.2023	1543 dt. 24.05.2023		7.2	48	8.05	14	90	ND	Complying	Complying
	03.07.2023	13.06.2023	1867 dt. 20.06.2023		6.2	36	7.62	14	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	08.08.2023	20.07.2023	2294 dt. 28.07.2023		8	48	6.84	16	80	ND	Complying	Complying
	29.08.2023	14.08.2023	2504 dt. 22.08.2023		7.8	40	6.79	13	90	ND	Complying	Complying
	17.10.2023	27.09.2023	2993 dt. 13.10.2023		7.8	36	6.97	13	60	ND	Complying	Complying
	03.11.2023	12.10.2023	3193 dt. 28.10.2023		7.8	44	7.2	13	80	ND	Complying	Complying
	05.01.2024	19.12.2023	3998 dt. 29.12.2023		6.4	36	6.96	10	60	ND	Complying	Complying
		24.01.2024	4281 dt. 30.01.2024		8	48	7.2	10	70	ND	Complying	Complying
		23.04.2024	110 dt. 30.04.2024		5.6	32	7.42	10	60	ND	Complying	Complying
		17.05.2024	231 dt. 15.05.2024		7	44	7.56	192	80	ND	Complying	Complying
		10.07.2024	597 dt. 22.07.2024		7.2	36	7.01	12		ND	Complying	Complying
		12.08.2024	851 dt. 21.08.2024		7	40	7.74	12		0.37	Complying	Complying
		16.09.2024	1112 dt. 30.09.2024		7.6	44	6.36	13		ND	Complying	Complying
		15.10.2024	1276 dt. 24.10.2024		7.6	40	7.76	15		ND	Complying	Complying
		21.11.2024	1478 dt. 27.11.2024		7.6	44	7.23	15		ND	Complying	Complying
25	(PKL-STP-007) 9 MLD STP Garrison Engineer , Chandimandir Panchkula in April 2012	08.01.2021	81 dt. 21.01.2021		5.4	22	7.65	6	1400	0.23	Complying	Complying
		11.02.2021	373 dt. 22.02.2021		2.6	28	7.45	6	110	2.5	Complying	Complying
		08.03.2021	599 dt. 24.03.2021		4.2	28	7.21	9	370	0.59	Complying	Complying
		12.04.2021	916 dt. 27.04.2021		2.8	12	7.23	6	Absent	0.46	Complying	Complying
		10.05.2021	1092 dt. 24.05.2021		9	48	7.25	21	900	0.2	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		16.06.2021	1375 dt. 28.06.2021		5.6	24	7.54	9	1100	1.32	Complying	Complying
	07.09.2021	13.07.2021	1626 dt. 22.07.2021		4.2	28	6.4	9	370	0.59	Complying	Complying
	24.09.2021	11.08.2021	2025 dt. 24.08.2021		7	28	7.73	14	4300	N.D.	Complying	Complying
	25.10.2021	08.09.2021	2297 dt. 24.09.2021		6.8	36	7.46	6	Absent	1.87	Complying	Complying
	25.11.2021	05.10.2021	2589 dt. 19.10.2021		3.4	16	8.12	8	BDL	N.D.	Complying	Complying
	09.12.2021	12.11.2021	3014 dt. 26.11.2021		6.2	36	7.85	13	600	2.76	Complying	Complying
	19.01.2022	14.12.2021	3366 dt. 28.12.2021		5.8	28	7.12	17	50	0.77	Complying	Complying
	09.02.2022	19.01.2022	3832 dt. 31.01.2022		6.5	28	7.68	8	200	N.D.	Complying	Complying
	06.04.2022	09.02.2022	4136 dt. 18.02.2022		6.5	20	7.88	12	80	1.02	Complying	Complying
	15.04.2022	08.03.2022	4444 dt. 21.03.2022		9	64	7.55	14	80	1.95	Complying	Complying
	04.05.2022	08.04.2022	4962 dt. 27.04.2022		13	60	7.37	28	60	1.29	Non-Complying	Non-Complying
	10.06.2022	19.05.2022	5501 dt. 01.06.2022		6.2	24	7.87	10	50	ND	Complying	Complying
	14.07.2022	20.06.2022	5913 dt. 30.06.2022		6.8	32	8.02	10	80	0.87	Complying	Complying
	05.08.2022	14.07.2022	6236 dt. 21.07.2022		7.2	44	7.58	15	80	2.12	Complying	Complying
	02.09.2022	16.08.2022	6527 dt. 25.08.2022		6.2	24	7.81	13	50	ND	Complying	Complying
	10.10.2022	13.09.2022	6821 dt. 21.09.2022		6.8	32	7.28	9	Absent	ND	Complying	Complying
	16.11.2022	27.10.2022	7301 dt. 07.11.2022		5.2	24	7.25	9	70	ND	Complying	Complying
	02.12.2022	21.11.2022	7519 dt. 01.12.2022		7	28	7.04	12	80	ND	Complying	Complying
	13.01.2023	22.12.2022	7983 dt. 03.01.2023		4.5	20	7.23	8	80	ND	Complying	Complying
	31.01.2023	17.01.2023	179 dt. 25.01.2023		5.4	20	7.72	9	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	03.03.2023	21.02.2023	576 dt. 01.03.2023		7	40	7.32	13	80	ND	Complying	Complying
	11.04.2023	21.03.2023	894 dt. 29.03.2023		6.2	24	7.16	9	90	ND	Complying	Complying
	28.04.2023	19.04.2023	1253 dt. 28.04.2023		7.4	36	7.27	13	70	ND	Complying	Complying
	06.06.2023	16.05.2023	1560 dt. 26.05.2023		7.8	40	7.1	13	90	ND	Complying	Complying
	13.07.2023	27.06.2023	2007 dt. 04.07.2023		7	36	6.93	16	80	ND	Complying	Complying
	08.08.2023	20.07.2023	2295 dt. 28.07.2023		7.5	36	6.55	15	90	ND	Complying	Complying
	29.08.2023	14.08.2023	2507 dt. 22.08.2023		7.6	48	7.29	14	80	ND	Complying	Complying
	17.10.2023	27.09.2023	2994 dt. 13.10.2023		8.2	40	7	13	80	ND	Complying	Complying
	10.11.2023	20.10.2023	3296 dt. 31.10.2023		7.2	40	6.99	17	70	ND	Complying	Complying
	11.12.2023	21.11.2023	3618 dt. 30.11.2023		5.4	28	6.97	10	50	ND	Complying	Complying
	05.01.2024	18.12.2023	3995 dt. 29.12.2023		9.2	48	7.18	13	90	ND	Complying	Complying
		25.01.2024	4347 dt. 01.02.2024		6.8	40	7.35	12	70	ND	Complying	Complying
		23.04.2024	108 dt. 30.04.2024		5	32	7.42	10	50	ND	Complying	Complying
		17.05.2024	274 dt. 23.05.2024		5.4	32	7	13	60	ND	Complying	Complying
		23.07.2024	712 dt. 30.07.2024		6.2	44	7.19	15		ND	Complying	Complying
		20.08.2024	904 dt. 28.08.2024		7.5	44	6.87	15		ND	Complying	Complying
		25.09.2024	1129 dt. 07.10.2024		7.6	40	7.52	13		ND	Complying	Complying
		22.10.2024	1314 dt. 29.10.2024		7	40	7.59	13		ND	Complying	Complying
		27.11.2024	1517 dt. 10.12.2024		6.2	40	7.2	11		ND	Complying	Complying
26	(PKL-STP-008) 0.75 MLD STP, Khatoli, Panchkula by ULBD in 31.10.2021	16.12.2023 (Upload on 05.01.2024)	3990 dt. 29.12.2023		6.4	36	7.4	13	70	ND	Complying	Complying
		03.01.2024	4150 dt. 15.01.2024		5.8	32	7.86	10	60	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		22.04.2024	98 dt.29.04.2024		9	48	7.64	14	90	ND	Complying	Complying
		06.05.2024	200 dt. 13.05.2024		7	48	7.81	13	60	ND	Complying	Complying
		11.07.2024	613 dt. 23.07.2024		7.6	48	6.88	14		ND	Complying	Complying
		06.08.2024	800 dt. 14.08.2024		6.8	36	7.76	14		ND	Complying	Complying
		20.09.2024	1124 dt. 01.10.2024		6.5	36	7.44	13		ND	Complying	Complying
		11.10.2024	1231 dt. 21.10.2024		7.6	40	7.59	17		ND	Complying	Complying
		19.11.2024	1470 dt. 26.11.2024		5.2	28	7.28	11		ND	Complying	Complying
27	(PKL-STP-009) 0.75 MLD STP, Billa, Panchkula by ULBD in 31.10.2021	09.01.2024	4217 dt. 18.01.2024		7.2	40	7.9	12	80	ND	Complying	Complying
		22.04.2024	99 dt.29.04.2024		5.8	36	7.63	10	50	ND	Complying	Complying
		06.05.2024	196 dt. 13.05.2024		4.8	28	7.41	12	40	ND	Complying	Complying
		12.07.2024	616 dt. 24.07.2024		6.4	32	6.9	12		ND	Complying	Complying
		06.08.2024	802 dt. 14.08.2024		7.2	40	7.2	12		ND	Complying	Complying
		12.09.2024	1104 dt. 20.09.2024		7.6	44	7.63	13		ND	Complying	Complying
		14.10.2024	1261 dt. 23.10.2024		6.8	36	7.74	9		ND	Complying	Complying
		19.11.2024	1472 dt. 26.11.2024		7.8	44	7.18	12		ND	Complying	Complying
28	(PKL-STP-010) 0.75 MLD STP, Sukhdarshanpur, Panchkula by ULBD in 30.09.2021	03.01.2024	4149 dt. 15.01.2024		7.6	40	7.6	13	80	ND	Complying	Complying
		22.04.2024	95 dt.29.04.2024		6	32	7.56	10	60	ND	Complying	Complying
		06.05.2024	195 dt. 13.05.2024		5	32	7.69	10	50	ND	Complying	Complying
		11.07.2024	614 dt. 23.07.2024		6.8	32	6.76	13		1.27	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		06.08.2024	803 dt. 14.08.2024		7	48	7.25	13		ND	Complying	Complying
		20.09.2024	1126 dt. 01.10.2024		7.4	40	7.3	13		ND	Complying	Complying
		11.10.2024	1229 dt. 21.10.2024		8	44	7.18	16		ND	Complying	Complying
		19.11.2024	1473 dt. 26.11.2024		5.6	28	7.49	13		ND	Complying	Complying
29	(PKL-STP-011) 0.5 MLD STP, Nangal & Alipur, Panchkula by ULBD in 31.10.2021	03.01.2024	4151 dt. 15.01.2024		5.2	28	7.05	11	50	ND	Complying	Complying
		22.04.2024	96 dt.29.04.2024		6.8	40	7.6	12	70	ND	Complying	Complying
		06.05.2024	199 dt. 13.05.2024		4	24	7.43	10	40	ND	Complying	Complying
		11.07.2024	617 dt. 23.07.2024		7.8	48	6.92	16		ND	Complying	Complying
		06.08.2024	805 dt. 14.08.2024		5.8	36	7.27	14		ND	Complying	Complying
		20.09.2024	1125 dt. 01.10.2024		7.2	48	7.47	14		ND	Complying	Complying
		11.10.2024	1230 dt. 21.10.2024		7.2	48	7.37	15		ND	Complying	Complying
		19.11.2024	1469 dt. 26.11.2024		6.2	36	7.17	15		ND	Complying	Complying
30	(PKL-STP-012) 0.75 MLD STP, Kot, Panchkula by ULBD in 31.10.2021	09.01.2024	4215 dt. 18.01.2024		6.4	36	7.95	11	60	ND	Complying	Complying
		22.04.2024	100 dt.29.04.2024		7.2	40	7.98	11	60	ND	Complying	Complying
		06.05.2024	198 dt. 13.05.2024		6	36	7.67	12	70	ND	Complying	Complying
		11.07.2024	615 dt. 23.07.2024		7	36	6.68	14		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		06.08.2024	801 dt. 14.08.2024		7.4	32	7.25	15		ND	Complying	Complying
		12.09.2024	1103 dt. 20.09.2024		7.2	44	7.05	13		ND	Complying	Complying
		14.10.2024	1260 dt. 23.10.2024		7.2	44	7.49	11		ND	Complying	Complying
		19.11.2024	1471 dt. 26.11.2024		5.8	32	7.14	11		ND	Complying	Complying
31	(PKL-STP-013) 0.5 MLD STP, Khagesara & Toka, Panchkula by ULBD in 31.10.2021	03.01.2024	4152 dt. 15.01.2024		6.8	36	7.67	12	70	ND	Complying	Complying
		22.04.2024	97 dt.29.04.2024		8	48	7.68	13	90	ND	Complying	Complying
		06.05.2024	198 dt. 13.05.2024		7.8	40	7.55	11	80	ND	Complying	Complying
		11.07.2024	618 dt. 23.07.2024		6.4	40	6.82	14		ND	Complying	Complying
		06.08.2024	804 dt. 14.08.2024		7.6	44	7.25	12		ND	Complying	Complying
		20.09.2024	1123 dt. 01.10.2024		7	44	7.62	15		ND	Complying	Complying
		19.11.2024	1474 dt. 26.11.2024		6	32	7.24	12		ND	Complying	Complying
32	(PKL-STP-014) 1.5 MLD STP, Saketri, Panchkula by ULBD in 30.06.2022	14.12.2023 (uploaded on 18.01.2024)	3896 dt. 27.12.2023		7	40	7.06	11	80	ND	Complying	Complying
		25.01.2024	4346 dt. 01.02.2024		5	28	7.6	10	50	ND	Complying	Complying
		10.04.2024	53 dt. 19.04.2024		7	40	7.18	13	50	ND	Complying	Complying
		06.05.2024	197 dt. 13.05.2024		6	36	7.67	12	70	ND	Complying	Complying
		12.07.2024	636 dt. 24.07.2024		7.2	44	6.2	13			Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		08.08.2024	827 dt. 20.08.2024		7	40	7.4	15		ND	Complying	Complying
		11.09.2024	1076 dt. 19.09.2024		6.8	48	7.68	14		ND	Complying	Complying
		15.10.2024	1278 dt. 24.10.2024		7	40	7.49	13		ND	Complying	Complying
		07.11.2024	1398 dt. 13.11.2024		7.2	40	7.26	13		ND	Complying	Complying
33	(PKL-STP-015) 1 MLD STP, Ramgarh, Panchkula by ULBD in 30.06.2022	14.12.2023 (uploaded on 18.01.2024)	3895 dt. 27.12.2023		6.4	36	7.43	12	70	ND	Complying	Complying
		09.01.2024	4216 dt. 18.01.2024		5	28	7.47	10	50	ND	Complying	Complying
		10.04.2024	55 dt. 19.04.2024		5.2	32	7.25	10	50	ND	Complying	Complying
		03.05.2024	187 dt. 09.05.2024		6	40	7.63	12	70	ND	Complying	Complying
		12.07.2024	637 dt. 24.07.2024		6.8	40	6.96	12		ND	Complying	Complying
		08.08.2024	826 dt. 20.08.2024		5.5	28	7.7	13		ND	Complying	Complying
		11.09.2024	1075 dt. 19.09.2024		6.5	48	7.4	11		ND	Complying	Complying
		15.10.2024	1277 dt. 24.10.2024		6.2	36	7.4	11		ND	Complying	Complying
		07.11.2024	1400 dt. 13.11.2024		5.8	32	7.22	10		ND	Complying	Complying
	Jind											
34	(JND-STP-001) 15 MLD STP by PHED Jind in Jan, 2009	16.02.2021	1301-1302 dt. 22.02.2021		26	128	8	46	21000		Complying	Complying
		19.04.2021	105-106 dt. 01.05.2021	2940	23	104	7.8	38	13000	8.4	Complying	Complying
		25.05.2021	247-248 dt. 01.06.2021		22	96	7.9	34	11000	8.1	Complying	Complying
		08.06.2021	324-325 dt. 15.06.2021		21	112	7.8	32	8000	8.7	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		02.07.2021	469-470 dt. 09.07.2021		22	104	7.9	34	8600	8.4	Complying	Complying
		09.08.2021	798-799 dt. 16.08.2021		26	112	8.1	36	9000	8.8	Non-Complying	Non-Complying
	25.10.2021	20.09.2021	984-985 dt. 27.09.2021	Not Work	24	96	8.2	48	6800		Non-Complying	Non-Complying
	30.11.2021	26.10.2021	1272-1273 dt. 08.11.2021	Not Work	22	80	8.1	42	4500		Non-Complying	Non-Complying
	15.12.2021	09.11.2021	1347-1348 dt. 18.11.2021	Not Work	28	112	8.3	48	5600		Non-Complying	Non-Complying
	28.12.2021	13.12.2021	1576-1577 dt. 22.12.2021		26	104	8.2	42	5200		Non-Complying	Non-Complying
	02.03.2022	18.01.2022	1828-1829 dt. 24.01.2022	Not Inst.	9.2	40	7.8	14	94		Complying	Complying
	15.04.2022	25.03.2022	4701 dt. 31.03.2022		8.5	48	7.68	18	80	5.06	Complying	Complying
	18.05.2022	28.04.2022	5193 dt. 11.05.2022		7.2	40	7.48	14	90	2.2	Complying	Complying
	23.06.2022	30.05.2022	5620 dt. 10.06.2022		8.2	48	7.29	15	90	1.97	Complying	Complying
	18.07.2022	27.06.2022	5990 dt. 08.07.2022		7.6	44	7.53	11	90	2.23	Complying	Complying
	18.08.2022	28.07.2022	6351 dt. 08.08.2022		7.6	44	7.12	15	80	0.23	Complying	Complying
	05.09.2022	23.08.2022	6578 dt. 01.09.2022		7	32	7.45	12	200	0.72	Complying	Complying
	10.10.2022	13.09.2022	6826 dt. 27.09.2022		13	68	7.54	31	400	2.73	Non-Complying	Non-Complying
	17.11.2022	28.10.2022	7320 dt. 07.11.2022		8.6	48	7.52	17	400	1.07	Complying	Complying
	14.12.2022	25.11.2022	7592 dt. 07.12.2022		15	80	7.08	25	400	1.24	Non-Complying	Non-Complying
	13.01.2023	27.12.2022	8084 dt. 10.01.2023		8.6	48	7.84	17	90	1.27	Complying	Complying
	16.02.2023	03.02.2023	332 dt. 14.02.2023		7.8	32	7.58	13	90	ND	Complying	Complying
	13.03.2023	27.02.2023	650 dt. 13.03.2023		7.5	32	7.08	10	90	ND	Complying	Complying
	11.04.2023	27.03.2023	969 dt. 07.04.2023		7.5	36	7.8	11	90	ND	Complying	Complying
	14.06.2023	25.05.2023	1691 dt. 02.06.2023		7	28	7.51	11	80	ND	Complying	Complying
	13.07.2023	29.06.2023	2045 dt. 07.07.2023		8.2	44	7.85	16	80	ND	Complying	Complying
	14.08.2023	29.07.2023	2383 dt. 08.08.2023		7.5	32	7.42	11	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	14.09.2023	29.08.2023	2708 dt. 08.09.2023		8	32	6.97	14	80	ND	Complying	Complying
	17.10.2023	27.09.2023	3000 dt. 13.10.2023		7.8	40	7.09	12	50	BDL	Complying	Complying
	10.11.2023	25.10.2023	3316 dt. 03.11.2023		8.2	48	6.89	16	90	ND	Complying	Complying
	20.12.2023	25.11.2023	3679 dt. 06.12.2023		20	96	7.4	40	200	ND	Non-Complying	Non-Complying
	18.01.2024	28.12.2023	4082 dt. 09.01.2024		5.2	28	6.96	11	60	ND	Complying	Complying
	Jan, 2024	24.01.2024	4277 dt 30.01.2024		4	24	7.08	11	50	ND	Complying	Complying
	Feb, 2024	26.02.2024	4753 dt 14.03.2024		5.2	32	7.23	10	60	ND	Complying	Complying
	Mar, 2024	21.03.2024	5097 dt 28.03.2024		4.2	24	6.9	10	40	ND	Complying	Complying
	Apr,2024	25.04.2024	138 dt 02.05.2024		4	24	7.46	10	30	ND	Complying	Complying
		18.06.2024	370 dt. 27.06.2024		7.2	40	7.85	13		0.76	Complying	Complying
		17.07.2024	666 dt. 25.07.2024		6.8	44	7.08	15		ND	Complying	Complying
		20.08.2024	899 dt. 28.08.2024		6.8	36	6.94	14		ND	Complying	Complying
		25.09.2024	1139 dt. 07.10.2024		7.5	48	6.78	13		ND	Complying	Complying
		22.10.2024	1331 dt. 04.11.2024		5.6	44	7.46	12		ND	Complying	Complying
		18.01.2025	1936 dt. 24.01.2025		6.2	48	7.08	12		ND	Complying	Complying
35	(JND-STP-002) 10 MLD by HUDA Jind in 27.12.2014	22.01.2021	1167-1168 dt. 29.01.2021		9	32	7.9	14	15000		Complying	Complying
		16.02.2021	1307-1308 dt. 22.02.2021		9	48	7.6	16	15000		Complying	Complying
		19.03.2021	1495-1496 dt. 26.03.2021		8.7	40	7.7	14	9600		Complying	Complying
		19.04.2021	107-108 dt. 01.05.2021	1670	8.2	40	7.6	10	5000	2.5	Complying	Complying
		24.05.2021	243-244 dt. 31.05.2021		7.9	32	7.5	10	2800	2.1	Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	08.06.2021	328-329 dt. 15.06.2021		8	4	7.6	12	3100	2.9	Complying	Complying
	02.07.2021	463-464 dt. 09.07.2021		8.2	32	7.6	9	2800	3.1	Complying	Complying
	09.08.2021	802-803 dt. 16.08.2021		8	32	7.5	10	2500	2.6	Complying	Complying
25.10.2021	20.09.2021	978-979 dt. 27.09.2021	Not Work	8.2	32	7.6	12	700		Complying	Complying
30.11.2021	26.10.2021	1274-1275 dt. 08.11.2021	Not Work	8	32	7.4	9	250		Complying	Complying
15.12.2021	09.11.2021	1351-1352 dt. 18.11.2021	Not Work	8.2	40	7.5	14	94		Complying	Complying
27.12.2021	02.12.2021	1505-1506 dt. 10.12.2021	Not Work	8.1	32	7.6	12	84		Complying	Complying
04.02.2022	12.01.2022	1800-1801 dt. 19.01.2022	Not work	8.4	40	7.8	14	90		Complying	Complying
05.04.2022	28.02.2022	4367 dt. 15.03.2022		22	136	7.54	72	800	8.5	Non complying	Non complying
15.04.2022	25.03.2022	4697 dt. 31.03.2022		8	44	7.84	17	Absent	2.84	Complying	Complying
18.05.2022	28.04.2022	5191 dt. 11.05.2022		17	128	7.28	88	600	2.31	Non complying	Non complying
23.06.2022	30.05.2022	5622 dt. 10.06.2022		15	76	7.3	28	600	3.42	Non complying	Non complying
18.07.2022	27.06.2022	5989 dt. 08.07.2022		8.2	48	7.35	17	80	2.3	Complying	Complying
18.08.2022	28.07.2022	6347 dt. 08.08.2022		7	44	7.39	17	90	1.62	Complying	Complying
05.09.2022	23.08.2022	6579 dt. 01.09.2022		6.5	28	7.02	11	80	1.32	Complying	Complying
10.10.2022	13.09.2022	6829 dt. 27.09.2022		8	40	7.63	15	50	1.21	Complying	Complying
17.11.2022	28.10.2022	7315 dt. 07.11.2022		7.2	28	8	14	80	0.34	Complying	Complying
14.12.2022	25.11.2022	7593 dt. 07.12.2022		7.2	32	7.58	11	70	ND	Complying	Complying
13.01.2023	27.12.2022	8082 dt. 10.01.2023		7.2	44	7.99	13	90	1.23	Complying	Complying
16.02.2023	03.02.2023	330 dt. 14.02.2023		7	28	7.6	11	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
36	(JND-STP-003) 3.5 MLD Patiala Road , Narwana by PHED in Jan , 2011	23.01.2021	1175-1176 dt. 01.02.2021		23	112	7.9	32	56000		Complying	Non complying
		11.02.2021	1283-1284 dt. 17.02.2021		20	120	7.8	38	38000		Complying	Non complying
		19.03.2021	1489-1490 dt. 26.03.2021		21	112	7.7	34	22000		Complying	Non complying
		19.04.2021	121-122 dt. 01.05.2021		22	96	7.9	32	28000	8.6	Complying	Non complying
		24.05.2021	235-236 dt. 31.05.2021		20	88	8	28	21000	8.2	Complying	Non complying
		09.06.2021	348-349 dt. 16.06.2021		22	80	8.1	26	32000	7.8	Complying	Non complying
		09.07.2021	527-528 dt. 15.07.2021		20	72	8.1	24	28000	7.9	Complying	Non complying
		04.08.2021	771-772 dt. 11.08.2021		34	144	8.2	56	80000	9.2	Non complying	Non complying
	25.10.2021	23.09.2021	1032-1033 dt. 04.10.2021	Not work	35	160	8.1	58	110000		Non complying	Non complying
	30.11.2021	27.10.2021	1282-1283 dt. 08.11.2021	Not Work	28	144	8	46	78000		Non complying	Non complying
	20.12.2021	15.11.2021	1417-1418 dt. 01.12.2021	Not Work	26	128	7.9	36	65000		Non complying	Non complying
	27.12.2021	10.12.2021	1548-1549 dt. 20.07.2021		22	120	7.7	32	42000		Non complying	Non complying
	02.03.2022	24.01.2022	1875-1876 dt. 31.01.2022	Not Inst.	21	112	7.5	36	38000		Non complying	Non complying
	05.04.2022	28.02.2022	4360 dt. 15.03.2022		52	176	7.38	88	3200	7.65	Non complying	Non complying
	20.04.2022	31.03.2022	4822 dt. 13.04.2022		44	188	7.25	68	600	2.37	Non complying	Non complying
	18.05.2022	28.04.2022	5196 dt. 12.05.2022		14	60	6.89	35	90	1.29	Non complying	Non complying
	23.06.2022	31.05.2022	5641 dt. 13.06.2022		16	80	7.43	41	1100	2.38	Non complying	Non complying
	15.07.2022	13.06.2022	5859 dt. 24.06.2022		28	100	7.47	46	900	3.9	Non complying	Non complying
	09.09.2022	29.08.2022	6642 dt. 08.09.2022		15	72	7.08	29	400	1.43	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	18.10.2022	28.09.2022	7025 dt. 11.10.2022		15	72	7	37	500	5.75	Non complying	Non complying
	16.11.2022	26.10.2022	7280 dt. 07.11.2022		8	48	8.14	32	400	1.92	Complying	Complying
	09.12.2022	22.11.2022	7525 dt. 02.12.2022		7.5	24	7.27	13	200	0.93	Complying	Complying
	13.01.2023	26.12.2022	8067 dt. 10.01.2023		46	152	7.06	108	500	4.22	Non complying	Non complying
	16.02.2023	02.02.2023	328 dt. 14.02.2023		18	92	7.36	42	500	1.43	Non complying	Non complying
	13.03.2023	28.02.2023	655 dt. 13.03.2023		14	72	7.52	25	500	2.42	Non complying	Non complying
	17.04.2023	31.03.2023	1055 dt. 11.04.2023		7.8	48	7.1	15	90	ND	Complying	Complying
	12.05.2023	27.04.2023	1389 dt. 09.05.2023		8.6	48	7.45	15	200	ND	Complying	Complying
	14.06.2023	30.05.2023	1719 dt. 08.06.2023		15	72	7.43	28	400	2.83	Non complying	Non complying
	13.07.2023	28.06.2023	2037 dt. 06.07.2023		18	80	7.4	29	600	2.86	Non complying	Non complying
	17.08.2023	31.07.2023	2385 dt. 09.08.2023		15	76	7.08	33	400	2.58	Non complying	Non complying
	14.09.2023	29.08.2023	2710 dt. 08.09.2023		17	80	7.05	31	400	ND	Non complying	Non complying
	17.10.2023	27.09.2023	2999 dt. 13.10.2023		26	120	7.1	45	500	3.62	Non complying	Non complying
	22.11.2023	27.10.2023	3381 dt. 07.11.2023		18	76	6.75	35	500	1.18	Non complying	Non complying
	14.12.2023	26.11.2023	3685 dt. 07.12.2023		24	108	7.22	51	600	1.21	Non complying	Non complying
	19.01.2024	29.12.2023	4097 dt. 12.01.2024		16	90	6.45	27	400	1.87	Non complying	Non complying
	Jan, 2024	31.01.2024	4424 dt 07.02.2024		8.6	48	7.3	13	90	ND	Complying	Complying
	Feb, 2024	20.02.2024	4601 dt 11.03.2024		5	32	6.79	12	50	1.62	Complying	Complying
	Mar, 2024	20.03.2024	5092 dt 28.03.2024		7	40	6.84	12	80	ND	Complying	Complying
	Apr, 2024	29.04.2024	169 dt. 07.05.2024		5	24	7	10	40	ND	Complying	Complying
		24.06.2024	459 dt. 05.07.2024		7	40	7.82	10		ND	Complying	Complying
		22.07.2024	707 dt. 30.07.2024		7.2	40	6.72	14		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		22.08.2024	923 dt. 30.08.2024		8	40	7.08	16		ND	Complying	Complying
		27.09.2024	1174 dt. 09.10.2024		6.8	36	7.36	13		ND	Complying	Complying
		24.10.2024	1344 dt. 05.11.2024		6.8	36	7.25	13		ND	Complying	Complying
		31.12.2024	1779 dt. 08.01.2025		6.8	48	6.7	17		ND	Complying	Complying
		24.01.2025	1971 dt. 30.01.2025		15	80	7.04	38		ND	Non complying	Non complying
37	(JND-STP-011) 3.75 MLD STP Narwana Jind by PHED in Jan , 2011	23.01.2021	1177-1178 dt. 01.02.2021		25	104	8	42	42000		Complying	Non complying
		11.02.2021	1285-1286 dt. 17.02.2021		2.3	40	7.6	10	ND		Complying	Complying
		19.03.2021	1491-1492 dt. 26.03.2021		12.4	56	7.9	22	1100		Complying	Non complying
		19.04.2021	117-118 dt. 01.05.2021		18	72	7.9	26	3600	6.8	Complying	Non complying
		24.05.2021	231-232 dt. 31.05.2021		21	96	8	28	4200	7.2	Complying	Non complying
		09.06.2021	340-341 dt. 16.06.2021		23	104	7.7	36	5000	8.4	Complying	Non complying
		09.07.2021	531-532 dt. 15.07.2021		21	96	7.9	34	7200	8.1	Complying	Non complying
		04.08.2021	773-774 dt. 11.08.2021		36	128	7.9	42	21000	8.6	Non complying	Non complying
	25.10.2021	23.09.2021	1024-1025 dt. 04.10.2021	Not Work	28	112	7.8	38	17000		Non complying	Non complying
	30.11.2021	27.10.2021	1286-1287 dt. 08.11.2021	Not Work	25	104	7.9	32	11000		Non complying	Non complying
	20.12.2021	15.11.2021	1419-1420 dt. 01.12.2021	Not Work	22	96	7.6	28	9400		Non complying	Non complying
	27.12.2021	10.12.2021	1546-1547 dt. 20.12.2021	Not Work	24	80	7.7	26	11000		Non complying	Non complying
	02.03.2022	24.01.2022	1877-1878 dt. 31.01.2022	Not Inst.	22	72	7.6	24	9400		Non complying	Non complying
	05.04.2022	28.02.2022	4362 dt. 15.03.2022		18	92	7.12	37	1200	2.36	Non complying	Non complying
	20.04.2022	31.03.2022	4824 dt. 13.04.2022		14	68	7	44	800	2.37	Non complying	Non complying
	18.05.2022	28.04.2022	5188 dt. 11.05.2022		26	156	7.24	76	800	1.73	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	23.06.2022	31.05.2022	5640 dt. 13.06.2022		28	124	7.19	86	1700	7.47	Non complying	Non complying
	15.07.2022	14.06.2022	5860 dt. 24.06.2022		32	128	7.39	92	1100	11.83	Non complying	Non complying
	18.08.2022	29.07.2022	6377 dt. 09.08.2022		13	56	7.35	28	200	1.99	Non complying	Non complying
	09.09.2022	29.08.2022	6641 dt. 08.09.2022		16	76	7.23	32	400	1.31	Non complying	Non complying
	18.10.2022	28.09.2022	7024 dt. 11.10.2022		13	60	7.02	25	200	2.83	Non complying	Non complying
	16.11.2022	26.10.2022	7278 dt. 07.11.2022		15	68	7.08	34	200	1.32	Non complying	Non complying
	09.12.2022	23.11.2022	7524 dt. 02.12.2022		9	56	7.34	18	200	1.22	Complying	Complying
	13.01.2023	26.12.2022	8065 dt. 09.01.2023		17	84	7.22	38	500	2.86	Non complying	Non complying
	16.02.2023	02.02.2023	327 dt. 14.02.2023		28	132	7.53	89	700	3.48	Non complying	Non complying
	13.03.2023	28.02.2023	654 dt. 13.03.2023		13	68	7.39	28	400	1.82	Non complying	Non complying
	17.04.2023	31.03.2023	1054 dt. 11.04.2023		22	132	7.27	88	700	3.28	Non complying	Non complying
	12.05.2023	27.04.2023	1387 dt. 09.05.2023		23	100	7.4	42	500	2.46	Non complying	Non complying
	14.06.2023	30.05.2023	1720 dt. 08.06.2023		7.8	36	7.68	12	90	ND	Complying	Complying
	13.07.2023	28.06.2023	2038 dt. 06.07.2023		6.8	32	7.5	13	90	ND	Complying	Complying
	17.08.2023	31.07.2023	2386 dt. 09.08.2023		16	80	7.01	35	400	2.78	Complying	Complying
	14.09.2023	29.08.2023	2709 dt. 08.09.2023		8.5	48	7.19	17	200	ND	Complying	Complying
	17.10.2023	27.09.2023	2998 dt. 13.10.2023		15	84	6.9	32	200	BDL	Non complying	Non complying
	22.11.2023	27.10.2023	3379 dt. 07.11.2023		8.2	44	6.34	16	80	1.29	Complying	Complying
	14.12.2023	26.11.2023	3684 dt. 07.12.2023		7.6	40	6.97	14	80	ND	Complying	Complying
	19.01.2024	29.12.2023	4098 dt. 12.01.2024		5.8	32	7	13	50	ND	Complying	Complying
	Jan, 2024	31.01.2024	4425 dt 07.02.2024		7.2	40	7.28	11	70	ND	complying	Complying
	Feb, 2024	20.02.2024	4603 dt 11.03.2024		6.8	40	7.27	10	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	Mar, 2024	20.03.2024	5091 dt 28.03.2024		6	32	6.89	10	50	ND	Complying	Complying
	Apr, 2024	29.04.2024	167 dt 07.05.2024		7	40	7.57	10	70	ND	Complying	Complying
		24.06.2024	458 dt. 05.07.2024		5.8	32	7.73	14		ND	Complying	Complying
		22.07.2024	708 dt. 30.07.2024		7.8	44	7.05	13		ND	Complying	Complying
		22.08.2024	925 dt. 30.08.2024		5.2	36	6.96	11		ND	Complying	Complying
		27.09.2024	1178 dt. 09.10.2024		6.8	36	7.16	11		ND	Complying	Complying
		24.10.2024	1345 dt. 05.11.2024		7.2	48	7.39	14		ND	Complying	Complying
		31.12.2024	1780 dt. 08.01.2025		7.5	40	6.75	15		ND	Complying	Complying
		24.01.2025	1970 dt. 30.01.2025		13	64	6.84	68		ND	Complying	Complying
38	(JND-STP-005) 02 MLD STP, PHED , Dablain Road, Narwana, Jind (24.5.2017)	23.01.2021	1173-1174 dt. 01.02.2021		20	96	7.8	28	25000		Complying	Non complying
		11.02.2021	1279-1280 dt. 17.02.2021		21	104	7.9	28	18000		Complying	Non complying
		19.03.2021	1493-1494 dt. 26.03.2021		25	96	8	22	15000		Complying	Non complying
		19.04.2021	119-120 dt. 01.05.2021		26	112	7.8	28	21000	7.6	Complying	Non complying
		24.05.2021	233-234 dt. 31.05.2021		24	104	7.9	22	16000	7.8	Complying	Non complying
		09.06.2021	344-345 dt. 16.06.2021		25	96	7.8	28	18000	7.2	Complying	Non complying
		09.07.2021	529-530 dt. 15.07.2021		24	112	8	32	17000	6.9	Complying	Non complying
		04.08.2021	769-770 dt. 11.08.2021		38	160	8.1	64	45000	9.8	Non complying	Non complying
	25.10.2021	23.09.2021	1028-1029 dt. 04.10.2021	Not Work	39	208	8.1	72	65000		Non complying	Non complying
	30.11.2021	27.10.2021	1284-1285 dt. 08.11.2021	Not Work	35	192	8	64	52000		Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	20.12.2021	15.11.2021	1415-1416 dt. 01.12.2021	Not Work	32	208	8.2	68	32000		Non complying	Non complying
	27.12.2021	10.12.2021	1550-1551 dt. 20.12.2021	Not Work	34	232	8.1	78	45000		Non complying	Non complying
	02.03.2022	24.01.2022	1879-1880 dt. 31.01.2022	Not Inst.	27	208	8	72	31000		Non complying	Non complying
	05.04.2022	28.02.2022	4361 dt. 15.03.2022		72	256	7.12	125	4300	8.25	Non complying	Non complying
	20.04.2022	31.03.2022	4823 dt. 13.04.2022		170	624	6.83	135	2100	11.2	Non complying	Non complying
	18.05.2022	28.04.2022	5189 dt. 11.05.2022		22	144	7.12	78	900	1.73	Non complying	Non complying
	18.05.2022	28.04.2022	5189 dt. 11.05.2022		22	144	7.12	78	900	1.73	Non complying	Non complying
	23.06.2022	31.05.2022	5639 dt. 13.06.2022		68	244	7.32	135	2100	8.7	Non complying	Non complying
	14.07.2022	13.06.2022	5858 dt. 24.06.2022		90	324	7.79	215	1700	13.19	Non complying	Non complying
	18.08.2022	28.07.2022	6379 dt. 09.08.2022		52	192	7.62	68	900	5.77	Non complying	Non complying
	09.09.2022	29.08.2022	6640 dt. 08.09.2022		62	220	7.54	188	1400	6.46	Non complying	Non complying
	18.10.2022	28.09.2022	7023 dt. 11.10.2022		16	84	7.09	40	600	3.9	Non complying	Non complying
	16.11.2022	26.10.2022	7279 dt. 07.11.2022		80	316	7.3	128	1100	11.83	Non complying	Non complying
	09.12.2022	22.11.2022	7526 dt. 02.12.2022		8	40	7.41	17	400	2.42	Complying	Complying
	13.01.2023	26.12.2022	8063 dt. 09.01.2023		58	200	7.68	124	700	8.74	Non complying	Non complying
	16.02.2023	02.02.2023	326 dt. 14.02.2023		125	500	7.5	238	700	7.48	Non complying	Non complying
	13.03.2023	28.02.2023	657 dt. 13.03.2023		16	84	7.7	37	500	1.48	Non complying	Non complying
	17.04.2023	31.03.2023	1056 dt. 11.04.2023		20	128	7.16	56	500	2.48	Non complying	Non complying
	12.05.2023	27.04.2023	1388 dt. 09.05.2023		78	288	7.62	134	600	2.98	Non complying	Non complying
	14.06.2023	30.05.2023	1723 dt. 08.06.2023		92	324	7.61	167	900	8.42	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	13.07.2023	28.06.2023	2035 dt. 06.07.2023		27	112	6.96	96	700	2.78	Non complying	Non complying
	17.08.2023	31.07.2023	2388 dt. 09.08.2023		62	248	7.08	156	900	8.65	Non complying	Non complying
	17.08.2023	31.07.2023	2389 dt. 09.08.2023		48	164	7.16	117	600	4.78	Non complying	Non complying
	14.09.2023	29.08.2023	2706 dt. 08.09.2023		17	76	7.4	36	400	4.76	Non complying	Non complying
	22.11.2023	27.10.2023	3383 dt. 07.11.2023		110	380	6.7	197	900	2.94	Non complying	Non complying
	14.12.2023	26.11.2023	3683 dt. 07.12.2023		78	288	7.38	69	800	1.21	Non complying	Non complying
	19.01.2024	29.12.2023	4095 dt. 12.01.2024		28	132	7.16	62	800	2.64	Non complying	Non complying
	Jan, 2024	31.01.2024	4427 dt 07.02.2024		14	76	7.4	32	400	2.64	Non complying	Non complying
	Feb, 2024	20.02.2024	4604 dt 11.03.2024		28	152	6.97	46	800	2.91	Non complying	Non complying
	Mar, 2024	20.03.2024	5088 dt 28.03.2024		64	248	7	136	7600	3.46	Non complying	Non Complying
	Apr, 2024	29.04.2024	168 dt 07.05.2024		60	276	7.4	86	3300	2.86	Non complying	Non Complying
		24.06.2024	460 dt. 05.07.2024		70	268	7.72	61		3.48	Non complying	Non Complying
		22.07.2024	705 dt. 30.07.2024		120	384	6.43	248		12.04	Non complying	Non Complying
		22.08.2024	924 dt. 30.08.2024		7.6	48	7.06	13		ND	Complying	Complying
		27.09.2024	1175 dt. 09.10.2024		7	40	7.23	13		ND	Complying	Complying
		24.10.2024	1343 dt. 05.11.2024		8.5	44	7.09	38		0.65	Complying	Complying
		31.12.2024	1777 dt. 08.01.2025		7.2	48	7.02	11		ND	Complying	Complying
		24.01.2025	1972 dt. 30.01.2025		7.5	48	7.1	18		ND	Complying	Complying
39	(JND-STP-006) 3 MLD STP Uchana Jind by PHED in 30.06.2022	23.01.2021	1171-1172 dt. 01.02.2021		22	104	8.1	38	6200		Complying	Non complying
		11.02.2021	1277-1278 dt. 17.02.2021		24	120	7.9	44	9600		Complying	Non complying
		19.03.2021	1487-1488 dt. 26.03.2021		25	128	8.1	52	8000		Complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	09.04.2021	115-116 dt. 01.05.2021		27	152	8	68	12000	8.6	Complying	Non complying
	24.05.2021	237-238 dt. 31.05.2021		38	208	8.3	124	56000	18.9	Non complying	Non complying
	09.06.2021	342-343 dt. 16.06.2021		28	136	8.1	68	45000	7.9	Complying	Non complying
16.08.2021	27.07.2021	709-710 dt. 03.08.2021		24	112	8	54	22000	7.6	Complying	Non complying
	10.08.2021	804-805 dt. 17.08.2021		21	104	7.8	46	15000	7.4	Non complying	Non complying
25.10.2021	23.09.2021	1026-1027 dt. 04.10.2021	Not Work	26	120	8	54	18000		Non complying	Non complying
30.11.2021	26.10.2021	1278-1279 dt. 08.11.2021		24	128	8.1	48	12000		Non complying	Non complying
15.12.2021	09.11.2021	1357-1358 dt. 18.11.2021		34	136	8.2	54	9000		Non complying	Non complying
27.12.2021	07.12.2021	1528-1529 dt. 15.12.2021		29	128	8.1	48	7200		Non complying	Non complying
02.03.2022	19.01.2022	1836-1837 dt. 25.01.2022		26	112	8	46	6500		Non complying	Non complying
05.04.2022	28.02.2022	4359 dt. 15.03.2022		64	236	7.62	125	3300	9.02	Non complying	Non complying
20.04.2022	31.03.2022	4821 dt. 13.04.2022		42	148	8.74	78	2100	4.67	Non complying	Non complying
18.05.2022	28.04.2022	5197 dt. 12.05.2022		52	196	7.35	87	1400	1.44	Non complying	Non complying
23.06.2022	31.05.2022	5643 dt. 13.06.2022		25	120	7.46	81	1400	1.73	Non complying	Non complying
18.07.2022	27.06.2022	5991 dt. 08.07.2022		28	160	7.74	108	900	8.64	Non complying	Non complying
18.08.2022	28.07.2022	6378 dt. 09.08.2022		21	132	7.62	62	500	1.31	Non complying	Non complying
09.09.2022	29.08.2022	6638 dt. 08.09.2022		55	216	7.37	178	1100	10.28	Non complying	Non complying
18.10.2022	28.09.2022	7027 dt. 11.10.2022		35	124	7.23	54	800	2.97	Non complying	Non complying
16.11.2022	26.10.2022	7282 dt. 07.11.2022		54	216	7.52	134	700	1.27	Non complying	Non complying
09.12.2022	22.11.2022	7522 dt. 02.12.2022		60	264	7.5	123	1100	9.23	Non complying	Non complying
13.01.2023	26.12.2022	8064 dt. 09.01.2023		86	312	8.18	185	900	7.86	Non complying	Non complying
16.02.2023	02.02.2023	324 dt. 14.02.2023		42	180	7.26	128	1100	8.97	Non complying	Non complying
13.03.2023	28.02.2023	658 dt. 13.03.2023		20	128	7.68	56	900	4.68	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		17.04.2023	31.03.2023	1058 dt. 11.04.2023	23	108	7.15	77	400	1.78	Non complying	Non complying
		12.05.2023	27.04.2023	1386 dt. 09.05.2023	82	288	7.75	163	700	8.66	Non complying	Non complying
		14.06.2023	30.05.2023	1722 dt. 08.06.2023	120	412	7.51	188	1100	9.36	Non complying	Non complying
		13.07.2023	28.06.2023	2034 dt. 06.07.2023	28	120	7.32	112	600	2.73	Non complying	Non complying
		17.08.2023	31.07.2023	2387 dt. 09.08.2023	14	68	6.82	35	200	3.86	Non complying	Non complying
		14.09.2023	29.08.2023	2705 dt. 08.09.2023	21	108	7.4	35	700	ND	Non complying	Non complying
		17.10.2023	27.09.2023	2997 dt. 13.10.2023	28	112	7.14	37	200	BDL	Non complying	Non complying
		22.11.2023	27.10.2023	3382 dt. 07.11.2023	80	284	7.47	119	700	8.72	Non complying	Non complying
		14.12.2023	26.11.2023	3687 dt. 07.12.2023	26	128	7.37	14	400	ND	Non complying	Non complying
		19.01.2024	29.12.2023	4094 dt. 12.01.2024	84	292	6.98	126	800	9.28	Non complying	Non complying
		Jan, 2024	31.12.2023	4426 dt 07.02.2024	26	148	7.57	41	600	3.48	Non complying	Non complying
		Mar, 2024	20.03.2024	5094 dt 28.03.2024	7.2	40	7.1	10	60	ND	Complying	Complying
		Apr, 2024	29.04.2024	166 dt. 07.05.2024	8	48	7.73	12	70	ND	Complying	Complying
			24.06.2024	461 dt. 05.07.2024	7.6	44	7.83	12		ND	Complying	Complying
			22.07.2024	706 dt. 30.07.2024	7.2	40	7.5	13		0.97	Complying	Complying
			22.08.2024	921 dt. 30.08.2024	7.2	40	7.03	14		ND	Complying	Complying
			27.09.2024	1179 dt. 09.10.2024	6.2	40	7.01	12		ND	Complying	Complying
			24.10.2024	1342 dt. 05.11.2024	6.2	40	7.23	11		0.72	Complying	Complying
			31.12.2024	1775 dt. 08.01.2025	65	256	6.68	268		6.36	Non complying	Non complying
			24.01.2025	1973 dt. 30.01.2025	7	44	7.09	13		ND	Complying	Complying
40	(JND-STP-007) 1.5 MLD Uchana by PHED in 31.5.2013	23.01.2021	1169-1170 dt. 01.02.2021		26	120	8.2	48	15000		Complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks	
	11.02.2021	1281-1282 dt. 17.02.2021		22	128	8.2	36	12000		Complying	Non complying	
	19.03.2021	1497-1498 dt. 26.03.2021		26	144	8.2	48	15000		Complying	Non complying	
	19.04.2021	113-114 dt. 01.05.2021		27	152	8.1	56	21000	8.2	Complying	Non complying	
	24.05.2021	241-242 dt. 31.05.2021		45	272	8.1	128	32000	19.6	Non complying	Non complying	
	16.08.2021	27.07.2021	707-708 dt. 03.08.2021	23	104	7.8	36	17000	8.6	Complying	Non complying	
		10.08.2021	806-807 dt. 17.08.2021	20	88	8	32	11000	8.4	Non complying	Non complying	
	25.10.2021	23.09.2021	1030-1031 dt. 04.10.2021	Not Work	24	96	8.2	34	9000		Non complying	Non complying
	30.11.2021	26.10.2021	1276-1277 dt. 08.11.2021	Not Work	23	120	8.3	38	8600		Non complying	Non complying
	15.12.2021	09.11.2021	1359-1360 dt. 18.11.2021	Not Work	26	128	8.2	42	6200		Non complying	Non complying
	28.12.2021	13.12.2021	1574-1575 dt. 22.12.2021	Not Inst.	23	160	8.3	58	5600		Non complying	Non complying
	02.03.2022	19.01.2022	1832-1833 dt. 25.01.2022	Not Inst.	22	144	8.1	48	5200		Non complying	Non complying
	05.04.2022	28.02.2022	4364 dt. 15.03.2022		102	384	7.38	134	2200	16.75	Non complying	Non complying
	20.04.2022	31.03.2022	4820 dt. 13.04.2022		48	168	7.26	121	1400	3.88	Non complying	Non complying
	18.05.2022	28.04.2022	5187 dt. 11.05.2022		15	80	7.07	37	200	2.34	Non complying	Non complying
	18.05.2022	28.04.2022	5187 dt. 11.05.2022		15	80	7.07	37	200	2.34	Non complying	Non complying
	23.06.2022	31.05.2022	5642 dt. 13.06.2022		15	88	7.25	76	1100	5.69	Non complying	Non complying
	18.07.2022	27.06.2022	5986 dt. 06.07.2022		38	152	7.36	86	1200	3.05	Non complying	Non complying
	18.08.2022	28.07.2022	6376 dt. 09.08.2022		86	312	7.52	218	1400	18.6	Non complying	Non complying
	09.09.2022	29.08.2022	6639 dt. 08.09.2022		52	216	7.38	112	1200	9.36	Non complying	Non complying
	18.10.2022	28.09.2022	7026 dt. 11.10.2022		16	88	7.02	35	400	1.48	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	16.11.2022	26.10.2022	7281 dt. 07.11.2022		15	72	7.38	36	500	1.33	Non complying	Non complying
	09.12.2022	22.11.2022	7523 dt. 02.12.2022		7.2	48	7.45	16	400	1.93	Non complying	Non complying
	13.01.2023	26.12.2022	8066 dt. 09.01.2023		48	180	7.59	97	700	8.86	Non complying	Non complying
	16.02.2023	02.02.2023	325 dt. 14.02.2023		28	124	7.53	86	900	3.76	Non complying	Non complying
	13.03.2023	28.02.2023	656 dt. 13.03.2023		15	80	7.13	36	700	1.58	Non complying	Non complying
	17.04.2023	31.03.2023	1057 dt. 11.04.2023		17	120	7.23	45	500	3.96	Non complying	Non complying
	12.05.2023	27.04.2023	1385 dt. 09.05.2023		14	68	7.23	36	500	2.64	Non complying	Non complying
	14.06.2023	30.05.2023	1721 dt. 08.06.2023		16	76	7.06	31	500	2.98	Non complying	Non complying
	13.07.2023	28.06.2023	2036 dt. 06.07.2023		28	128	6.94	116	500	2.83	Non complying	Non complying
	17.08.2023	31.07.2023	2387 dt. 09.08.2023		14	68	6.82	35	200	3.86	Non complying	Non complying
	14.09.2023	29.08.2023	2711 dt. 08.09.2023		20	120	7.12	44	500	4.56	Non complying	Non complying
	22.11.2023	27.10.2023	3380 dt. 07.11.2023		15	80	6.49	35	400	3.46	Non complying	Non complying
	14.12.2023	26.11.2023	3686 dt. 07.12.2023		44	172	7.06	67	800	2.14	Non complying	Non complying
	19.01.2024	29.12.2023	4096 dt. 12.01.2024		7.8	40	6.65	12	80	ND	Complying	Complying
	Jan, 2024	31.01.2024	4428 dt 07.02.2024		11.8	64	7.52	27	200	1.62	Non complying	Non complying
	Feb, 2024	20.02.2024	4605 dt 11.03.2024		6.8	40	7.34	10	60	ND	Complying	Complying
	Mar, 2024	20.03.2024	5093 dt 28.03.2024		6.8	36	6.99	11	60	ND	Complying	Complying
	Apr, 2024	29.04.2024	165 dt. 07.05.2024		4	24	7.13	10	50	ND	Complying	Complying
		24.06.2024	462 dt. 05.07.2024		6.2	40	7.12	10		ND	Complying	Complying
		22.07.2024	704 dt. 30.07.2024		6.2	28	6.67	13		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		27.09.2024	1176 dt. 09.10.2024		7.2	44	7.8	15		ND	Complying	Complying
		24.10.2024	1341 dt. 05.11.2024		8.6	48	7.52	37		ND	Complying	Complying
		31.12.2024	1776 dt. 08.01.2025		6.5	36	6.98	11		ND	Complying	Complying
		24.01.2025	1974 dt. 30.01.2025		8	48	7.53	17		ND	Complying	Complying
41	(JND-STP-008) 5 MLD STP Jind by PHED in 1.4.2016	23.01.2021	1179-1180 dt. 01.02.2021		26	104	8	28	21000		Complying	Non complying
		16.02.2021	1303-1304 dt. 22.02.2021		25	112	7.8	34	32000		Complying	Non complying
		18.03.2021	1485-1486 dt. 25.03.2021		21	96	8	36	28000		Complying	Non complying
		19.04.2021	111-112 dt. 01.05.2021		23	104	8	38	32000	9.1	Complying	Non complying
		25.05.2021	245-246 dt. 01.06.2021		24	112	8.1	32	25000	7.8	Complying	Non complying
		08.06.2021	322-323 dt. 15.06.2021		26	104	8.2	38	22000	8.3	Complying	Non complying
		02.07.2021	465-466 dt. 09.07.2021		24	96	8	32	21000	8.1	Complying	Non complying
	27.09.2021	26.08.2021	146-147 dt. 07.09.2021	Under Ins	36	148	8.4	56	250000		Non complying	Non complying
	25.10.2021	20.09.2021	982-983 dt. 27.09.2021	Not Work	26	112	8.1	48	13000		Non complying	Non complying
	30.11.2021	26.10.2021	1280-1281 dt. 08.11.2021	Not Work	24	120	8.2	42	9600		Non complying	Non complying
	15.12.2021	09.11.2021	1353-1354 dt. 18.11.2021	Not Work	32	128	8.4	46	8400		Non complying	Non complying
	27.12.2021	07.12.2021	1530-1531 dt. 15.12.2021	Not Work	38	152	8.5	64	18000		Non complying	Non complying
	02.03.2022	18.01.2022	1830-1831 dt. 24.01.2022	Not Work	27	128	8.1	42	12000		Non complying	Non complying
	05.04.2022	28.02.2022	4363 dt. 15.03.2022		105	396	7.34	124	2600	11.56	Non complying	Non complying
	15.04.2022	25.03.2022	4698 dt. 31.03.2022		16	96	7.82	56	300	1.01	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	18.05.2022	28.04.2022	5190 dt. 11.05.2022		14	72	7.23	26	800	2.36	Non complying	Non complying
	23.06.2022	30.05.2022	5619 dt. 10.06.2022		7.2	44	7.28	14	200	2.04	Non complying	Non complying
	18.07.2022	27.06.2022	5987 dt. 08.07.2022		23	112	7.36	47	2100	8.64	Non complying	Non complying
	18.08.2022	28.07.2022	6350 dt. 08.08.2022		38	140	7.48	56	900	6.12	Non complying	Non complying
	05.09.2022	23.08.2022	6576 dt. 01.09.2022		15	72	7.34	28	800	3.23	Non complying	Non complying
	18.10.2022	28.09.2022	7049 dt. 11.10.2022		16	72	7.07	27	200	1.42	Non complying	Non complying
	16.11.2022	26.10.2022	7317 dt. 07.11.2022		42	152	7.75	87	700	2.86	Non complying	Non complying
	14.12.2022	25.11.2022	7590 dt. 07.12.2022		25	128	7.08	55	600	2.76	Non complying	Non complying
	13.01.2023	27.12.2022	8083 dt. 10.01.2023		15	76	7.58	33	200	0.96	Non complying	Non complying
	16.02.2023	03.02.2023	331 dt. 14.02.2023		16	76	7.96	28	400	1.36	Non complying	Non complying
	13.03.2023	27.02.2023	649 dt. 13.03.2023		25	104	7.27	35	600	3.65	Non complying	Non complying
	12.05.2023	28.04.2023	1409 dt. 10.05.2023		12	60	7.35	24	200	1.36	Non complying	Non complying
	14.06.2023	25.05.2023	1688 dt. 02.06.2023		14	76	7.57	28	400	ND	Non complying	Non complying
	13.07.2023	29.06.2023	2042 dt. 07.07.2023		32	140	7.29	178	700	3.23	Non complying	Non complying
	14.08.2023	29.07.2023	2382 dt. 08.08.2023		7.8	44	7.24	15	90	ND	Complying	Complying
	12.09.2023	29.08.2023	2704 dt. 08.09.2023		18	84	7.13	46	500	2.46	Non complying	Non complying
	17.10.2023	27.09.2023	3005 dt. 13.10.2023		25	116	7.1	36	200	2.01	Non complying	Non complying
	10.11.2023	25.10.2023	3318 dt. 03.11.2023		42	156	7.19	108	700	4.22	Non complying	Non complying
	14.12.2023	25.11.2023	3680 dt. 06.12.2023		24	100	7.35	31	600	0.34	Non complying	Non complying
	18.01.2024	28.12.2023	4086 dt. 12.01.2024		7	36	6.95	12	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	Jan, 2024	24.01.2024	4276 dt 30.01.2024		16	104	7.9	41	400	ND	Non complying	Non complying
	Feb, 2024	26.02.2024	4754 dt 14.03.2024		26	108	6.7	51	1400	2.18	Non complying	Non complying
	Mar, 2024	20.03.2024	5089 dt 28.03.2024		27	132	7.04	86	4100	2.81	Non Complying	Non Complying
	Apr, 2024	25.04.2024	141 dt. 02.05.2024		18	112	7.48	49	1700	ND	Non Complying	Non Complying
		19.06.2024	368 dt. 27.06.2024		7.5	44	8	13		0.64	Complying	Complying
		17.07.2024	664 dt. 25.07.2024		7.2	44	7.58	13		ND	Complying	Complying
		20.08.2024	898 dt. 28.08.2024		7.4	40	6.86	13		0.62	Complying	Complying
		25.09.2024	1142 dt. 07.10.2024		5.8	32	7.63	12		ND	Complying	Complying
		22.10.2024	1332 dt. 04.11.2024		6.8	40	7.52	15		ND	Complying	Complying
		31.12.2024	1778 dt. 08.01.2025		36	140	6.78	172		ND	Non Complying	Non Complying
		18.01.2025	1941 dt. 24.01.2025		13	68	7.15	9		ND	Non Complying	Non Complying
42	(JND-STP-009) 7 MLD STP, Jind by PHED in 30.11.2019	22.01.2021	1163-1164 dt. 29.01.2021		6	24	7.7	12	120		Complying	Complying
		16.02.2021	1309-1310 dt. 22.02.2021		5.8	32	7.9	10	80		Complying	Complying
		18.03.2021	1483-1484 dt. 25.03.2021		6.2	40	7.8	14	150000		Complying	Complying
		19.04.2021	109-110 dt. 01.05.2021		7	32	7.9	12	210	2.3	Complying	Complying
		26.05.2021	268-269 dt. 03.06.2021		6	32	7.8	10	180	1.9	Complying	Complying
		08.06.2021	326-327 dt. 15.06.2021		7	32	7.7	9	280	2.1	Complying	Complying
		02.07.2021	467-468 dt. 09.07.2021		7.4	24	7.8	8	350	2.4	Complying	Complying
		09.08.2021	800-801 dt. 16.08.2021		7	16	7.6	8	310	2.1	Complying	Complying
	25.10.2021	20.09.2021	980-981 dt. 27.09.2021	88	7.2	24	7.7	10	90		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	30.11.2021	26.10.2021	1270-1271 dt. 08.11.2021	7887.5	7.2	40	7.5	10	94		Complying	Complying
	15.12.2021	09.11.2021	1349-1350 dt. 18.11.2021	1580	7.4	48	7.6	18	84		Complying	Complying
	27.12.2021	07.12.2021	1526-1527 dt. 15.12.2021	5833	7.7	40	7.5	14	90		Complying	Complying
	02.03.2022	18.01.2022	1826-1827 dt. 24.01.2022	1044	7.2	32	7.6	12	88		Complying	Complying
	05.04.2022	28.02.2022	4368 dt. 15.03.2022		16	88	7.64	68	1400	2.26	Non complying	Non complying
	15.04.2022	25.03.2022	4699 dt. 31.03.2022		8	40	7.7	13	30	1.95	Complying	Complying
	18.05.2022	28.04.2022	5194 dt. 12.05.2022		13	72	7.27	28	200	2.28	Non complying	Non complying
	23.06.2022	30.05.2022	5619 dt. 10.06.2022		7.2	44	7.28	14	200	2.04	Non complying	Non complying
	18.07.2022	27.06.2022	5988 dt. 08.07.2022		6.8	40	7.52	9	80	2.14	Complying	Complying
	18.08.2022	28.07.2022	6352 dt. 08.08.2022		6	32	7.34	12	90	0.31	Complying	Complying
	05.09.2022	23.08.2022	6580 dt. 01.09.2022		6	20	7.46	11	200	1.12	Complying	Complying
	10.10.2022	13.09.2022	6828 dt. 27.09.2022		15	72	7.64	29	200	2.04	Non complying	Non complying
	17.11.2022	28.10.2022	7319 dt. 07.11.2022		18	70	7.99	52	500	1.04	Non complying	Non complying
	14.12.2022	25.11.2022	7591 dt. 07.12.2022		7	32	7.33	13	200	1.12	Complying	Complying
	13.01.2023	27.12.2022	8080 dt. 10.01.2023		5.8	24	7.54	9	50	ND	Complying	Complying
	16.02.2023	03.02.2023	333 dt. 14.02.2023		7	28	7.6	13	90	ND	Complying	Complying
	13.03.2023	27.02.2023	651 dt. 13.03.2023		6.5	28	7.23	12	80	ND	Complying	Complying
	11.04.2023	27.03.2023	968 dt. 07.04.2023		6.2	28	7.7	9	50	ND	Complying	Complying
	12.05.2023	28.04.2023	1406 dt. 10.05.2023		8.5	48	7.05	16	80	ND	Complying	Complying
	12.06.2023	25.05.2023	1641 dt. 2.06.2023		7.6	32	7.3	16	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	13.07.2023	29.06.2023	2044 dt. 07.07.2023		8	40	7.5	13	80	ND	Complying	Complying
	14.08.2023	29.07.2023	2381 dt. 08.08.2023		7.6	28	7.3	13	80	ND	Complying	Complying
	14.09.2023	29.08.2023	2707 dt. 08.09.2023		7.2	28	7.13	12	70	ND	Complying	Complying
	17.10.2023	27.09.2023	3003 dt. 13.10.2023		6	32	6.87	10	40	BDL	Complying	Complying
	10.11.2023	25.10.2023	3320 dt. 03.11.2023		7.5	36	7.37	16	70	ND	Complying	Complying
	14.12.2023	25.11.2023	3678 dt. 06.12.2023		9.4	48	7.29	13	80	ND	Complying	Complying
	18.01.2024	28.12.2023	4083 dt. 12.01.2024		6	32	6.98	13	70	ND	Complying	Complying
	Feb, 2024	26.02.2024	4752 dt 14.03.2024		7	40	7.1	12	80	ND	Complying	Complying
	Mar, 2024	21.03.2024	5098 dt 28.03.2024		6	36	7.58	11	60	ND	Complying	Complying
	Apr, 2024	25.04.2024	142 dt. 02.05.2024		5	28	6.95	10	50	ND	Complying	Complying
		18.06.2024	371 dt. 27.06.2024		6.8	36	7.37	11		0.56	Complying	Complying
		17.07.2024	665 dt. 25.07.2024		6.8	36	6.59	12		ND	Complying	Complying
		20.08.2024	901 dt. 28.08.2024		5.8	36	7.14	12		ND	Complying	Complying
		25.09.2024	1140 dt. 07.10.2024		7	48	6.87	15		ND	Complying	Complying
		22.10.2024	1330 dt. 04.11.2024		5.6	28	7.32	9		ND	Complying	Complying
		18.01.2025	1938 dt. 24.01.2025		6	32	7.69	13		ND	Complying	Complying
43	(JND-STP-010) 9 MLD STP Safidon , Jind by PHED in 31.05.2018	25.01.2021	1201-1202 dt. 02.02.2021		7	32	7.8	9	110		Complying	Complying
		16.02.2021	1305-1306 dt. 22.02.2021		8	24	7.8	9	250		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		22.03.2021	1520-1521 dt. 31.03.2021		7.8	32	8.1	9	380		Complying	Complying
		30.04.2021	165-166 dt. 11.05.2021		8.2	32	7.9	8	450	3.8	Complying	Complying
		26.05.2021	266-267 dt. 03.06.2021		7.4	32	8	8	380	2.4	Complying	Complying
		08.06.2021	320-321 dt. 15.06.2021		7.8	32	7.9	10	410	2.8	Complying	Complying
		15.07.2021	587-588 dt. 22.07.2021		7.5	32	7.8	8	120	2.6	Complying	Complying
	27.09.2021	26.08.2021	150-151 dt. 07.09.2021	88.1	7.2	40	8.1	10	150		Complying	Complying
	30.11.2021	26.10.2021	1262-1263 dt. 08.11.2021	Not Work	7.4	40	7.8	12	77		Complying	Complying
	15.12.2021	09.11.2021	1355-1356 dt. 18.11.2021	361.4	7.1	32	7.9	10	63		Complying	Complying
	27.12.2021	02.12.2021	1503-1504 dt. 10.12.2021	3.35	7.5	32	7.7	9	77		Complying	Complying
	02.03.2022	19.01.2022	1834-1835 dt. 25.01.2022	97.2	7.2	32	7.8	8	65		Complying	Complying
	05.04.2022	28.02.2022	4366 dt. 15.03.2022		7.5	36	7.65	15	200	2.3	Complying	Complying
	15.04.2022	25.03.2022	4702 dt. 31.03.2022		6.8	40	8.17	13	70	2.35	Complying	Complying
	18.05.2022	28.04.2022	5192 dt. 11.05.2022		5.5	20	7.36	12	400	0.59	Complying	Complying
	23.06.2022	30.05.2022	5623 dt. 10.06.2022		7.5	40	7.47	9	90	2.38	Complying	Complying
	15.07.2022	14.06.2022	5861 dt. 24.06.2022		7.6	48	7.77	16	600	4.67	Complying	Complying
	18.08.2022	28.07.2022	6346 dt. 08.08.2022		6.8	36	7.72	15	80	ND	Complying	Complying
	05.09.2022	23.08.2022	6575 dt. 01.09.2022		7.8	32	7.6	17	90	1.18	Complying	Complying
	10.10.2022	13.09.2022	6827 dt. 27.09.2022		4.2	16	7.25	9	20	0.46	Complying	Complying
	17.11.2022	28.10.2022	7316 dt. 07.11.2022		7.8	36	7.68	13	70	0.36	Complying	Complying
	05.12.2022	17.11.2022	7495 dt. 30.11.2022		4.6	28	7.75	7	80	0.23	Complying	Complying
	13.01.2023	27.12.2022	8085 dt. 10.01.2023		6.8	36	6.75	12	80	1.26	Complying	Complying
	16.02.2023	03.02.2023	335 dt. 14.02.2023		6	24	8.06	12	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	Kaithal											
44	(KTL-STP-001) 10 MLD STP Cheeka , Kaithal by PHED in 1.4.2013	22.01.2021	1139-1140 dt. 28.01.2021		9	56	7.8	15	7200		Complying	Complying
		26.02.2021	1373-1374 dt. 08.03.2021		8	64	7.5	22	2100		Complying	Complying
		22.03.2021	1522-1523 dt. 31.03.2021		7.5	56	8	18	2200		Complying	Complying
		22.04.2021	126-127 dt. 01.05.2021		7.9	64	7.9	16	2800	4.2	Complying	Complying
		21.05.2021	219-220 dt. 29.05.2021		7.6	56	7.8	10	2500	2.1	Complying	Complying
		21.06.2021	394-395 dt. 28.06.2021		7	56	7.8	12	2800	2.3	Complying	Complying
		14.07.2021	585-586 dt. 22.07.2021		6	40	7.7	9	1800	2.1	Complying	Complying
	27.09.2021	26.08.2021	156-157 dt. 07.09.2021	6	6.8	32	7.6	10	2500		Complying	Complying
	28.10.2021	29.09.2021	1066-1067 dt. 06.10.2021	6.3	6.2	32	8.2	10	2100		Complying	Complying
	29.11.2021	22.10.2021	1242-1243 dt. 28.10.2021	6	6.8	32	8.3	12	94		Complying	Complying
	27.12.2021	23.11.2021	1443-1444 dt. 03.12.2021	6.85	6.4	40	8.4	12	84		Complying	Complying
	02.02.2022	27.12.2021	1634-1635 dt. 04.01.2022	7.16	6.8	40	8.2	10	94		Complying	Complying
	02.03.2022	24.01.2022	1869-1870 dt. 31.01.2022	7	6.4	32	8.1	10	86		Complying	Complying
	06.04.2022	25.02.2022	4292 dt. 10.03.2022		8	48	7.67	12	20	2.89	Complying	Complying
	15.04.2022	29.03.2022	4735 dt. 07.04.2022	6.50 MLD	8	48	7.44	15	200	2.16	Complying	Complying
	18.05.2022	21.04.2022	5143 dt. 06.05.2022		6.5	24	8.48	12	300	1.03	Complying	Complying
	22.06.2022	25.05.2022	5556 dt. 07.06.2022		7.8	48	7.76	17	90	2.36	Complying	Complying
	18.07.2022	27.06.2022	5993 dt. 08.07.2022	6.5 MLD	7.6	40	8.43	15	80	2.13	Complying	Complying
	18.08.2022	26.07.2022	6337 dt. 04.08.2022	6.9 MLD	7.8	44	7.72	26	500	0.33	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	06.09.2022	24.08.2022	6596 dt. 05.09.2022		8.2	48	8.68	18	90	1.38	Complying	Complying
	18.10.2022	29.09.2022	7048 dt. 11.10.2022	7.9 MLD	8	44	7.63	16	80	1.92	Complying	Complying
	16.11.2022	27.10.2022	7298 dt. 07.11.2022		8.4	44	7.54	15	90	2.04	Complying	Complying
	14.12.2022	25.11.2022	7596 dt. 07.12.2022	8.1 MLD	7.8	48	7.25	18	200	1.68	Complying	Complying
	13.01.2023	27.12.2022	8086 dt. 10.01.2023	5.9 MLD	8	40	7.16	15	90	1.35	Complying	Complying
	10.02.2023	30.01.2023	286 dt. 08.02.2023		8.5	48	7.67	16	80	1.42	Complying	Complying
	09.03.2023	22.02.2023	588 dt. 03.03.2023	5.65 MLD	8.6	48	7.34	18	90	1.54	Complying	Complying
	17.04.2023	31.03.2023	1064 dt. 11.04.2023		7.5	40	7.3	10	70	ND	Complying	Complying
	12.05.2023	28.04.2023	1403 dt. 10.05.2023	5.8 MLD	7.6	48	7.1	15	90	ND	Complying	Complying
	12.05.2023	28.04.2023	1407 dt. 10.05.2023		7.8	48	7.1	17	90	ND	Complying	Complying
	14.06.2023	30.05.2023	1725 dt. 08.06.2023	6.0 MLD	8	40	7.3	15	90	ND	Complying	Complying
	12.07.2023	22.06.2023	1987 dt. 03.07.2023		8.5	48	7.07	16	90	ND	Complying	Complying
	09.08.2023	24.07.2023	2335 dt. 01.08.2023		7.8	44	7.55	14	90	ND	Complying	Complying
	12.09.2023	28.08.2023	2627 dt. 06.09.2023		7.2	36	7.1	14	80	ND	Complying	Complying
	19.10.2023	28.09.2023	3063 dt. 14.10.2023		8.6	44	7.25	12	80	ND	Complying	Complying
	22.11.2023	27.10.2023	3391 dt. 08.11.2023		8	48	6.9	15	70	ND	Complying	Complying
	11.12.2023	18.11.2023	3595 dt. 29.11.2023		8.4	44	7.42	15	80	2.86	Complying	Complying
	05.01.2024	15.12.2023	3979 dt. 28.12.2023		7.6	44	7.49	12	80	ND	Complying	Complying
	Jan, 2024	20.01.2024	4271 dt. 29.01.2024		7	40	7.07	13	80	ND	Complying	Complying
	Feb, 2024	19.02.2024	4606 dt. 11.03.2024		7.6	44	7.14	13	80	ND	Complying	Complying
	Mar, 2024	12.03.2024	4924 dt. 22.03.2024		6.8	40	7.38	13	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		18.06.2024	377 dt. 27.06.2024		6.8	44	7.05	12		0.68	Complying	Complying
		08.07.2024	551 dt. 19.07.2024		6.5	40	6.44	15		ND	Complying	Complying
		06.08.2024	807 dt. 14.08.2024		6.5	40	7.22	13		ND	Complying	Complying
		02.09.2024	1004 dt. 10.09.2024		7.6	44	6.39	15		ND	Complying	Complying
		28.10.2024	1365 dt. 07.11.2024		5.4	36	7.3	11		ND	Complying	Complying
		22.11.2024	1485 dt. 28.11.2024		7.2	44	6.96	13		ND	Complying	Complying
		11.12.2024	1656 dt. 18.12.2024		7.5	40	7.07	17		ND	Complying	Complying
		13.01.2025	1884 dt. 21.01.2025		7	36	7.28	12		ND	Complying	Complying
		04.02.2025	2028 dt. 10.02.2025		7.5	44	7.25	17		ND	Complying	Complying
		02.03.2025	9196 dt. 13.03.2025		7.2	44	6.87	12		ND	Complying	Complying
45	(KTL-STP-002) 10 MLD STP, Jind Road Kaithal by PHED in September, 2012	21.01.2021	1129-1130 dt. 28.01.2021		8	32	7.8	10	500		Complying	Complying
		11.02.2021	1287-1288 dt. 17.02.2021		6	32	7.9	12	480		Complying	Complying
		08.03.2021	1423-1424 dt. 16.03.2021		7.2	24	7.7	8	520		Complying	Complying
		16.04.2021	85-86 dt. 26.04.2021		7.5	32	7.9	7	800	1.8	Complying	Complying
		20.05.2021	209-210 dt. 29.05.2021		6.9	24	7.6	8	520	1.6	Complying	Complying
		10.06.2021	356-357 dt. 18.06.2021		6	24	7.8	8	480	1.8	Complying	Complying
		08.07.2021	521-522 dt. 14.07.2021		6.2	32	7.8	9	620	1.6	Complying	Complying
		19.08.2021	868-869 dt. 26.08.2021		6.8	32	7.9	10	700	2	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	25.10.2021	21.09.2021	990-991 dt. 29.09.2021	7	6.5	24	7.8	10	180		Complying	Complying
	29.10.2021	06.10.2021	1152-1153 dt. 18.10.2021	4.5	6.2	32	7.6	8	63		Complying	Complying
	20.12.2021	10.11.2021	1365-1366 dt. 24.11.2021	5.5	6.4	24	7.7	10	56		Complying	Complying
	28.12.2021	14.12.2021	1580-1581 dt. 22.12.2021	6.6	6.8	32	7.5	12	72		Complying	Complying
	02.03.2022	22.01.2022	1841-1842 dt. 27.01.2022	6.6	7.1	24	7.3	10	65		Complying	Complying
	06.04.2022	25.02.2022	4296 dt. 10.03.2022		8	44	7.57	17	40	0.95	Complying	Complying
	15.04.2022	29.03.2022	4736 dt. 07.04.2022	6.4 MLD	7.6	40	7.33	14	400	2.14	Complying	Complying
	18.05.2022	21.04.2022	5144 dt. 06.05.2022		7.8	44	7.28	11	200	1.32	Complying	Complying
	22.06.2022	25.05.2022	5558 dt. 07.06.2022		7	36	7.52	18	80	2.38	Complying	Complying
	18.08.2022	26.07.2022	6336 dt. 04.08.2022	6.5 MLD	8.2	48	7.47	18	80	1.44	Complying	Complying
	06.09.2022	24.08.2022	6594 dt. 05.09.2022		8.5	48	7.14	16	70	2.83	Complying	Complying
	18.10.2022	29.09.2022	7044 dt. 11.10.2022		6	24	7.05	10	50	0.81	Complying	Complying
	09.11.2022	13.10.2022	7231 dt. 26.10.2022		7.5	36	6.98	15	50	1.24	Complying	Complying
	09.12.2022	23.11.2022	7527 dt. 02.12.2022	4.2 MLD	7.4	40	7.29	15	90	ND	Complying	Complying
	05.01.2023	15.12.2022	7927 dt. 26.12.2022	6.7 MLD	12	28	7.28	15	80	1.43	Complying	Complying
	10.02.2023	30.01.2023	290 dt. 08.02.2023	6.5 MLD	7.8	40	7.01	13	50	ND	Complying	Complying
	09.03.2023	22.02.2023	589 dt. 03.03.2023	4.2 MLD	7.2	32	7.16	12	70	ND	Complying	Complying
	17.04.2023	31.03.2023	1065 dt. 11.04.2023		7.8	44	6.6	15	80	ND	Complying	Complying
	28.04.2023	18.04.2023	1246 dt. 27.04.2023	3.7 MLD	7	28	6.91	13	90	ND	Complying	Complying
	12.06.2023	25.05.2023	1643 dt. 02.06.2023	5.5 MLD	8.2	48	7.31	18	90	ND	Complying	Complying
	12.07.2023	22.06.2023	1988 dt. 03.07.2023		6.4	24	7.19	11	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	09.08.2023	24.07.2023	2336 dt. 01.08.2023		8.2	48	7.88	16	90	ND	Complying	Complying
	12.09.2023	28.08.2023	2628 dt. 06.09.2023		7.2	36	7.1	14	90	ND	Complying	Complying
	17.10.2023	21.09.2023	2960 dt. 13.10.2023	5.7	7.5	48	7.35	15	90	0.92	Complying	Complying
	11.12.2023	18.11.2023	3596 dt. 29.11.2023		6.4	32	7.4	15	80	1.46	Complying	Complying
	05.01.2024	16.12.2023	3981 dt. 28.12.2023		7	40	7.16	13	80	ND	Complying	Complying
	Jan, 2024	19.01.2024	4267 dt. 29.01.2024		8	44	7.42	15	80	ND	Complying	Complying
	Feb, 2024	20.02.2024	4613 dt. 11.03.2024		6.8	36	7.08	12	60	ND	Complying	Complying
	Mar, 2024	12.03.2024	4923 dt. 22.03.2024		5.6	32	7.76	11	60	ND	Complying	Complying
		08.07.2024	552 dt. 19.07.2024		5.8	24	6.79	11		1.08	Complying	Complying
		06.08.2024	814 dt. 14.08.2024		7.6	44	7.67	16		ND	Complying	Complying
		02.09.2024	1005 dt. 10.09.2024		6.2	36	6.7	12		ND	Complying	Complying
		28.10.2024	1364 dt. 07.11.2024		5	28	7.46	9		ND	Complying	Complying
		22.11.2024	1486 dt. 28.11.2024		6.8	36	6.97	14		ND	Complying	Complying
		11.12.2024	1655 dt. 18.12.2024		6.5	40	7.05	13		ND	Complying	Complying
		13.01.2025	889 dt. 21.01.2025		5.8	36	6.56	12		ND	Complying	Complying
		04.02.2025	2027 dt. 10.02.2025		7.4	40	7	16		ND	Complying	Complying
		02.03.2025	2197 dt. 13.03.2025		7.2	48	7.12	15		ND	Complying	Complying
46	(KTL-STP-003) 10 MLD STP Manas Road, Kaithal by PHED in June , 2006 (MBBR+TT)	21.01.2021	1133-1134 dt. 28.01.2021		7	40	7.9	14	17000		Complying	Complying
		11.02.2021	1271-1272 dt. 17.02.2021		9	40	7.8	14	3200		Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	11.02.2021	1273-1274 dt. 17.02.2021		8	48	8.1	12	21000		Complying	Complying
	08.03.2021	1421-1422 dt. 16.03.2021		9	56	8	16	9000		Complying	Complying
	16.04.2021	81-82 dt. 26.04.2021		8.2	64	8.1	14	6500	6.2	Complying	Complying
	20.05.2021	215-216 dt. 29.05.2021		7.8	56	8	12	960	4.9	Complying	Complying
	10.06.2021	354-355 dt. 18.06.2021		8	40	7.9	10	820	4.2	Complying	Complying
	08.07.2021	519-520 dt. 14.07.2021		7.8	32	8	10	900	3.8	Complying	Complying
	18.08.2021	860-861 dt. 25.08.2021		8	40	8.1	12	960	3.9	Complying	Complying
25.10.2021	21.09.2021	988-989 dt. 29.09.2021	Not Work	7.3	32	8	10	280		Complying	Complying
29.10.2021	06.10.2021	1148-1149 dt. 18.10.2021	5.8	7	24	7.8	10	82		Complying	Complying
20.12.2021	10.11.2021	1363-1364 dt. 24.11.2021	5.8	6.5	32	7.9	12	76		Complying	Complying
28.12.2021	14.12.2021	1582-1583 dt. 22.12.2021	6.2	6.9	24	7.2	12	84		Complying	Complying
02.03.2022	22.01.2022	1845-1846 dt. 27.01.2022	6.2	6.5	32	7.4	10	77		Complying	Complying
06.04.2022	25.02.2022	4295 dt. 10.03.2022		6.8	32	7.42	12	80	2.89	Complying	Complying
15.04.2022	29.03.2022	4737 dt. 07.04.2022	5.9 MLD	7.5	40	7.29	17	600	1.85	Complying	Complying
18.05.2022	28.04.2022	5199 dt. 12.05.2022		7.4	48	7.22	12	300	2.48	Complying	Complying
22.06.2022	25.05.2022	5560 dt. 07.06.2022		8	44	7.14	15	80	5.06	Complying	Complying
18.08.2022	26.07.2022	6334 dt. 04.08.2022	7.8 MLD	16	68	7.38	31	500	1.2	Non-complying	Non-complying
06.09.2022	24.08.2022	6598 dt. 05.09.2022		7.6	44	7.29	15	50	2.42	Complying	Complying
18.10.2022	29.09.2022	7045 dt. 11.10.2022	6.3 MLD	7.5	36	7.07	12	70	1.25	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	09.11.2022	13.10.2022	7229 dt. 26.10.2022	6.7 MLD	7.6	44	7.2	16	80	0.83	Complying	Complying
	09.12.2022	23.11.2022	7528 dt. 02.12.2022	3 MLD	7.5	44	7.61	14	80	1.12	Complying	Complying
	05.01.2023	15.12.2022	7926 dt. 26.12.2022	7.3 MLD	8	48	7.35	17	90	1.38	Complying	Complying
	10.02.2023	30.01.2023	289 dt. 08.02.2023	6.7 MLD	7.6	28	7.75	11	90	ND	Complying	Complying
	09.03.2023	22.02.2023	585 dt. 03.03.2023	5.6 MLD	7	36	7	14	80	ND	Complying	Complying
	17.04.2023	31.03.2023	1063 dt. 11.04.2023		8	44	6.26	15	90	ND	Complying	Complying
	28.04.2023	18.04.2023	1245 dt. 27.04.2023		6.5	32	6.61	12	80	0.76	Complying	Complying
	12.06.2023	25.05.2023	1642 dt. 02.06.2023	6.3 MLD	8.5	44	7.29	17	90	ND	Complying	Complying
	12.07.2023	22.06.2023	1989 dt. 03.07.2023		7.5	40	7.04	12	80	ND	Complying	Complying
	09.08.2023	24.07.2023	2332 dt. 01.08.2023		7.6	36	7.62	13	90	ND	Complying	Complying
	12.09.2023	28.08.2023	2629 dt. 06.09.2023		7.6	44	7.08	16	80	ND	Complying	Complying
	17.10.2023	21.09.2023	2961 dt. 13.10.2023		7.4	36	7.15	12	80	0.74	Complying	Complying
	10.11.2023	25.10.2023	3312 dt. 03.11.2023		6.5	40	7.33	16	70	ND	Complying	Complying
	11.12.2023	18.11.2023	3597 dt. 29.11.2023		7.6	40	7.13	13	60	1.47	Complying	Complying
	05.01.2024	16.12.2023	3982 dt. 28.12.2023		6.2	36	7.12	10	70	ND	Complying	Complying
	Jan, 2024	20.01.2024	4272 dt. 29.01.2024		8	44	7.36	12	90	ND	Complying	Complying
	Feb, 2024	20.02.2024	4610 dt. 11.03.2024		4.6	28	7.04	10	40	ND	Complying	Complying
	Mar, 2024	13.03.2024	4928 dt. 22.03.2024		8	48	7.38	13	90	ND	Complying	Complying
		18.06.2024	375 dt. 27.06.2024		7	36	7.08	12		0.76	Complying	Complying
		08.07.2024	549 dt. 19.07.2024		6	40	6.68	15		ND	Complying	Complying
		06.08.2024	815 dt. 14.08.2024		7.2	40	7.38	13		ND	Complying	Complying
		03.09.2024	1010 dt. 10.09.2024		7.6	44	6.98	13		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		28.10.2024	1367 dt. 07.11.2024		5.8	36	7.52	11		ND	Complying	Complying
		22.11.2024	1487 dt. 28.11.2024		6.5	36	7	15		ND	Complying	Complying
		11.12.2024	1658 dt. 18.12.2024		8.2	44	7.4	15		ND	Complying	Complying
		14.01.2025	1892 dt. 21.01.2025		7	48	6.99	11		ND	Complying	Complying
		04.02.2025	2024 dt. 10.02.2025		7.8	48	7.09	15		ND	Complying	Complying
		02.03.2025	2195 dt. 13.03.2025		6.8	40	7.32	11		ND	Complying	Complying
47	(KTL-STP-004) 10 MLD Manas Road,Kaithal bby PHED in Sep., 2012 (SBR)	21.01.2021	1135-1136 dt. 28.01.2021		9	24	7.6	10	2500		Complying	Complying
		08.03.2021	1419-1420 dt. 16.03.2021		8.6	32	7.6	12	720		Complying	Complying
		16.04.2021	83-84 dt. 26.04.2021		7.8	24	7.8	9	520	4.2	Complying	Complying
		20.05.2021	213-214 dt. 29.05.2021		7.4	24	7.6	8	480	3.9	Complying	Complying
		10.06.2021	352-353 dt. 18.06.2021		7	32	7.8	9	420	3.4	Complying	Complying
		08.07.2021	517-518 dt. 14.07.2021		6.9	32	7.7	8	520	3.2	Complying	Complying
		18.08.2021	858-859 dt. 25.08.2021		7	32	7.6	10	480	3.1	Complying	Complying
	25.10.2021	21.09.2021	994-995 dt. 29.09.2021	6.5	6.2	24	7.4	8	90		Complying	Complying
	29.10.2021	06.10.2021	1150-1151 dt. 18.10.2021	6.2	6.2	24	7.2	9	84		Complying	Complying
	20.12.2021	10.11.2021	1361-1362 dt. 24.11.2021	6	6.8	32	7.4	10	90		Complying	Complying
	28.12.2021	14.12.2021	1584-1585 dt. 22.12.2021	6.7	7.2	40	7.1	8	94		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	02.03.2022	22.01.2022	1843-1844 dt. 27.01.2022	6	7.1	32	7.4	12	91		Complying	Complying
	06.04.2022	25.02.2022	4294 dt. 10.03.2022		7.2	48	7.73	16	40	1.03	Complying	Complying
	15.04.2022	29.03.2022	4738 dt. 07.04.2022	6.0 MLD	7.4	36	7.38	16	400	2.04	Complying	Complying
	18.05.2022	28.04.2022	5200 dt. 12.05.2022		7.4	36	7.25	10	200	0.58	Complying	Complying
	22.06.2022	25.05.2022	5555 dt. 07.06.2022		8	44	7.46	12	80	1.44	Complying	Complying
	18.08.2022	26.07.2022	6335 dt. 04.08.2022	1.7 MLD	8	40	7.48	17	90	0.46	Complying	Complying
	06.09.2022	24.08.2022	6597 dt. 05.09.2022		8	44	7.46	14	90	2.08	Complying	Complying
	18.10.2022	29.09.2022	7046 dt. 11.10.2022	5.9MLD	8	44	7.05	16	80	1.33	Complying	Complying
	09.11.2022	13.10.2022	7230 dt. 26.10.2022	6.3	7.8	40	6.92	18	90	1.92	Complying	Complying
	09.12.2022	23.11.2022	7529 dt. 02.12.2022	6.2 MLD	7	44	7.48	12	90	1.32	Complying	Complying
	05.01.2023	15.12.2022	7925 dt. 26.12.2022	6.3 MLD	7.5	32	7.23	12	80	1.34	Complying	Complying
	10.02.2023	30.01.2023	287 dt. 08.02.2023	6.2 MLD	6	32	6.93	13	70	ND	Complying	Complying
	09.03.2023	22.02.2023	590 dt. 03.03.2023	4.2 MLD	8	44	7.32	15	90	ND	Complying	Complying
	17.04.2023	31.03.2023	1062 dt. 11.04.2023		7	32	6.64	11	80	ND	Complying	Complying
	28.04.2023	18.04.2023	1244 dt. 27.04.2023		5.8	28	6.9	11	70	ND	Complying	Complying
	14.06.2023	25.05.2023	1685 dt. 02.06.2023	4.2 MLD	8	48	7.51	16	90	ND	Complying	Complying
	12.07.2023	22.06.2023	1990 dt. 03.07.2023		6	24	7.25	12	90	ND	Complying	Complying
	09.08.2023	24.07.2023	2337 dt. 01.08.2023	4.75 MLD	7.5	44	7.9	16	80	ND	Complying	Complying
	12.09.2023	28.08.2023	2630 dt. 06.09.2023		6.4	28	7.12	11	70	0.72	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	17.10.2023	21.09.2023	2962 dt. 13.10.2023		7	32	7.25	11	90	ND	Complying	Complying
	10.11.2023	25.10.2023	3313 dt. 03.11.2023		7.8	48	7.08	17	80	ND	Complying	Complying
	11.12.2023	18.11.2023	3598 dt. 29.11.2023		210	736	6.85	216		14.29	Complying	Complying
	05.01.2024	16.12.2023	3983 dt. 28.12.2023		5	28	7.05	10	50	ND	Complying	Complying
	Jan, 2024	20.01.2024	4270 dt. 29.01.2024		5.8	32	7.26	11	50	ND	Complying	Complying
	Feb, 2024	20.02.2024	4611 dt. 11.03.2024		6	32	7.02	12	70	ND	Complying	Complying
	Mar, 2024	13.03.2024	4929 dt. 22.03.2024		6	32	7.34	13	70	ND	Complying	Complying
		18.06.2024	378 dt. 27.06.2024		6.2	44	7.47	11		1.02	Complying	Complying
		08.07.2024	546 dt. 19.07.2024		7.4	44	6.38	13		ND	Complying	Complying
		06.08.2024	808 dt. 14.08.2024		5.2	28	7.1	12		ND	Complying	Complying
		03.09.2024	1011 dt. 10.09.2024		7.2	36	6.39	13		ND	Complying	Complying
		28.10.2024	1366 dt. 07.11.2024		5.4	40	7.52	12		ND	Complying	Complying
		22.11.2024	1492 dt. 28.11.2024		5.6	36	6.89	11		ND	Complying	Complying
		11.12.2024	1659 dt. 18.12.2024		7.5	36	7.03	15		ND	Complying	Complying
		14.01.2025	1891 dt. 21.01.2025		6.8	44	6.76	12		ND	Complying	Complying
48	(KTL-STP-005) 7.5 MLD Kaithal by HUDA in 31.8.2016	21.01.2021	1131-1132 dt. 28.01.2021		7	32	7.7	9	1100		Complying	Complying
		11.02.2021	1269-1270 dt. 17.02.2021		8	24	7.5	8	1300		Complying	Complying
		08.03.2021	1425-1426 dt. 16.03.2021		6	16	7.4	9	920		Complying	Complying
		16.04.2021	87-88 dt. 26.04.2021		6.5	24	7.6	8	1100	2.1	Complying	Complying
		20.05.2021	217-218 dt. 29.05.2021		6.2	24	7.5	8	920	2.4	Complying	Complying
		10.06.2021	350-351 dt. 18.06.2021		7	24	7.6	9	800	2.8	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		08.07.2021	515-516 dt. 14.07.2021		6.8	16	7.5	8	ND	2.2	Complying	Complying
		19.08.2021	866-867 dt. 26.08.2021		7	24	7.6	10	24	2.5	Complying	Complying
	25.10.2021	21.09.2021	992-993 dt. 29.09.2021	4	6.5	24	7.5	8	25		Complying	Complying
	29.10.2021	06.10.2021	1154-1155 dt. 18.10.2021	3.75	6.8	24	7.4	8	38		Complying	Complying
	20.12.2021	10.11.2021	1367-1368 dt. 24.11.2021	3.2	6.3	32	7.5	8	45		Complying	Complying
	28.12.2021	14.12.2021	1586-1587 dt. 22.12.2021	3	7.5	32	7.8	12	80		Complying	Complying
	02.03.2022	22.01.2022	1851-1852 dt. 27.01.2022	4.1	7.9	32	7.6	10	84		Complying	Complying
	06.04.2022	25.02.2022	4293 dt. 10.03.2022		7.5	44	7.51	17	20	0.69	Complying	Complying
	15.04.2022	29.03.2022	4739 dt. 07.04.2022	3.45 MLD	7.8	48	7.43	13	400	1.87	Complying	Complying
	18.05.2022	21.04.2022	5142 dt. 06.05.2022		6.2	20	7.35	15	200	1.95	Complying	Complying
	22.06.2022	25.05.2022	5557 dt. 07.06.2022		7	44	7.46	15	80	2.36	Complying	Complying
	18.08.2022	26.07.2022	6338 dt. 04.08.2022	3.7 MLD	7	40	7.22	15	50	1.19	Complying	Complying
	06.09.2022	24.08.2022	6592 dt. 05.09.2022		7.8	40	7.32	16	90	1.22	Complying	Complying
	18.10.2022	29.09.2022	7047 dt. 11.10.2022	3.3 MLD	8.2	48	7.29	17	90	2.13	Complying	Complying
	09.11.2022	13.10.2022	7228 dt. 26.10.2022	2.7 MLD	8.2	48	7.25	17	90	1.41	Complying	Complying
	09.12.2022	23.11.2022	7530 dt. 02.12.2022	3.2 MLD	7.2	28	7.35	12	70	1.21	Complying	Complying
	05.01.2023	15.12.2022	7923 dt. 26.12.2022	3.2 MLD	4.6	20	7.25	9	50	1.22	Complying	Complying
	10.02.2023	30.01.2023	285 dt. 08.02.2023	2.5 MLD	7.8	44	8.04	17	90	1.36	Complying	Complying
	09.03.2023	22.02.2023	587 dt. 03.03.2023		6.8	40	7.3	12	80	ND	Complying	Complying
	17.04.2023	31.03.2023	1061 dt. 11.04.2023		7.2	36	7.14	13	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	28.04.2023	18.04.2023	1247 dt. 27.04.2023	3.20 MLD	7.8	44	7.37	15	90	ND	Complying	Complying
	12.06.2023	25.05.2023	1644 dt. 02.06.2023	3.2 MLD	7.8	44	7.12	16	90	ND	Complying	Complying
	12.07.2023	22.06.2023	1991 dt. 03.07.2023		8	44	7.15	15	90	ND	Complying	Complying
	09.08.2023	24.07.2023	2333 dt. 01.08.2023	3.6 MLD	7	40	7.42	13	80	1.13	Complying	Complying
	12.09.2023	28.08.2023	2631 dt. 06.09.2023		6.2	32	7	12	80	ND	Complying	Complying
	17.10.2023	21.09.2023	2963 dt. 13.10.2023		7.8	44	7.26	13	70	1.06	Complying	Complying
	10.11.2023	25.10.2023	3314 dt. 03.11.2023		8	44	6.97	15	90	ND	Complying	Complying
	11.12.2023	18.11.2023	3599 dt.29.11.2023		9.6	48	7.23	16	80	1.48	Complying	Complying
	05.01.2024	15.12.2023	3980 dt. 28.12.2023		6	32	7.36	16	50	ND	Complying	Complying
	Jan, 2024	20.01.2024	4269 dt. 29.01.2024		5	28	7.5	11	60	ND	Complying	Complying
	Feb, 2024	20.02.2024	4612 dt. 11.03.2024		8.2	48	7.26	13	90	ND	Complying	Complying
	Mar, 2024	13.03.2024	4930 dt. 22.03.2024		8	44	7.48	10	80	ND	Complying	Complying
		18.06.2024	374 dt. 27.06.2024		6.5	32	7.4	10		0.2	Complying	Complying
		08.07.2024	544 dt. 19.07.2024		6.5	32	6.56	11		ND	Complying	Complying
		06.08.2024	809 dt. 14.08.2024		7.5	36	7.1	15		ND	Complying	Complying
		02.09.2024	1006 dt. 10.09.2024		8	44	6.4	15		ND	Complying	Complying
		28.10.2024	1359 dt. 07.11.2024		6	36	7.22	13		ND	Complying	Complying
		22.11.2024	1488 dt. 28.11.2024		7.6	40	7.07	13		ND	Complying	Complying
		11.12.2024	1657 dt. 18.12.2024		7.6	48	7.03	15		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		13.01.2025	1890 dt 21.01.2025		5.6	32	7.26	8		ND	Complying	Complying
		04.02.2025	2029 dt. 10.02.2025		7.6	40	7.09	15		ND	Complying	Complying
		02.03.2025	2194 dt. 13.03.2025		6	44	7.1	8		ND	Complying	Complying
49	(KTL-STP-006) 5 MLD STP Kalayat , Kaithal by PHED in 1.4.2014	21.01.2021	1137-1138 dt. 28.01.2021		17	72	8	24	5000		Complying	Non-complying
		12.02.2021	1293-1294 dt. 18.02.2021		12	88	7.8	22	5600		Complying	Non-complying
		23.03.2021	1526-1527 dt. 31.03.2021		9.4	80	7.9	16	8200		Complying	Complying
		23.04.2021	128-129 dt. 03.05.2021		8.4	72	7.8	12	5000	7.6	Complying	Complying
		20.05.2021	207-208 dt. 29.05.2021		7.1	56	7.9	10	2200	5.4	Complying	Complying
		21.06.2021	390-391 dt. 28.06.2021		7	56	8	10	2100	4.2	Complying	Complying
	16.08.2021	28.07.2021	711-712 dt. 05.08.2021		7.2	48	7.9	12	1800	3.9	Complying	Complying
		18.08.2021	862-863 dt. 25.08.2021		14	64	8.4	22	5600	4.2	Non-complying	Non-complying
	28.10.2021	29.09.2021	1064-1065 dt. 06.10.2021	2.75	7.2	40	7.8	14	77		Complying	Complying
	29.11.2021	21.10.2021	1240-1241 dt. 28.10.2021	3	7	40	7.7	12	63		Complying	Complying
	27.12.2021	22.11.2021	1441-1442 dt. 03.12.2021	2.2	7.6	32	7.6	8	94		Complying	Complying
	02.02.2022	27.12.2021	1630-1631 dt. 04.01.2022	2.8	7.9	40	8	12	90		Complying	Complying
	02.03.2022	22.01.2022	1847-1848 dt. 27.01.2022	2.8	7.5	48	7.8	14	86		Complying	Complying
	06.04.2022	25.02.2022	4297 dt. 10.03.2022		7	40	5.99	13	40	N.D.	Complying	Complying
	15.04.2022	29.03.2022	4740 dt. 07.04.2022	2.2 MLD	8.5	48	6.12	18	200	2.3	Complying	Complying
	18.05.2022	21.04.2022	5146 dt. 06.05.2022		13	64	6.66	26	400	1.24	Non-complying	Non-complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	22.06.2022	25.05.2022	5559 dt. 07.06.2022		7.8	48	7.27	17	90	ND	Complying	Complying
	18.07.2022	28.06.2022	5992 dt. 08.07.2022	2.6MLD	7.8	48	6.78	13	70	1.82	Complying	Complying
	18.08.2022	28.07.2022	6354 dt. 08.08.2022		17	92	6.85	29	600	2.48	Non-complying	Non-complying
	06.09.2022	24.08.2022	6593 dt. 05.09.2022		24	112	6.97	45	500	1.72	Non-complying	Non-complying
	18.10.2022	29.09.2022	7029 dt. 11.10.2022		7.8	36	6.9	14	70	1.22	Complying	Complying
	16.11.2022	26.10.2022	7276 dt. 07.11.2022	2.5 MLD	8.4	48	7.14	17	90	0.83	Complying	Complying
	14.12.2022	25.11.2022	7595 dt. 07.12.2022		8	44	7.24	12	90	ND	Complying	Complying
	13.01.2023	26.12.2022	8068 dt. 09.01.2023		7.6	48	6.46	13	Absent	1.25	Complying	Complying
	10.02.2023	30.01.2023	284 dt. 08.02.2023	2.7 MLD	7.8	36	6.88	13	90	ND	Complying	Complying
	09.03.2023	22.02.2023	586 dt. 03.03.2023	2.75 MLD	8.5	48	7.34	17	90	0.43	Complying	Complying
	17.04.2023	31.03.2023	1060 dt. 11.04.2023		7.6	48	6.97	15	90	ND	Complying	Complying
	12.05.2023	28.04.2023	1404 dt. 10.05.2023	2.4 MLD	7.8	44	7.12	13	90	ND	Complying	Complying
	14.06.2023	30.05.2023	1726 dt. 08.06.2023	2.6 MLD	7.6	36	7.42	13	80	ND	Complying	Complying
	12.07.2023	22.06.2023	1992 dt. 03.07.2023		6.2	32	7.03	14	80	ND	Complying	Complying
	09.08.2023	24.07.2023	2338 dt. 01.08.2023	2.2 MLD	7.6	36	7.24	13	80	ND	Complying	Complying
	17.10.2023	21.09.2023	2964 dt. 13.10.2023		8	40	6.65	16	70	ND	Complying	Complying
	10.11.2023	25.10.2023	3315 dt. 03.11.2023		7	36	6.25	15	60	ND	Complying	Complying
	11.12.2023	18.11.2023	3600 dt.29.11.2023		28	104	6.9	57	500	2.16	Complying	Complying
	05.01.2024	16.12.2023	3984 dt. 28.12.2023		9	48	7	14	90	1.21	Complying	Complying
	Jan, 2024	19.01.2024	4264 dt. 29.01.2024		11.8	72	6.99	18	200	2.67	Non-complying	Non-complying
	Feb, 2024	19.02.2024	4607 dt. 11.03.2024		6	32	7.07	10	60	ND	Complying	Complying
	Mar, 2024	12.03.2024	4922 dt. 22.03.2024		8.2	48	7.54	10	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		19.06.2024	382 dt. 27.06.2024		7	48	6.82	13		0.72	Complying	Complying
		08.07.2024	550 dt. 19.07.2024		6.8	40	6.48	13		1.04	Complying	Complying
		06.08.2024	810 dt. 14.08.2024		7.8	40	7.29	16		ND	Complying	Complying
		02.09.2024	1007 dt. 10.09.2024		6.8	40	6.39	13		ND	Complying	Complying
		28.10.2024	1360 dt. 07.11.2024		6.8	44	7.47	12		ND	Complying	Complying
		22.11.2024	1489 dt. 28.11.2024		6.5	48	6.87	9		ND	Complying	Complying
		11.12.2024	1654 dt. 18.12.2024		7.6	48	7.13	16		ND	Complying	Complying
		14.01.2025	1887 dt. 21.01.2025		6.8	40	6.86	12		ND	Complying	Complying
		04.02.2025	2025 dt. 10.02.2025		7.6	44	7.1	13		ND	Complying	Complying
		10.03.2025	2275 dt. 24.03.2025		92	332	7.03	58		12.37	Non-complying	Non-complying
50	(KTL-STP-007) 3.5 Pundri Kaithal by PHED in 4.7.2014	21.01.2021	1127-1128 dt. 28.01.2021		21	88	8	34	5000		Complying	Non-complying
		26.02.2021	1371-1372 dt. 08.03.2021		9	96	7.8	32	7200		Complying	Non-complying
		23.03.2021	1524-1525 dt. 31.03.2021		8.6	72	8.1	26	6500		Complying	Complying
		23.04.2021	130-131 dt. 03.05.2021		8.2	64	7.9	22	3200	4.9	Complying	Complying
		20.5.2021	211-212 dt. 29.05.2021		7.9	56	7.8	18	2500	5.2	Complying	Complying
		21.06.2021	392-393 dt. 28.06.2021		7.5	64	7.9	14	1800	4.8	Complying	Complying
		08.07.2021	513-514 dt. 14.07.2021		7	40	7.8	12	ND	3.9	Complying	Complying
		18.08.2021	864-865 dt. 25.08.2021		12	72	8	18	520	4.5	Non-complying	Non-complying
	25.10.2021	21.09.2021	1018-1019 dt. 29.09.2021	2.85	8.4	48	7.8	14	86		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	29.10.2021	05.10.2021	1146-1147 dt. 18.10.2021	1.75	7.5	32	7.5	10	72		Complying	Complying
	27.12.2021	22.11.2021	1439-1440 dt. 03.12.2021	2.8	7.1	40	7.4	12	65		Complying	Complying
		22.12.2021	1599-1600 dt. 29.12.2021	2.8	9.5	32	7.8	10	94		Complying	Complying
	02.03.2022	19.01.2022	1838-1839 dt. 25.01.2022	2.9	9.2	24	7.6	10	90		Complying	Complying
	06.04.2022	25.02.2022	4298 dt. 10.03.2022		15	80	7.5	32	80	0.25	Complying	Complying
	15.04.2022	29.03.2022	4741 dt. 07.04.2022	2.9 MLD	8	44	7.36	17	200	1.47	Complying	Complying
	18.05.2022	21.04.2022	5145 dt. 06.05.2022		12	56	7.23	27	600	2.96	Complying	Complying
	22.06.2022	25.05.2022	5561 dt. 07.06.2022		7	48	7.27	11	90	2.88	Complying	Complying
	18.08.2022	28.07.2022	6353 dt. 08.08.2022		7.4	40	7.32	18	80	2.89	Complying	Complying
	06.09.2022	24.08.2022	6595 dt. 05.09.2022		8	48	6.89	17	80	2.42	Complying	Complying
	18.10.2022	29.09.2022	7028 dt. 11.10.2022		7	40	7.1	15	80	2.84	Complying	Complying
	16.11.2022	26.10.2022	7277 dt. 07.11.2022	3.1 MLD	8.5	48	7.12	15	80	1.02	Complying	Complying
	14.12.2022	25.11.2022	7597 dt. 07.12.2022	2.9 MLD	8.5	48	7.3	17	80	1.25	Complying	Complying
	05.01.2023	15.12.2022	7924 dt. 26.12.2022	2.7 MLD	7.6	40	7.3	12	70	1.23	Complying	Complying
	10.02.2023	30.01.2023	288 dt. 08.02.2023	3.0 MLD	15	80	7.98	34	400	1.42	Complying	Complying
	09.03.2023	22.02.2023	584 dt. 03.03.2023		7.6	48	7.57	15	90	ND	Complying	Complying
	17.04.2023	31.03.2023	1059 dt. 11.04.2023		7.8	40	7.82	11	90	ND	Complying	Complying
	12.05.2023	28.04.2023	1402 dt. 10.05.2023	2.7 MLD	7.8	36	7.18	11	80	ND	Complying	Complying
	14.06.2023	30.05.2023	1724 dt. 08.06.2023	3.0 MLD	8.4	44	8.1	17	80	ND	Complying	Complying
	12.07.2023	22.06.2023	1993 dt. 03.07.2023		7.8	36	7.25	15	80	ND	Complying	Complying
	09.08.2023	24.07.2023	2334 dt. 01.08.2023	2.9 MLD	7.2	36	7.2	12	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	12.09.2023	28.08.2023	2633 dt. 06.09.2023		7.6	44	7.12	13	80	ND	Complying	Complying
	17.10.2023	21.09.2023	2965 dt. 13.10.2023		8.5	48	8.1	16	90	ND	Complying	Complying
	22.11.2023	28.10.2023	3393 dt. 08.11.2023		7.4	40	7.45	15	70	ND	Complying	Complying
	11.12.2023	19.11.2023	3616 dt.30.11.2023		8	44	7.24	13	80	1.62	Complying	Complying
	05.01.2024	16.12.2023	3985 dt. 28.12.2023		7.4	40	7.32	12	80	ND	Complying	Complying
	Feb, 2024	20.02.2024	4609 dt. 11.03.2024		6.8	36	7.2	12	70	ND	Complying	Complying
	Mar, 2024	12.03.2024	4927 dt. 22.03.2024		7.6	40	7.74	12	70	ND	Complying	Complying
		19.06.2024	381 dt. 27.06.2024		5.8	32	7.39	10		ND	Complying	Complying
		08.07.2024	548 dt. 19.07.2024		6.8	44	6.56	15		ND	Complying	Complying
		06.08.2024	811 dt. 14.08.2024		6.8	40	7.37	13		ND	Complying	Complying
		02.09.2024	1008 dt. 10.09.2024		7.6	36	6.26	15		ND	Complying	Complying
		28.10.2024	1362 dt. 07.11.2024		5.8	44	7.32	12		ND	Complying	Complying
		22.11.2024	1490 dt. 28.11.2024		6.8	44	7.01	12		ND	Complying	Complying
		11.12.2024	1653 dt. 18.12.2024		7.5	44	7.1	13		ND	Complying	Complying
		13.01.2025	1885 dt. 21.01.2025		6.8	32	7.17	11		ND	Complying	Complying
		04.02.2025	2030 dt. 10.02.2025		6.8	36	6.98	14		ND	Complying	Complying
		10.03.2025	2273 dt. 24.03.2025		62	224	6.76	188		9.27	non-complying	non-complying
51	3 MLD, STP, PHED, SBR Village Keorak Distt Kaithal	28.10.2023	3392 dt. 08.11.2023		7.8	44	6.79	12	80	ND	Complying	Complying
		18.11.2023	3601 dt. 29.11.2023		8.6	44	7.29	14	80	ND	Complying	Complying
		16.12.2023	3987 dt. 28.12.2023		5.4	28	7.13	10	60	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks	
		Jan, 2024	19.01.2024	4268 dt. 29.01.2024		6.8	36	7.39	12	70	ND	Complying	Complying
		Feb, 2024	19.02.2024	4608 dt. 11.03.2024		5	28	7.39	10	50	ND	Complying	Complying
		Mar, 2024	12.03.2024	4925 dt. 22.03.2024		5.8	36	7.36	10	60	ND	Complying	Complying
			19.06.2024	381 dt. 27.06.2024		6.2	28	7.17	11		0.32	Complying	Complying
			08.07.2024	545 dt. 19.07.2024		6.2	36	6.49	12		ND	Complying	Complying
			06.08.2024	813 dt. 14.08.2024		5.2	28	7.3	11		ND	Complying	Complying
			02.09.2024	1003 dt. 10.09.2024		6.2	32	6.97	14		ND	Complying	Complying
			28.10.2024	1361 dt. 07.11.2024		6.5	32	7.45	12		ND	Complying	Complying
			22.11.2024	1491 dt. 28.11.2024		5.8	28	6.87	9		ND	Complying	Complying
			11.12.2024	1651 dt. 18.12.2024		7.5	36	7.16	11		ND	Complying	Complying
			13.01.2025	1888 dt. 21.01.2025		6	40	7.01	11		ND	Complying	Complying
			04.02.2025	2026 dt. 10.02.2025		7.5	48	7.13	16		ND	Complying	Complying
			02.03.2025	2193 dt 13.03.2025		5.2	24	6.98	6		MD	Complying	Complying
52	3.5 MLD STP based on SBR Technology, Pilni Road, Village Pai, Tehsil Pundri District Kaithal		28.10.2023	3394 dt. 08.11.2023		7.8	36	6.98	13	80	ND	Complying	Complying
			19.11.2023	3615 dt. 30.11.2023		6.2	32	7.38	13	70	ND	Complying	Complying
			16.12.2023	3986 dt. 28.12.2023		6.2	36	7.28	10	50	ND	Complying	Complying
		Jan, 2024	19.01.2024	4265 dt. 29.01.2024		6	32	7.35	12	70	ND	Complying	Complying
		Feb, 2024	20.02.2024	4614 dt. 11.03.2024		7.2	40	7.27	11	70	ND	Complying	Complying
		Mar, 2024	12.03.2024	4926 dt. 22.03.2024		4.8	28	7.7	10	40	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		19.06.2024	380 dt. 27.06.2024		6	36	7.4	11		ND	Complying	Complying
		08.07.2024	547 dt. 19.07.2024		7.5	36	6.67	14		ND	Complying	Complying
		06.08.2024	812 dt. 14.08.2024		7	48	7.27	13		ND	Complying	Complying
		02.09.2024	1009 dt. 10.09.2024		7.8	44	6.9	15		ND	Complying	Complying
		28.10.2024	1363 dt. 07.11.2024		5.2	32	7.39	9		ND	Complying	Complying
		22.11.2024	1490-A dt. 28.11.2024		6.2	40	7.62	12		ND	Complying	Complying
		11.12.2024	1652 dt. 18.12.2024		6.8	40	7.04	11		ND	Complying	Complying
		13.01.2025	1886 dt. 21.01.2025		6.4	36	7.02	9		ND	Complying	Complying
		04.02.2025	2031 dt. 10.02.2025		7	40	7	13		ND	Complying	Complying
		10.03.2025	2274 dt. 24.03.2025		42	176	7.53	50		8.64	non-complying	non-complying
	Hisar											
53	(HSR-STP-001) 15 MLD STP Azad Nagar, Rajgarh Road Hisar by PHED in 31.12.2014	22.01.2021	1157-1158 dt. 29.01.2021		7	32	8	10	1700		Complying	Complying
		22.01.2021	1165-1166 dt. 29.01.2021		24	112	8.1	38	15000		Non-complying	Non-complying
		22.02.2021	1341-1342 dt. 02.03.2021		16	96	8	34	1300		Non-complying	Non-complying
		09.03.2021	1427-1428 dt. 17.03.2021	6.17	6.4	24	8.1	9	800		Complying	Complying
		17.04.2021	95-96 dt. 27.04.2021	12.9	6.2	32	7.6	9	960	2.6	Complying	Complying
		21.05.2021	227-228 dt. 29.05.2021		6	32	7.8	8	80	1.9	Complying	Complying
		09.06.2021	334-335 dt. 16.06.2021		9.6	48	8	16	1800	2.8	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		03.07.2021	489-490 dt. 12.07.2021		9.4	40	8	14	1100	2.9	Complying	Complying
		19.08.2021	872-873 dt. 26.08.2021		9	32	8.1	12	720	2.5	Complying	Complying
	28.10.2021	25.09.2021	1050-1051 dt. 04.10.2021	13.5	9	40	7.8	10	1300		Complying	Complying
	29.10.2021	04.10.2021	1128-1129 dt. 12.10.2021	9.89	8.7	40	7.6	12	70		Complying	Complying
	20.12.2021	12.11.2021	1397-1398 dt. 26.11.2021	6.48	8.5	32	7.1	10	56		Complying	Complying
	27.12.2021	11.12.2021	1554-1555 dt. 20.12.2021	12.7	8.3	48	7.8	12	65		Complying	Complying
	03.02.2022	04.01.2022	1720-1721 dt. 12.01.2022		8	40	7.9	10	56		Complying	Complying
	15.04.2022	01.03.2022	4374 dt. 15.03.2022	13.65 MLD	7.6	48	7.62	18	80	1.44	Complying	Complying
	04.05.2022	04.04.2022	4865 dt. 21.04.2022	12.98 MLD	8.2	48	7.37	14	90	1.04	Complying	Complying
	01.06.2022	07.05.2022	5308 dt. 20.05.2022		8.5	40	7.75	15	60	1.67	Complying	Complying
	06.07.2022	09.06.2022	5821 dt. 23.06.2022	12.50MLD	8	44	7	13	90	1.28	Complying	Complying
	03.08.2022	08.07.2022	6108 dt. 18.07.2022	10.98 MLD	7.6	36	7.01	18	50	2.42	Complying	Complying
	25.08.2022	07.08.2022	6444 dt. 22.08.2022	13.20 MLD	7.6	36	7.32	16	90	0.77	Complying	Complying
	10.10.2022	14.09.2022	6855 dt. 27.09.2022		5.8	20	7.85	11	Absent	0.82	Complying	Complying
	25.10.2022	05.10.2022	7062 dt. 17.10.2022	12 MLD	7.5	24	7.32	12	90	ND	Complying	Complying
	02.12.2022	15.11.2022	7475 dt. 29.11.2022		7.6	44	7.44	13	70	0.84	Complying	Complying
	27.12.2022	03.12.2022	7691 dt. 19.12.2022		6.5	28	7.2	12	70	1.32	Complying	Complying
	18.01.2023	02.01.2023	4 dt. 12.01.2023		7.2	40	6.84	15	80	ND	Complying	Complying
	20.02.2023	05.02.2023	362 dt. 16.02.2023		8	44	7.19	14	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	16.03.2023	03.03.2023	745 dt. 15.03.2023		8	48	6.64	17	80	ND	Complying	Complying
	18.04.2023	01.04.2023	1100 dt. 13.04.2023		7.8	40	6.65	14	80	ND	Complying	Complying
	23.05.2023	04.05.2023	1427 dt. 15.05.2023		7.5	40	6.52	12	80	ND	Complying	Complying
	22.06.2023	02.06.2023	1750 dt. 12.06.2023		5.2	20	6.97	8	50	ND	Complying	Complying
	27.07.2023	08.07.2023	2173 dt. 19.07.2023		9	40	6.89	17	80	2.93	Complying	Complying
	21.08.2023	04.08.2023	2432 dt. 16.08.2023		7	40	7.48	13	90	ND	Complying	Complying
	21.09.2023	08.09.2023	2795 dt. 15.09.2023		8.2	44	7.39	17	70	0.36	Complying	Complying
	03.11.2023	07.10.2023	3138 dt. 27.10.2023		7	32	7.75	13	80	1.24	Complying	Complying
	23.11.2023	09.11.2023	3472 dt. 17.11.2023		7.2	32	7.6	9	70	ND	Complying	Complying
	22.12.2023	09.12.2023	3828 dt. 20.12.2023		6.4	36	7.29	13	60	ND	Complying	Complying
		03.01.2024	4141 dt. 12.01.2024		7.6	40	7	13	80	ND	Complying	Complying
		22. 02.2024	4720 dt. 13.03.2024		7.2	40	6.6	12	80	ND	Complying	Complying
	Mar, 2024	15.03.24	4962 dt. 22.03.24		7	40	7.62	12	70	ND	Complying	Complying
	April, 2024	03.04.24	19 dt. 10.04.24		4.8	28	7.28	10	40	ND	Complying	Complying
		03.05.2024	191 dt. 13.05.2024		8	48	7.01	13	90	ND	Complying	Complying
		12.06.2024	344 dt. 24.06.2024		8.2	48	7.48	13		0.34	Complying	Complying
		13.07.24	648 dt. 24.07.2024		7.4	40	7.07	12	ND		Complying	Complying
		03.08.24	778 dt. 12.08.2024		7.2	44	7.01	14	ND		Complying	Complying
		3.09.2024	1021 dt. 10.09.2024		7.8	40	7.24	15		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		09.10.24	1211 dt. 15.10.2024		7.8	40	7.05	17	ND		Complying	Complying
		06.11.24	1391 dt. 13.11.2024		4	24	6.68	9	ND		Complying	Complying
		10.12.24	1640 dt. 18.12.2024		7	36	6.89	11	ND		Complying	Complying
		08.01.25	1813 dt. 16.01.2025		7	44	6.35	15	ND		Complying	Complying
54	(HSR-STP-002) 40 MLD STP Rishi Nagar, Hisar by PHED in 02.12.2017	22.01.2021	1155-1156 dt. 29.01.2021		8	40	7.9	12	4500		Complying	Complying
		22.02.2021	1337-1338 dt. 02.03.2021		9	48	7.8	16	6500		Complying	Complying
		09.03.2021	1429-1430 dt. 17.03.2021	31.812	7.6	40	7.1	8	5000		Complying	Complying
		17.04.2021	91-92 dt. 27.04.2021	30.93	8.1	48	7.8	10	7200	2.3	Complying	Complying
		21.05.2021	225-226 dt. 29.05.2021	31	8.4	40	7.9	14	5600	2.6	Complying	Complying
		09.06.2021	336-337 dt. 16.06.2021		7.2	32	7.5	8	280	2.1	Complying	Complying
		03.07.2021	487-488 dt. 12.07.2021		8	40	7.9	9	360	2.4	Complying	Complying
		20.08.2021	879-880 dt. 26.08.2021		8.5	40	7.8	12	480	2.9	Complying	Complying
		04.09.2021	922-923 dt. 10.09.2021	31.58	8.2	48	7.4	14	620		Complying	Complying
	29.10.2021	04.10.2021	1126-1127 dt. 12.10.2021	40	7.4	32	7.2	10	80		Complying	Complying
	20.12.2021	12.11.2021	1395-1396 dt. 26.11.2021	32.7	7.5	32	6.8	12	90		Complying	Complying
	27.12.2021	11.12.2021	1556-1557 dt. 20.12.2021	32	7.1	32	7.1	10	94		Complying	Complying
	03.02.2022	04.01.2022	1718-1719 dt. 12.01.2022	32	7.6	40	7.4	12	90		Complying	Complying
	15.04.2022	01.03.2022	4376 dt. 15.03.2022	9.78 MLD	6.8	44	7.57	15	80	1.29	Complying	Complying
	04.05.2022	04.04.2022	4870 dt. 21.04.2022		8.5	48	7.34	12	80	1.41	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	01.06.2022	07.05.2022	5309 dt. 20.05.2022		7.2	44	7.83	18	90	1.47	Complying	Complying
	06.07.2022	09.06.2022	5829 dt. 23.06.2022	33.40MLD	7.6	48	7.7	15	60	0.24	Complying	Complying
	03.08.2022	08.07.2022	6111 dt. 18.07.2022	32.70 MLD	7.2	28	7.05	11	60	1.82	Complying	Complying
	25.08.2022	07.08.2022	6442 dt. 22.08.2022	38.80 MLD	7.5	32	7.59	15	90	1.32	Complying	Complying
	10.10.2022	14.09.2022	6854 dt. 27.09.2022		7.2	32	7.94	13	90	0.97	Complying	Complying
	25.10.2022	05.10.2022	7065 dt. 17.10.2022	36.5 MLD	7.8	44	7.22	15	80	ND	Complying	Complying
	02.12.2022	15.11.2022	7478 dt. 29.11.2022		8	40	7.52	16	80	0.95	Complying	Complying
	27.12.2022	03.12.2022	7694 dt. 19.12.2022		8	40	6.86	15	90	1.33	Complying	Complying
	18.01.2023	02.01.2023	2 dt. 12.01.2023		8.6	48	7.43	18	90	ND	Complying	Complying
	20.02.2023	05.02.2023	363 dt. 16.02.2023		7.8	40	7.09	15	80	ND	Complying	Complying
	16.03.2023	03.03.2023	744 dt. 15.03.2023		8.5	44	7.3	15	80	ND	Complying	Complying
	18.04.2023	01.04.2023	1099 dt. 13.04.2023		7.4	32	7.13	14	70	ND	Complying	Complying
	23.05.2023	04.05.2023	1426 dt. 15.05.2023		6.8	36	7.49	12	80	ND	Complying	Complying
	22.06.2023	01.06.2023	1747 dt. 12.06.2023		6.8	24	7.37	12	90	ND	Complying	Complying
	27.07.2023	11.07.2023	2180 dt. 21.07.2023		7.6	44	6.7	14	90	ND	Complying	Complying
	21.08.2023	04.08.2023	2433 dt. 16.08.2023		7.2	44	7.11	12	80	ND	Complying	Complying
	21.09.2023	08.09.2023	2793 dt. 15.09.2023		7.8	40	7.62	13	80	ND	Complying	Complying
	03.11.2023	07.10.2023	3140 dt. 27.10.2023		7.2	40	7.58	15	80	1.52	Complying	Complying
	23.11.2023	09.11.2023	3470 dt. 17.11.2023		5.8	20	7.2	11	80	ND	Complying	Complying
	22.12.2023	09.12.2023	3829 dt. 20.12.2023		7.8	44	7.23	12	80	ND	Complying	Complying
		03.01.2024	4140 dt. 12.01.2024		6	32	7.78	12	70	ND	Complying	Complying
		22.02.2024	4721 dt. 13.03.2024		6	32	7.7	10	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		08.04.2024	45 dt. 18.04.2024		4.2	24	7.49	10	40	ND	Complying	Complying
		2.05.2024	174 dt. 09.05.2024		8	48	7.23	12	80	ND	Complying	Complying
		12.06.2024	345 dt. 24.06.2024		6.6	40	6.99	14		0.48	Complying	Complying
		13.07.24	649 dt. 24.07.2024		7	44	7	15	ND		Complying	Complying
		03.08.24	776 dt. 12.08.2024		6.2	28	7.29	12	ND		Complying	Complying
		2.09.2024	1020 dt. 10.09.2024		7.6	48	7.03	17		ND	Complying	Complying
		08.10.24	1205 dt. 15.10.2024		7.2	44	7.45	13	ND		Complying	Complying
		06.11.24	1387 dt. 13.11.2024		5.2	32	7.08	9	ND		Complying	Complying
		09.12.24	1629 dt. 17.12.2024		8	48	6.92	17	ND		Complying	Complying
		08.01.25	1814 dt. 16.01.2025		5.5	28	6.75	12	ND		Complying	Complying
55	(HSR-STP-003) 4 MLD STP Narnaund, Hisar by PHED 31.03.2019	27.01.2021	1205-1206 dt. 02.02.2021		8	48	8	14	3500		Complying	Complying
		24.02.2021	1353-1354 dt. 05.03.2021		7	64	8	16	1700		Complying	Complying
		03.03.2021	1417-1418 dt. 15.03.2021		8.9	72	8.2	38	2200		Complying	Complying
		17.04.2021	101-102 dt. 27.04.2021	1.15	8.2	64	7.6	28	2500	3.9	Complying	Complying
		21.05.2021	221-222 dt. 29.05.2021	1.15	10	80	7.8	26	22000	3.2	Complying	Complying
		15.06.2021	362-363 dt. 22.06.2021		9	72	8	16	13000	3.6	Complying	Complying
		02.07.2021	479-480 dt. 09.07.2021		9.4	64	7.6	12	15000	3.8	Complying	Complying
		10.08.2021	816-817 dt. 17.08.2021		9	56	7.4	14	13000	3.1	Complying	Complying
	21.09.2021	06.09.2021	926-927 dt. 13.09.2021	1.58	8.5	48	7.1	10	8000		Complying	Complying
	29.10.2021	04.10.2021	1130-1131 dt. 12.10.2021	2	8.1	56	6.9	12	80		Complying	Complying
	20.12.2021	12.11.2021	1399-1400 dt. 26.11.2021	2.38	9	56	6.7	14	180		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	28.12.2021	13.12.2021	1570-1571 dt. 22.12.2021	2.3	9.4	64	7.4	16	150		Complying	Complying
	03.02.2022	05.01.2022	1740-1741 dt. 13.01.2022	2.4	8.2	72	7.6	18	90		Complying	Complying
	15.04.2022	01.03.2022	4371 dt. 15.03.2022	2.60 MLD	7	46	7.61	17	60	2.26	Complying	Complying
	04.05.2022	04.04.2022	4863 dt. 21.04.2022	1.25 MLD	15	92	7.84	34	600	1.04	Non-complying	Non-complying
	31.05.2022	03.05.2022	5274 dt. 17.05.2022		7	40	8.4	14	70	2.26	Complying	Complying
	06.07.2022	09.06.2022	5824 dt. 23.06.2022	1.5MLD	13	60	8.18	28	600	1.46	Non-complying	Non-complying
	03.08.2022	01.07.2022	6042 dt. 13.07.2022	1 MLD	60	44	8.2	14	90	ND	Non-complying	Non-complying
	25.08.2022	07.08.2022	6417 dt. 22.08.2022	1.94 MLD	8	48	7.84	17	70	1.41	Complying	Complying
	13.10.2022	18.09.2022	6969 dt. 07.09.2022	1 MLD	15	92	8.16	38	600	3.26	Non-complying	Non-complying
	25.10.2022	05.10.2022	7064 dt. 17.10.2022	1.2 MLD	20	116	7.93	52	700	3.14	Non-complying	Non-complying
	09.12.2022	22.11.2022	7538 dt. 02.12.2022		8	44	7.6	17	80	1.25	Complying	Complying
	27.12.2022	02.12.2022	7689 dt. 19.12.2022		8.5	48	7.49	18	90	1.32	Complying	Complying
	18.01.2023	04.01.2023	20 dt. 13.01.2023		7.8	44	7.44	13	90	1.28	Complying	Complying
	20.02.2023	06.02.2023	372 dt. 16.02.2023		8.2	48	7.65	16	90	2.56	Complying	Complying
	22.03.2023	09.03.2023	772 dt. 21.03.2023		8.6	8.6	7.59	18	90	1.28	Complying	Complying
	18.04.2023	03.04.2023	1106 dt. 13.04.2023		8.5	48	7.3	17	90	ND	Complying	Complying
	23.05.2023	05.05.2023	1420 dt. 15.05.2023		25	132	7.82	57	800	4.32	Non-complying	Non-complying
	22.06.2023	01.06.2023	1755 dt. 12.06.2023		8.5	48	7.9	18	80	ND	Complying	Complying
	27.07.2023	11.07.2023	2184 dt. 21.07.2023		8	48	7.22	16	200	1.93	Complying	Complying
	21.08.2023	04.08.2023	2420 dt. 16.08.2023		8.2	48	7.74	18	80	1.24	Complying	Complying
	21.09.2023	06.09.2023	2784 dt. 14.09.2023		7.2	40	7.43	15	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	03.11.2023	07.10.2023	3137 dt. 27.10.2023		8.2	44	6.98	16	90	1.08	Complying	Complying
	23.11.2023	09.11.2023	3474 dt. 17.11.2023		6.5	32	7.62	12	80	ND	Complying	Complying
	22.12.2023	08.12.2023	3820 dt. 20.12.2023		9	48	7.3	13	90	ND	Complying	Complying
		03.01.2024	4143 dt. 12.01.2024		5.8	32	8.07	13	70	ND	Complying	Complying
		21.02.2024	4670 dt. 12.03.2024		8	48	7.14	14	80	ND	Complying	Complying
		02.04.2024	20 dt. 10.04.2024		6.2	36	7.27	12	50	ND	Complying	Complying
		02.05.2024	180 dt. 09.05.2024		7.8	48	7.05	14	80	ND	Complying	Complying
		11.06.2024	338 dt. 21.06.2024		8.2	36	7.26	13		0.46	Complying	Complying
		13.07.24	646 dt. 24.07.2024		7.2	40	6.85	13	ND		Complying	Complying
		02.08.24	769 dt. 12.08.2024		7.4	36	7.6	13	ND		Complying	Complying
		2.09.2024	1017 dt. 10.09.2024		7.5	48	6.74	16		ND	Complying	Complying
		08.10.24	1204 dt. 15.10.2024		7.6	48	7.5	17		ND	Complying	Complying
		05.11.24	1386 dt. 12.11.2024		6	36	7.29	11		ND	Complying	Complying
		10.12.24	1641 dt. 18.12.2024		7.2	40	7.29	12		ND	Complying	Complying
		09.01.25	1848 dt. 17.01.2025		7.6	48	7.72	13		ND	Complying	Complying
56	(HSR-STP-004) 15 MLD STP, Dabara Tosham Road , Hisar by HUDA in 31.7.2014	22.01.2021	1161-1162 dt. 29.01.2021		6	16	7.8	8	5000		Complying	Complying
		22.02.2021	1333-1334 dt. 02.03.2021		8	32	7.9	10	8000		Complying	Complying
		24.03.2021	1534-1535 dt. 02.04.2021		5.8	24	7.2	8	900		Complying	Complying
		17.04.2021	93-94 dt. 27.04.2021	222	6.4	24	7.1	8	1200	1.2	Complying	Complying
		09.06.2021	338-339 dt. 16.06.2021		6	24	7.5	8	180	1.6	Complying	Complying
		03.07.2021	491-492 dt. 12.07.2021		6.2	32	7.7	8	160	1.8	Complying	Complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	20.08.2021	877-878 dt. 26.08.2021		6	24	7.4	10	210	2	Complying	Complying
	07.09.2021	934-935 dt. 14.09.2021	4.296	6.5	32	7.1	12	350		Complying	Complying
29.10.2021	04.10.2021	1132-1133 dt. 12.10.2021	13.3	6.4	32	6.8	10	90		Complying	Complying
20.12.2021	11.11.2021	1373-1374 dt. 24.11.2021	13.7	6.8	40	6.9	8	72		Complying	Complying
28.12.2021	11.12.2021	1560-1561 dt. 20.12.2021		7.1	32	7	9	84		Complying	Complying
15.04.2022	01.03.2022	4373 dt. 15.03.2022	11.80 MLD	18	84	7.55	48	90	2.46	Complying	Complying
04.05.2022	04.04.2022	4871 dt. 21.04.2022	10.90MLD	8	44	7.7	17	80	1.95	Complying	Complying
31.05.2022	03.05.2022	5273 dt. 17.05.2022		6.5	36	7.82	12	80	2.28	Complying	Complying
06.07.2022	09.06.2022	5820 dt. 23.06.2022	8.70MLD	7.2	40	7.48	12	1940	1.48	Complying	Complying
03.08.2022	08.07.2022	6112 dt. 18.07.2022	10 MLD	7.8	32	7.3	14	50	2.06	Complying	Complying
10.10.2022	14.09.2022	6853 dt. 27.09.2022		6.2	24	7.18	14	80	1.03	Complying	Complying
25.10.2022	05.10.2022	7067 dt. 17.10.2022	12.10 MLD	13	68	7.1	27	200	1.84	Non-complying	Non-complying
02.12.2022	15.11.2022	7477 dt. 29.11.2022		7.8	48	7.34	17	80	1.04	Complying	Complying
27.12.2022	03.12.2022	7692 dt. 19.12.2022		7.4	36	7.64	14	80	1.02	Complying	Complying
18.01.2023	02.01.2023	6 dt. 12.01.2023		7.8	48	7.49	16	90	1.05	Complying	Complying
20.02.2023	05.02.2023	366 dt. 16.02.2023		7.6	36	7.8	13	900	ND	Complying	Complying
16.03.2023	03.03.2023	742 dt. 14.03.2023		7.6	40	7.63	11	70	ND	Complying	Complying
18.04.2023	01.04.2023	1096 dt. 13.04.2023		5.6	28	7.63	9	50	ND	Complying	Complying
23.05.2023	04.05.2023	1425 dt. 15.05.2023		6.5	32	8.02	11	80	ND	Complying	Complying
22.06.2023	02.06.2023	1748 dt. 12.06.2023		7	28	7.92	13	80	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	27.07.2023	08.07.2023	2174 dt. 19.07.2023		7.8	44	7.02	13	90	ND	Complying	Complying
	21.08.2023	03.08.2023	2434 dt. 16.08.2023		6.2	32	7.46	10	70	ND	Complying	Complying
	21.09.2023	03.09.2023	2754 dt. 13.09.2023		6.8	36	7.63	12	50	0.5	Complying	Complying
	03.11.2023	08.10.2023	3144 dt. 27.10.2023		7.6	48	7.6	15	80	ND	Complying	Complying
	23.11.2023	09.11.2023	3471 dt. 17.11.2023		5.4	24	7.16	9	70	ND	Complying	Complying
	22.12.2023	09.12.2023	3830 dt. 20.12.2023		7.2	40	7.52	11	70	ND	Complying	Complying
		02.01.2024	4109 dt. 12.01.2024		5.8	32	7.39	11	60	ND	Complying	Complying
		22.02.2024	4722 dt. 13.03.2024		5	28	7.47	9	60	ND	Complying	Complying
		02.04.2024	21 dt. 10.04.2024		7.8	44	7.1	13	80	ND	Complying	Complying
		03.05.2024	192 dt. 13.05.2024		5.8	36	5.78	10	60	ND	Complying	Complying
		12.06.2024	346 dt. 24.06.2024		4.6	28	7.5	10		ND	Complying	Complying
		13.07.24	644 dt. 24.07.2024		6.5	36	6.65	14	ND		Complying	Complying
		03.08.24	779 dt. 12.08.2024		7	48	6.89	14	ND		Complying	Complying
		2.09.2024	1022 dt. 10.09.2024		7.8	44	7.72	13		ND	Complying	Complying
		09.10.24	1210 dt. 15.10.2024		6.8	48	7.12	12	ND		Complying	Complying
		06.11.24	1389 dt. 13.11.2024		5.8	32	6.78	10	ND		Complying	Complying
		10.12.24	1645 dt. 18.12.2024		7	44	6.74	13	ND		Complying	Complying
		07.01.25	1805 dt. 15.01.2025		7	44	6.99	13	ND		Complying	Complying
57	(HSR-STP-005) 4 MLD STP, Kaimri Road, Hisar by PHED in 2018	22.01.2021	1159-1160 dt. 29.01.2021		9	48	8.1	14	3800		Complying	Complying
		22.02.2021	1335-1336 dt. 02.03.2021		24	112	8	56	3200		Non-complying	Non-complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	03.03.2021	1417-1418 dt. 15.03.2021		8.9	72	8.2	38	2200		Complying	Complying
	24.03.2021	1536-1537 dt. 02.04.2021		13.8	72	7.9	38	1700		Non-complying	Non-complying
	17.04.2021	103-104 dt. 27.04.2021	1.1	9.8	64	8	34	2200	5.2	Complying	Complying
	07.06.2021	318-319 dt. 15.06.2021	1.9	17	64	7.4	38	5000	5.4	Non-complying	Non-complying
	12.07.2021	562-563 dt. 22.07.2021	3.1	14	56	7.5	32	4500	4.8	Non-complying	Non-complying
	19.08.2021	870-871 dt. 26.08.2021		15	72	8.6	36	8000	5.3	Non-complying	Non-complying
25.10.2021	25.09.2021	1046-1047 dt. 04.10.2021	2.2	16	80	7.8	46	9000		Non-complying	Non-complying
29.10.2021	04.10.2021	1134-1135 dt. 12.10.2021	3.3	28	112	8	54	9600		Non-complying	Non-complying
20.12.2021	11.11.2021	1377-1378 dt. 24.11.2021	Not Work	104	312	8.1	268	210000		Non-complying	Non-complying
28.12.2021	11.12.2021	1563 dt. 20.12.2021	Not Work	108	336	8.2	280	220000		Non-complying	Non-complying
03.02.2022	04.01.2022	1722 dt. 12.01.2022		106	352	8.4	310	180000		Non-complying	Non-complying
15.04.2022	01.03.2022	4379 dt. 15.03.2022		58	200	7.27	89	1200	5.55	Non-complying	Non-complying
04.05.2022	05.04.2022	4872 dt. 21.04.2022		60	228	7.72	156	1700	15.45	Non-complying	Non-complying
01.05.2022	07.05.2022	5307 dt. 19.05.2022		72	248	7.04	145	4800	17.66	Non-complying	Non-complying
06.07.2022	09.06.2022	5819 dt. 23.06.2022		102	360	7.48	168	1400	6.4	Non-complying	Non-complying
03.08.2022	08.07.2022	6123 dt. 18.07.2022		58	196	7.4	118	2100	19.38	Non-complying	Non-complying
25.08.2022	08.08.2022	6452 dt. 22.08.2022		52	188	7.42	121	1100	17.68	Non-complying	Non-complying
25.10.2022	05.10.2022	7061 dt. 17.10.2022		64	212	7.06	182	700	10.89	Non-complying	Non-complying
02.12.2022	19.11.2022	7512 dt. 30.11.2022		64	228	7.01	52	700	2.18	Non-complying	Non-complying
27.12.2022	03.12.2022	7693 dt. 19.12.2022		21	124	7.14	58	500	2.75	Non-complying	Non-complying
18.01.2023	02.01.2023	7 dt. 12.01.2023		20	96	7.04	31	400	4.82	Non-complying	Non-complying
20.02.2023	05.02.2023	367 dt. 16.02.2023		90	332	7.39	195	700	8.96	Non-complying	Non-complying
16.03.2023	03.03.2023	743 dt. 14.03.2023		13	60	7.18	34	200	1.24	Non-complying	Non-complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	18.04.2023	01.04.2023	1098 dt. 13.04.2023		17	92	7.2	32	500	1.94	Non-complying	Non-complying
	23.05.2023	04.05.2023	1428 dt. 15.05.2023		66	240	7.44	165	500	4.46	Non-complying	Non-complying
	22.06.2023	02.06.2023	1752 dt. 12.06.2023		36	140	7.19	125	700	6.87	Non-complying	Non-complying
	27.07.2023	21.07.2023	2181 dt. 21.07.2023		27	152	6.82	95	900	8.95	Non-complying	Non-complying
	21.08.2023	03.08.2023	2421 dt. 16.08.2023		25	124	7.06	75	600	3.83	Non-complying	Non-complying
	21.09.2023	06.09.2023	2788 dt. 14.09.2023		8	44	7.05	13	70	1.12	Complying	Complying
	03.11.2023	07.10.2023	3141 dt. 27.10.2023		7.8	40	7.4	12	90	1.23	Complying	Complying
	23.11.2023	07.11.2023	3463 dt. 16.11.2023		64	280	6.94	176	1100	17.38	Non-complying	Non-complying
		03.01.2024	4139 dt. 12.01.2024		150	536	7.16	288	800	14.87	Non-complying	Non-complying
		21.02.2024	4669 dt. 12.03.2024		175	608	6.97	237	3300	12.6	Non-complying	Non-complying
		02.04.2024	22 dt. 10.04.2024		102	352	7.4	88	2200	12.6	Non-complying	Non-complying
		2.05.2024	178 dt. 09.05.2024		195	736	7.67	289	22100	15.46	Non-complying	Non-complying
		12.06.2024	347 dt. 24.06.2024		145	496	7.01	194		13.75	Non-complying	Non-complying
		12.07.24	641 dt. 24.07.2024		135	456	6.82	285	ND		Non-complying	Non-complying
		02.08.24	770 dt. 12.08.2024		130	432	7.1	234	ND		Non-complying	Non-complying
		2.09.2024	1016 dt. 10.09.2024		110	400	6.75	225		9.72	Non-complying	Non-complying
		08.10.24	1202 dt. 15.10.2024		124	408	6.95	227	ND		Non-complying	Non-complying
		05.11.24	1384 dt. 12.11.2024		130	476	6.83	164	ND		Non-complying	Non-complying
		09.12.24	1630 dt. 17.12.2024		120	420	6.39	165	ND		Non-complying	Non-complying
		07.01.25	1806 dt. 15.01.2025		120	388	6.86	185	ND		Non-complying	Non-complying
58	(HSR-STP-011) 8 MLD STP Village Satrod, Dabra Road, Hisar by ULBD in 31.03.2021	10.06.2022 (Upload on 06.07.2022)	5828 dt. 23.06.2022	2.65MLD	6	20	7.79	10	50	0.29	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	03.08.2022	08.07.2022	6110 dt. 18.07.2022	2.3 MLD	6	32	7.28	14	80	2.5	Complying	Complying
	25.08.2022	07.08.2022	6446 dt. 22.08.2022	1.75 MLD	7.8	44	7.53	15	70	1.58	Complying	Complying
	27.09.2022	03.09.2022	6715 dt. 13.09.2022	3.20 MLD	7.6	48	8.25	17	90	2.98	Complying	Complying
	25.10.2022	05.10.2022	7063 dt. 17.10.2022	4.0 MLD	7.2	32	7.6	14	80	1.67	Complying	Complying
	02.12.2022	15.11.2022	7476 dt. 29.11.2022		7.5	40	7.48	15	90	2.16	Complying	Complying
	27.12.2022	03.12.2022	7695 dt. 19.12.2022		7.8	36	7.26	14	80	2.14	Complying	Complying
	18.01.2023	02.01.2023	8 dt. 12.01.2023		7.8	44	7.38	15	90	1.21	Complying	Complying
	20.02.2023	05.02.2023	364 dt. 16.02.2023		7.6	48	7.78	15	70	ND	Complying	Complying
	16.03.2023	03.03.2023	746 dt. 15.03.2023		7.2	36	7.25	13	80	ND	Complying	Complying
	18.04.2023	01.04.2023	1095 dt. 13.04.2023		8	48	6.97	15	80	2.95	Complying	Complying
	23.05.2023	04.05.2023	1424 dt. 15.05.2023		7.2	40	7.73	15	90	1.32	Complying	Complying
	22.06.2023	02.06.2023	1749 dt. 12.06.2023		8.6	48	7.66	17	90	ND	Complying	Complying
	27.07.2023	11.07.2023	2179 dt. 21.07.2023		8.2	40	7.06	15	90	ND	Complying	Complying
	21.08.2023	04.08.2023	2431 dt. 16.08.2023		6.6	36	7.05	11	80	ND	Complying	Complying
	21.09.2023	08.09.2023	2794 dt. 15.09.2023		6.8	36	7.46	11	50	ND	Complying	Complying
	03.11.2023	08.10.2023	3143 dt. 27.10.2023		7.5	36	7.55	12	80	ND	Complying	Complying
	23.11.2023	09.11.2023	3473 dt. 17.11.2023		4.8	20	7.22	11	90	ND	Complying	Complying
	22.12.2023	09.12.2023	3832 dt. 20.12.2023		6	32	7.29	11	50	ND	Complying	Complying
		02.01.2024	4113 dt. 12.01.2024		6	32	7.32	12	50	ND	Complying	Complying
		22.02.2024	4724 dt. 13.3.2024		8	44	7.04	14	80	ND	Complying	Complying
		02.04.2024	27 dt. 10.04.2024		7	40	6.79	13	60	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		03.05.2024	190 dt. 13.05.2024		6	40	6.07	13	70	ND	Complying	Complying
		11.06.2024	336 dt. 21.06.2024		8	44	7.35	15		1.26	Complying	Complying
		13.07.24	647 dt. 24.07.2024		6.2	32	6.29	12	ND		Complying	Complying
		03.08.24	777 dt. 12.08.2024		6.5	28	7.14	13	ND		Complying	Complying
		2.09.2024	1018 dt. 10.09.2024		7.4	44	7.16	15		ND	Complying	Complying
		09.10.24	1208 dt. 15.10.2024		7.6	40	7.59	13	ND		Complying	Complying
		06.11.24	1388 dt. 13.11.2024		4.2	28	7.1	10	ND		Complying	Complying
		10.12.24	1642 dt. 18.12.2024		6.5	36	7.02	11	ND		Complying	Complying
		08.01.25	1812 dt. 16.01.2025		5.8	36	6.43	11	ND		Complying	Complying
59	(HSR-STP-012)15 MLD STP, Hisar Sector-14, New Rishi Nagar, Hisar by HSVP in 31.05.2024											
		22.10.24	1335 dt. 30.10.24		6.2	44	6.79	16	ND		Complying	Complying
		29.11.24	1541 dt. 11.12.2024		6.2	36	7.32	14	ND		Complying	Complying
		10.12.24	1640 dt. 18.12.2024		7	36	6.89	11	ND		Complying	Complying
		08.01.25	1816 dt. 16.01.2025		6.8	44	6.45	15	ND		Complying	Complying
	Sirsa											
60	(SRS-STP-001) 15 MLD STP, Shamsabad patti, Kalania Road, Sirsa by PHED in 1.7.2012	23.02.2021	1351-1352 dt. 02.03.2021		22	120	8	36	5000		Complying	Non-complying
		09.03.2021	1435-1436 dt. 17.03.2021		24	104	7.7	38	3500		Complying	Non-complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		07.04.2021	39-40 dt. 15.04.2021		25	96	7.9	32	4200		Complying	Non-complying
		19.05.2021	197-198 dt. 27.05.2021		21	72	7.7	36	3500	7.6	Complying	Non-complying
		07.06.2021	315-316 dt. 14.06.2021		9.4	40	7.9	18	4800	7.8	Complying	Complying
		10.07.2021	556-557 dt. 15.07.2021	7.9	8	40	7.8	9	460	5.2	Complying	Complying
		13.08.2021	829-830 dt. 20.08.2021		7	32	8.1	12	80	4.6	Complying	Complying
	25.10.2021	21.09.2021	1004-1005 dt. 29.09.2021	12.6	7.2	40	8.2	14	77		Complying	Complying
	29.10.2021	06.10.2021	1162-1163 dt. 18.10.2021	11.16	6.8	48	8.3	16	58		Complying	Complying
	15.12.2021	09.11.2021	1341-1342 dt. 18.11.2021	9.75	7.1	48	8.1	18	43		Complying	Complying
	27.12.2021	04.12.2021	1512-1513 dt. 13.12.2021	12.65	7.2	40	8.3	16	65		Complying	Complying
	03.02.2022	06.01.2022	1748-1749 dt. 13.01.2022	13.5	7.8	48	8.2	14	72		Complying	Complying
	15.04.2022	04.03.2022	4430 dt. 21.03.2022	13.20 MLD	6.2	32	7.24	13	80	N.D.	Complying	Complying
	04.05.2022	06.04.2022	4938 dt. 22.04.2022	11.80MLD	7.5	40	7.58	16	90	1.32	Complying	Complying
	31.05.2022	02.05.2022	5264 dt. 17.05.2022		7.8	48	7.65	17	70	0.25	Complying	Complying
	28.06.2022	03.06.2022	5662 dt. 16.06.2022	13.00MLD	8.2	44	7.47	18	90	3.49	Complying	Complying
	02.08.2022	04.07.2022	6057 dt. 14.07.2022	11.90 MLD	7.6	44	7.62	15	90	1.72	Complying	Complying
	29.08.2022	10.08.2022	6519 dt. 23.08.2022	11.59 MLD	8.5	48	7.67	16	90	1.02	Complying	Complying
	16.09.2022	02.09.2022	6702 dt. 13.09.2022	11.92 MLD	8.2	48	7.38	6	70	0.72	Complying	Complying
	04.11.2022	10.10.2022	7134 dt. 20.10.2022	10.90 MLD	8	48	7.63	14	80	1.08	Complying	Complying
	02.12.2022	18.11.2022	7505 dt. 30.11.2022	12.20 MLD	7	44	7.61	13	90	1.2	Complying	Complying
	27.12.2022	05.12.2022	7709 dt. 20.12.2022		7.8	44	7.4	14	90	1.02	Complying	Complying
	18.01.2023	03.01.2023	11 dt. 12.01.2023		7.2	44	7.39	15	70	0.96	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	21.02.2023	07.02.2023	385 dt. 17.02.2023		8.6	48	7.36	18	90	1.56	Complying	Complying
	16.03.2023	01.03.2023	718 dt. 14.03.2023		7.8	48	7.22	17	70	0.1	Complying	Complying
	21.04.2023	05.04.2023	1126 dt. 20.04.2023		7.8	44	7.25	16	-	1.22	Complying	Complying
	05.06.2023	10.05.2023	1444 dt. 19.05.2023		8.5	48	7.92	17	90	1.22	Complying	Complying
	22.06.2023	05.06.2023	1768 dt. 13.06.2023		7.5	48	7.78	15	90	ND	Complying	Complying
	17.07.2023	03.07.2023	2100 dt. 12.07.2023		7.6	40	7.07	15	80	ND	Complying	Complying
	19.09.2023	02.09.2023	2731 dt. 12.09.2023		8.2	44	7.09	13	80	ND	Complying	Complying
	03.11.2023	05.10.2023	3106 dt. 27.10.2023		8.5	48	7.45	14	90	1.23	Complying	Complying
	23.11.2023	03.11.2023	3444 dt. 14.11.2023		6.8	36	7.23	10	50	ND	Complying	Complying
	21.12.2023	04.12.2023	3765 dt. 14.12.2023		9.2	48	7.52	13	90	ND	Complying	Complying
		01.04.2024	7 dt. 09.04.2024		8.6	48	7.48	13	90	0.4	Complying	Complying
		06.05.2024	209 dt. 15.05.2024		6.6	36	7.17	10	70	ND	Complying	Complying
		19.06.2024	405 dt. 02.07.2024		6.2	36	7.35	11		ND	Complying	Complying
		09.07.2024	576 dt. 22.07.2024		6.8	44	6.69	15		ND	Complying	Complying
		08.08.2024	828 dt. 20.08.2024		6.8	36	6.99	15		ND	Complying	Complying
		05.09.2024	1033 dt 13.09.2024		7	44	7.22	15			Complying	Complying
		09.10.2024	1220 dt 16.10.2024		7.6	40	7.30	15			Complying	Complying
		13.11.2024	1433 dt 20.11.2024		6.8	32	7.38	12			Complying	Complying
		04.12.2024	1588 dt 16.12.2024		7	40	7.01	11			Complying	Complying
		09.01.2025	1837 dt. 16.01.2025		7.5	48	7.01	16		ND	Complying	Complying
61	(SRS-STP-004) 7.5 MLD STP Ellenabad Sirsa by PHED in 11.5.2015 (MBBR+TT)	29.01.2021	1217-1218 dt. 05.02.2021		90	368	8.1	420	110000		Non complying	Non complying
		24.02.2021	1363-1364 dt. 05.03.2021		24	120	8	56	96000		Complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		10.03.2021	1447-1448 dt. 18.03.2021		21	104	7.9	42	54000		Complying	Non complying
		14.04.2021	73-74 dt. 23.04.2021		25	112	8	48	80000	8.2	Complying	Non complying
		19.05.2021	193-194 dt. 27.05.2021		22	88	7.8	34	68000	8.1	Complying	Non complying
		16.06.2021	374-375 dt. 23.06.2021		12	56	7.6	22	52000	5.2	Complying	Non complying
		09.07.2021	548-549 dt. 15.07.2021	6.1	18	64	7.4	22	39000	6.8	Complying	Non complying
		13.08.2021	835-836 dt. 20.08.2021		9.4	40	7.6	16	1100	5.1	Complying	Complying
		03.09.2021	914-915 dt. 08.09.2021	4.11	9.6	40	7.1	18	1300		Complying	Complying
	29.10.2021	06.10.2021	1170-1171 dt. 18.10.2021	5.6	9.2	32	7.6	14	94		Complying	Complying
	15.12.2021	09.11.2021	1337-1338 dt. 18.11.2021	5.9	8.9	48	7.8	16	70		Complying	Complying
	27.12.2021	04.12.2021	1520-1521 dt. 13.12.2021	5.98	8.2	40	7.9	18	36		Complying	Complying
	03.02.2022	06.01.2022	1742-1743 dt. 13.01.2022	3.98	7.8	48	7.7	16	68		Complying	Complying
	15.04.2022	05.03.2022	4435 dt. 21.03.2022	4.3 MLD	4.5	16	7.23	8	40	N.D.	Complying	Complying
	04.05.2022	06.04.2022	4934 dt. 22.04.2022	6.98MLD	7.4	36	6.97	12	400	2.37	Complying	Complying
	31.05.2022	02.05.2022	5262 dt. 17.05.2022		8	44	7.34	18	80	0.31	Complying	Complying
	28.06.2022	03.06.2022	5658 dt. 16.06.2022	5.40 MLD	7.2	44	8.13	16	90	ND	Complying	Complying
	03.08.2022	08.07.2022	6107 dt. 18.07.2022	4.5 MLD	6.8	28	7.05	14	80	2.11	Complying	Complying
	29.08.2022	04.08.2022	6413 dt. 16.08.2022	4.67 MLD	6.8	36	7.5	12	80	0.12	Complying	Complying
	21.09.2022	02.09.2022	6706 dt. 13.09.2022	4.72 MLD	8	44	7.68	9		0.97	Complying	Complying
	04.11.2022	10.10.2022	7139 dt. 20.10.2022	4.50 MLD	7	32	7.36	14	80	1.13	Complying	Complying
	02.12.2022	18.11.2022	7502 dt. 30.11.2022	4.2	8.6	48	7.76	18	90	1.21	Complying	Complying
	27.12.2022	05.12.2022	7712 dt. 20.12.2022		8.6	48	7.5	18	90	ND	Complying	Complying
	18.01.2023	03.01.2023	10 dt. 12.01.2023		8.5	48	7.6	16	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
62	(SRS-STP-005) 9.5 MLD STP, Daddu Road, Kalanwali , Sirsa by PHED in 17.02.2018	22.01.2021	1145-1146 dt. 29.01.2021		9	40	7.8	12	620		Complying	Complying
		24.02.2021	1359-1360 dt. 05.03.2021		38	152	8.2	190	180000		Non complying	Non complying
		10.03.2021	1445-1446 dt. 18.03.2021		9.7	48	7.6	14	22000		Complying	Complying
		15.04.2021	75-76 dt. 23.04.2021		9.4	40	7.8	16	58000	5.9	Complying	Complying
		25.05.2021	249-250 dt. 01.6.2021		9.2	48	7.9	18	56000	4.2	Complying	Complying
		17.06.2021	376-377 dt. 25.06.2021		9	40	7.6	12	54000	3.6	Complying	Complying
		09.07.2021	542-543 dt. 15.07.2021	6.9	9.2	40	7.6	14	960	3.4	Complying	Complying
		13.08.2021	831-832 dt. 20.08.2021		8.5	32	7.5	12	450	3.1	Complying	Complying
		03.09.2021	912-913 dt. 08.09.2021	1.97	8	40	7.3	14	520		Complying	Complying
	29.10.2021	06.10.2021	1156-1157 dt. 18.10.2021	4.6	7.5	48	7.4	12	84		Complying	Complying
	15.12.2021	09.11.2021	1331-1332 dt. 18.11.2021	2.1	7.2	40	7.6	14	56		Complying	Complying
	27.12.2021	04.12.2021	1510-1511 dt. 13.12.2021	3.12	6.9	32	7.8	12	62		Complying	Complying
	03.02.2022	06.01.2022	1756-1757 dt. 13.01.2022	4.1	6.5	40	8	14	77		Complying	Complying
	15.04.2022	05.03.2022	4437 dt. 21.03.2022	2.5 MLD	7.5	32	7.23	13	200	1.04	Complying	Complying
	04.05.2022	06.04.2022	4936 dt. 22.04.2022	2.1MLD	7.2	28	7.19	16	400	2.83	Complying	Complying
	09.06.2022	11.05.2022	5409 dt. 25.05.2022	1.8MLD	6.2	28	7.76	12	90	0.76	Complying	Complying
	28.06.2022	03.06.2022	5655 dt. 16.06.2022	2.98 MLD	7.2	44	8.14	16	90	ND	Complying	Complying
	03.08.2022	08.07.2022	6103 dt. 18.07.2022	4.30 MLD	8.5	48	6.8	26	90	2.32	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	29.08.2022	09.08.2022	6521 dt. 23.08.2022	4.32 MLD	7.5	44	7.75	44	80	2.67	Complying	Complying
	16.09.2022	02.09.2022	6704 dt. 13.09.2022	3.80 MLD	6.8	32	8	8	90	2.04	Complying	Complying
	04.11.2022	10.10.2022	7140 dt. 20.10.2022	2.10 MLD	7.2	32	6.87	12	50	1.14	Complying	Complying
	02.12.2022	18.11.2022	7508 dt. 30.11.2022	4.00 MLD	7.2	40	7.22	14	90	0.38	Complying	Complying
	27.12.2022	05.12.2022	7711 dt. 20.12.2022		7.2	32	7.53	13	80	ND	Complying	Complying
	18.01.2023	03.01.2023	12 dt. 12.01.2023		7.6	44	7.38	16	50	ND	Complying	Complying
	21.02.2023	07.02.2023	383 dt. 17.02.2023		5.2	20	7.64	9	70	ND	Complying	Complying
	16.03.2023	01.03.2023	720 dt. 14.03.2023		7.5	40	7.01	16	90	0.12	Complying	Complying
	21.04.2023	05.04.2023	1123 dt. 20.04.2023		7.8	44	7.52	16	80	1.54	Complying	Complying
	06.06.2023	11.05.2023	1478 dt. 24.05.2023		6	28	7.78	11	90	ND	Complying	Complying
	22.06.2023	05.06.2023	1770 dt. 13.06.2023		7	32	7.24	15	80	ND	Complying	Complying
	19.07.2023	04.07.2023	2106 dt. 13.07.2023		8	36	7.38	16	80	ND	Complying	Complying
	25.08.2023	08.08.2023	2453 dt. 18.08.2023		7.8	44	7.13	13	80	ND	Complying	Complying
	19.09.2023	03.09.2023	2753 dt. 13.09.2023		9.2	44	7.12	16	80	0.41	Complying	Complying
	03.11.2023	05.10.2023	3111 dt. 27.10.2023		7.6	36	7	11	70	ND	Complying	Complying
	21.12.2023	07.12.2023	3813 dt. 19.12.2023		9	48	6.99	15	90	2.49	Complying	Complying
		01.04.2024	11 dt. 09.04.2024		6	36	7.17	11	60	ND	Complying	Complying
		19.06.2024	407 dt. 02.07.2024		7.2	40	7.52	13		BDL(DL-02)	Complying	Complying
		09.07.2024	579 dt. 22.07.2024		7.2	40	6.37	13		ND	Complying	Complying
		08.08.2024	830 dt. 20.08.2024		6.5	40	6.78	13		ND	Complying	Complying
		05.09.2024	1026 dt 13.09.2024		6.8	36	7.83	13			Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		09.10.2024	1215 dt 16.10.2024		7.8	48	7.58	17			Complying	Complying
		13.11.2024	1438 dt 20.11.2024		5.5	28	7.38	9			Complying	Complying
		04.12.2024	1585 dt 16.12.2024		5.6	28	7.04	8			Complying	Complying
		09.01.2025	1839 dt. 16.01.2025		7.2	36	6.75	15		ND	Complying	Complying
63	(SRS-STP-006) 6 MLD STP Rania Sirsa by PHED in 30.6.2017	21.01.2021	1141-1142 dt. 28.01.2021		6	16	7.7	8	800		Complying	Complying
		11.02.2021	1267-1268 dt. 17.02.2021		36	208	8.2	128	12000		Non complying	Non complying
		09.03.2021	1439-1440 dt. 17.03.2021		8.9	48	8	14	4200		Complying	Complying
		19.03.2021	1502-1503 dt. 26.03.2021	5.2	7.8	48	7.7	12	5600		Complying	Complying
		14.04.2021	71-72 dt. 23.04.2021		9.2	40	8.1	18	38000	5.6	Complying	Complying
		19.05.2021	199-200 dt. 27.05.2021		8.6	32	8	14	25000	6.2	Complying	Complying
		07.06.2021	316-317 dt. 14.06.2021		7.5	24	7.6	9	11000	4.8	Complying	Complying
		09.07.2021	546-547 dt. 15.07.2021	4.9	8	32	7.4	14	7200	4.9	Complying	Complying
		13.08.2021	833-834 dt. 20.08.2021		7.6	24	7.1	14	2800	4.2	Complying	Complying
	29.10.2021	06.10.2021	1160-1161 dt. 18.10.2021	3.9	7.1	48	6.9	10	470		Complying	Complying
	15.12.2021	09.11.2021	1333-1334 dt. 18.11.2021	3	7.3	40	7.2	12	90		Complying	Complying
	27.12.2021	04.12.2021	1524-1525 dt. 13.12.2021	3.82	7.4	32	7.1	14	94		Complying	Complying
	03.02.2022	06.01.2022	1752-1753 dt. 13.01.2022	3.27	7.2	32	7.3	10	84		Complying	Complying
	15.04.2022	05.03.2022	4434 dt. 21.03.2022	2.98 MLD	5.6	20	7.32	12	60	0.51	Complying	Complying
	04.05.2022	06.04.2022	4940 dt. 22.04.2022	3.89MLD	8	40	7.99	16	80	1.04	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	31.05.2022	02.05.2022	5263 dt. 17.05.2022		7.6	44	7.96	16	0.19	0.19	Complying	Complying
	28.06.2022	03.06.2022	5657 dt. 16.06.2022	4.60 MLD	7	40	7.96	17	50	ND	Complying	Complying
	03.08.2022	04.07.2022	6058 dt. 14.07.2022	3.80 MLD	7.6	28	7.5	10	50	1.04	Complying	Complying
	29.08.2022	09.08.2022	6524 dt. 23.08.2022	4.00 MLD	6.5	32	8.13	13	80	2.35	Complying	Complying
	27.09.2022	02.09.2022	6708 dt. 13.09.2022	3.20 MLD	6.8	32	7.76	10	90	0.46	Complying	Complying
	04.11.2022	10.10.2022	7133 dt. 20.10.2022	4.0 MLD	7	40	7.85	15	90	1.2	Complying	Complying
	02.12.2022	18.11.2022	7504 dt. 30.11.2022	4.0 MLD	7.6	44	7.88	15	80	1.35	Complying	Complying
	27.12.2022	05.12.2022	7707 dt. 20.12.2022		8	40	7.27	15	90	ND	Complying	Complying
	18.01.2023	03.01.2023	12 dt. 12.01.2023		7.6	40	7.6	13	80	ND	Complying	Complying
	21.02.2023	07.02.2023	388 dt. 17.02.2023		7.8	44	7.42	17	80	1.36	Complying	Complying
	16.03.2023	01.03.2023	723 dt. 14.03.2023		7.6	40	7.09	16	90	1.04	Complying	Complying
	21.04.2023	05.04.2023	1127 dt. 20.04.2023		6.8	36	7.52	15	50	ND	Complying	Complying
	05.06.2023	10.05.2023	1445 dt. 19.05.2023		7.8	44	7.44	16	90	1.45	Complying	Complying
	22.06.2023	05.06.2023	1771 dt. 13.06.2023		6	40	7.74	13	90	ND	Complying	Complying
	17.07.2023	03.07.2023	2101 dt. 13.07.2023		7.2	36	7.22	12	70	ND	Complying	Complying
	25.08.2023	08.08.2023	2451 dt. 18.08.2023		7.8	48	7.22	16	80	ND	Complying	Complying
	19.09.2023	01.09.2023	2734 dt. 14.09.2023		8.2	40	7.17	16	80	ND	Complying	Complying
	03.11.2023	09.10.2023	3150 dt. 27.10.2023		8.5	48	7.25	17	90	ND	Complying	Complying
	23.11.2023	03.11.2023	3448 dt. 14.11.2023		8	44	6.75	15	80	1.92	Complying	Complying
	21.12.2023	07.12.2023	3815 dt. 19.12.2023		8	44	7.3	13	80	ND	Complying	Complying
		01.04.2024	12 dt. 09.04.2024		8	48	7.23	12	80	0.91	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		06.05.2024	212 dt. 15.05.2024		6.2	40	7.58	13	60	ND	Complying	Complying
		19.06.2024	408 dt. 02.07.2024		7.4	44	7.2	12		1.12	Complying	Complying
		09.07.2024	583 dt. 22.07.2024		6.4	36	6.89	11		ND	Complying	Complying
		08.08.2024	832 dt. 20.08.2024		8	48	6.98	17		ND	Complying	Complying
		05.09.2024	1028 dt 13.09.2024		7.5	48	7.43	13			Complying	Complying
		09.10.2024	1214 dt 16.10.2024		7.8	36	7.76	16			Complying	Complying
		13.11.2024	1431 dt 20.11.2024		7	40	7.70	13			Complying	Complying
		04.12.2024	1587 dt 16.12.2024		6.5	44	7.49	12			Complying	Complying
		09.01.2025	1840 dt 16.01.2025		6.8	40	7.29	12		ND	Complying	Complying
64	(SRS-STP-007) 16.5 MLD STP, Dabwali, Sirsa by PHED in 04.12.2017	22.01.2021	1147-1148 dt. 29.01.2021		8	32	7.9	12	500		Complying	Complying
		24.02.2021	1361-1362 dt. 05.03.2021		7.6	40	7.9	24	1100		Complying	Complying
		10.03.2021	1449-1450 dt. 18.03.2021		8	32	7.7	12	1500		Complying	Complying
		15.04.2021	77-78 dt. 23.04.2021		8.4	32	7.9	10	480	1.9	Complying	Complying
		25.05.2021	251-252 dt. 01.6.2021		7.4	40	7.6	12	420	2.1	Complying	Complying
		17.06.2021	380-381 dt. 25.06.2021		7	32	7.4	9	380	1.9	Complying	Complying
		09.07.2021	544-545 dt. 15.07.2021	11.9	9	32	7.9	16	450	2.1	Complying	Complying
		14.08.2021	843-844 dt. 23.08.2021		8.8	40	7.6	14	560	2.6	Complying	Complying
		03.09.2021	916-917 dt. 08.09.2021	14.6	8.2	40	7.5	12	390		Complying	Complying
	29.10.2021	06.10.2021	1158-1159 dt. 18.10.2021	12.6	7.8	40	7.3	12	94		Complying	Complying
	15.12.2021	09.11.2021	1335-1336 dt. 18.11.2021	12.7	7.5	48	7.4	16	56		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	27.12.2021	04.12.2021	1522-1523 dt. 13.12.2021	13.2	6.5	32	7.2	14	42		Complying	Complying
	03.02.2022	06.01.2022	1754-1755 dt. 13.01.2022	10.2	6.8	24	7.3	12	62		Complying	Complying
	15.04.2022	05.03.2022	4436 dt. 21.03.2022	13.9 MLD	6	24	7.36	10	80	0.36	Complying	Complying
	04.05.2022	06.04.2022	4933 dt. 22.04.2022	11.2MLD	7.5	28	7.98	14	60	1.41	Complying	Complying
	09.06.2022	11.05.2022	5410 dt. 25.05.2022	11.1MLD	7	32	8.16	13	70	1.02	Complying	Complying
	28.06.2022	03.06.2022	5656 dt. 16.06.2022	9.6 MLD	7.8	48	8.28	17	80	ND	Complying	Complying
	29.08.2022	09.08.2022	6523 dt. 23.08.2022	13.00 MLD	7.5	40	7.55	14	80	2.57	Complying	Complying
	21.09.2022	02.09.2022	6705 dt. 13.09.2022	13.40 MLD	7.5	36	7.19	10	50	1.24	Complying	Complying
	04.11.2022	10.10.2022	7138 dt. 20.10.2022	13.90 MLD	7.5	36	7.06	13	70	0.96	Complying	Complying
	02.12.2022	18.11.2022	7509 dt. 30.11.2022	14.0 MLD	7.5	48	7.79	11	80	1.04	Complying	Complying
	09.12.2022	24.11.2022	7554 dt. 06.12.2022		8.5	48	7.03	17	90	0.34	Complying	Complying
	27.12.2022	05.12.2022	7713 dt. 20.12.2022		6.8	36	7.61	15	80	ND	Complying	Complying
	18.01.2023	03.01.2023	14 dt. 12.01.2023		7	48	8.45	15	90	1.12	Complying	Complying
	21.02.2023	07.02.2023	381 dt. 17.02.2023		8.2	48	7.17	14	90	ND	Complying	Complying
	16.03.2023	01.03.2023	724 dt. 14.03.2023		8.2	48	7.15	17	90	0.85	Complying	Complying
	21.04.2023	05.04.2023	1124 dt. 20.04.2023		7.2	40	7.9	13	70	1.32	Complying	Complying
	06.06.2023	11.05.2023	1477 dt. 24.05.2023		6.8	32	8.1	12	70	ND	Complying	Complying
	22.06.2023	05.06.2023	1769 dt. 13.06.2023		6.4	36	7.24	14	80	ND	Complying	Complying
	17.07.2023	04.07.2023	2105 dt. 13.07.2023		8.2	40	7.4	15	90	ND	Complying	Complying
	25.08.2023	08.08.2023	2454 dt. 18.08.2023		7.5	48	7.65	13	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	19.09.2023	01.09.2023	2735 dt. 12.09.2023		6.8	36	7.33	14	60	ND	Complying	Complying
	03.11.2023	05.10.2023	3107 dt. 27.10.2023		7.8	44	7.54	15	80	ND	Complying	Complying
	23.11.2023	03.11.2023	3449 dt. 14.11.2023		7.8	48	7.02	15	90	ND	Complying	Complying
	21.12.2023	07.12.2023	3812 dt. 19.12.2023		7.6	40	7.02	10	60	ND	Complying	Complying
		01.04.2024	13 dt. 09.04.2024		5	28	7.24	10	50	ND	Complying	Complying
		19.06.2024	409 dt. 02.07.2024		7.8	48	7.35	13		1.23	Complying	Complying
		09.07.2024	580 dt. 22.07.2024		7.2	36	6.79	14		ND	Complying	Complying
		08.08.2024	831 dt. 20.08.2024		6.2	36	7.28	14		ND	Complying	Complying
		05.09.2024	1029 dt 13.09.2024		7	44	7.28	16			Complying	Complying
		09.10.2024	1216 dt 16.10.2024		7.2	36	7.28	14			Complying	Complying
		13.11.2024	1432 dt 20.11.2024		7	40	7.30	13			Complying	Complying
		04.12.2024	1584 dt 16.12.2024		7	48	7.28	11			Complying	Complying
		09.01.2025	1834 dt. 16.01.2025		7	36	6.87	12		ND	Complying	Complying
65	(SRS-STP-008) 20 MLD STP Kelnia, Distt. Sirsa by PHED in 30.10.2019	21.01.2021	1143-1144 dt. 28.01.2021		8	32	7.6	10	380		Complying	Complying
		02.02.2020	1245-1246 dt. 09.02.2021		9	40	7.4	12	500		Complying	Complying
		09.03.2021	1437-1438 dt. 17.03.2021		9.4	48	7.6	16	7200		Complying	Complying
		19.03.2021	1500-1501 dt. 26.03.2021	11.5	9.6	32	8.1	14	6500		Complying	Complying
		07.04.2021	41-42 dt. 15.04.2021		8	32	7.8	9	2800		Complying	Complying
		19.05.2021	195-196 dt. 27.05.2021		6.8	24	7.3	7	800	1.2	Complying	Complying
		07.06.2021	314-315 dt. 14.06.2021		7.2	48	7.1	8	820	1.4	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		10.07.2021	558-559 dt. 15.07.2021	11	7	32	7.2	9	620	1.5	Complying	Complying
		13.08.2021	837-838 dt. 20.08.2021		6	32	7.1	10	250	1.8	Complying	Complying
	25.10.2021	21.09.2021	1002-1003 dt. 29.09.2021	11.68	7	48	7.8	12	5800		Complying	Complying
	29.10.2021	06.10.2021	1164-1165 dt. 18.10.2021	12.6	7.6	40	7.9	9	350		Complying	Complying
	15.12.2021	09.11.2021	1339-1340 dt. 18.11.2021	7.1	7.4	48	7.8	14	180		Complying	Complying
	27.12.2021	04.12.2021	1514-1515 dt. 13.12.2021	12.68	7.8	40	7.7	10	94		Complying	Complying
	03.02.2022	06.01.2022	1750-1751 dt. 13.01.2022	12.8	8.2	40	7.2	12	84		Complying	Complying
	15.04.2022	05.03.2022	4433 dt. 21.03.2022	13.5 MLD	6	28	7.34	11	200	1.47	Complying	Complying
	04.05.2022	06.04.2022	4935 dt. 22.04.2022		7.2	32	8.1	16	400	2.83	Complying	Complying
	09.06.2022	11.05.2022	5406 dt. 25.05.2022	12.80MLD	6.2	44	8.26	11	80	1.43	Complying	Complying
	28.06.2022	03.06.2022	5661 dt. 16.06.2022	13 MLD	8	40	8.32	17	50	0.16	Complying	Complying
	03.08.2022	04.07.2022	6056 dt. 14.07.2022	13.90 MLD	7.2	28	7.5	12	80	1.44	Complying	Complying
	29.08.2022	09.08.2022	6522 dt. 23.08.2022	14.27 MLD	7	40	8.2	13	50	2.89	Complying	Complying
	21.09.2022	02.09.2022	6707 dt. 13.09.2022	14.0 MLD	7.5	24	8.05	8	20	1.06	Complying	Complying
	04.11.2022	10.10.2022	7137 dt. 20.10.2022	15.50 MLD	7.8	44	7.87	15	90	1.12	Complying	Complying
	02.12.2022	18.11.2022	7503 dt. 30.11.2022		7.8	44	7.9	16	80	1.27	Complying	Complying
	27.12.2022	05.12.2022	7710 dt. 20.12.2022		7.8	36	7.58	13	80	ND	Complying	Complying
	18.01.2023	03.01.2023	09 dt. 12.01.2023		8	48	7.56	16	70	1.38	Complying	Complying
	21.02.2023	07.02.2023	386 dt. 17.02.2023		8.5	48	7.29	17	90	1.48	Complying	Complying
	16.03.2023	01.03.2023	722 dt. 14.03.2023		6.8	40	7.14	15	80	0.68	Complying	Complying
	21.04.2023	05.04.2023	1128 dt. 20.04.2023		7.8	36	7.6	15	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	05.06.2023	10.05.2023	1446 dt. 19.05.2023		8	40	7.08	15	80	1.44	Complying	Complying
	17.07.2023	03.07.2023	2099 dt. 12.07.2023		8.2	48	7.1	16	90	ND	Complying	Complying
	25.08.2023	08.08.2023	2450 dt. 18.08.2023		7.6	36	7.14	14	90	ND	Complying	Complying
	19.09.2023	01.09.2023	2736 dt. 12.09.2023		6	32	7.08	12	50	ND	Complying	Complying
	03.11.2023	05.10.2023	3108 dt. 27.10.2023		8	40	7.99	13	80	ND	Complying	Complying
	23.11.2023	03.11.2023	3450 dt. 14.11.2023		7.8	40	7.46	15	80	ND	Complying	Complying
	21.12.2023	04.12.2023	3763 dt. 14.12.2023		8.8	48	7.47	10	70	ND	Complying	Complying
		01.04.2024	14 dt. 09.04.2024		7.2	40	7.36	13	80	0.47	Complying	Complying
		06.05.2024	214 dt. 15.05.2024		5	28	7.34	10	50	ND	Complying	Complying
		19.06.2024	410 dt. 02.07.2024		5.2	28	7.3	11		ND	Complying	Complying
		09.07.2024	581 dt. 22.07.2024		7.6	40	6.96	13		ND	Complying	Complying
		08.08.2024	833 dt. 20.08.2024		7.8	44	7.3	16		ND	Complying	Complying
		05.09.2024	1030 dt 13.09.2024		7.5	40	7.59	15			Complying	Complying
		09.10.2024	1217 dt 16.10.2024		7.6	44	7.38	16			Complying	Complying
		13.11.2024	1435 dt 20.11.2024		6.8	40	7.12	12			Complying	Complying
		04.12.2024	1583 dt 16.12.2024		6.8	40	7.39	12			Complying	Complying
		09.01.2025	1841 dt. 16.01.2025		6.8	44	7.02	13		ND	Complying	Complying
66	(SRS-STP-009) 7.5 MLD STP, Sirsa by HSVP in 31.01.2022	08.08.2023	2447 dt. 18.08.2023		6.8	28	7.24	13	80	ND	Complying	Complying
	25.08.2023	08.08.2023	2452 dt. 18.08.2023		8	40	6.92	15	80	ND	Complying	Complying
	19.09.2023	02.09.2023	2730 dt. 12.09.2023		7.2	36	6.2	10	60	ND	Complying	Complying
	03.11.2023	09.10.2023	3149 dt. 27.10.2023		6.8	36	7.7	11	80	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
68	(FTB-STP-001) 10 MLD STP Vill. Bhodia Khera, Bhattu Road , Fatehabad by PHED in 1.4.2013	18.01.2021	1098-1099 dt. 25.01.2021		23	112	8	34	45000		Complying	Non complying
		03.02.2021	1247-1248 dt. 09.02.2021		25	104	7.9	36	56000		Complying	Non complying
		12.03.2021	1463-1464 dt. 19.03.2021		42	392	8.1	128	72000		Non complying	Non complying
		02.04.2021	11-12 dt. 12.04.2021		28	136	7.9	32	32000		Complying	Non complying
		11.05.2021	173-174 dt. 21.05.2021	3.67	23	104	8.1	38	25000	8.1	Complying	Non complying
		17.06.2021	378-379 dt. 25.06.2021		18	96	7.8	36	28000	7.2	Complying	Non complying
		20.07.2021	637-638 dt. 28.07.2021		56	296	8.1	218	64000	28.6	Non complying	Non complying
	20.09.2021	24.08.2021	899 dt. 07.09.2021	not work	52	272	8.3	204	72000		Non complying	Non complying
	27.09.2021	10.09.2021	950-951 dt. 16.09.2021	8.7	22	104	8.4	48	48000		Non complying	Non complying
	29.10.2021	12.10.2021	1214-1215 dt. 21.10.2021	25.44	24	112	8.4	46	25000		Non complying	Non complying
	20.12.2021	11.11.2021	1383-1384 dt. 24.11.2021	803.27	28	136	10.2	48	28000		Non complying	Non complying
	27.12.2021	09.12.2021	1540-1541 dt. 16.12.2021	6.2	26	128	10.4	42	25000		Non complying	Non complying
	04.02.2022	07.01.2022	1766-1767 dt. 14.01.2022	8.1	24	144	10.2	46	21000		Non complying	Non complying
	04.05.2022	08.04.2022	4980 dt. 28.04.2022	6.80MLD	18	72	7.13	52	800	2.17	Non complying	Non complying
	01.06.2022	06.05.2022	5306 dt. 19.05.2022		8.2	48	7.28	13	80	1.58	Complying	Complying
	05.07.2022	06.06.2022	5675 dt. 20.06.2022	5.8	7	40	2.21	11	80	1.48	Complying	Complying
	05.08.2022	09.07.2022	6141 dt. 18.07.2022	8.20 MLD	8.2	48	7.79	17	90	ND	Complying	Complying
	25.08.2022	04.08.2022	6414 dt. 16.08.2022	8.5	7.5	36	7.88	11	50	0.9	Complying	Complying
	10.10.2022	15.09.2022	6882 dt. 29.09.2022	5.50 MLD	21	108	7.16	58	700	1.86	Non complying	Non complying
	25.10.2022	08.10.2022	7125 dt. 19.10.2022	6.65 MLD	7	16	7.67	48	90	1.26	Complying	Complying
	23.11.2022	08.11.2022	7350 dt. 21.11.2022		7.4	39.6	7.23	13	200	1.08	Non complying	Non complying
	27.12.2022	08.12.2022	7773 dt. 21.12.2022		8	48	7.45	15	80	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	24.01.2023	10.01.2023	70 dt. 20.01.2023		6	28	7.87	11	90	ND	Complying	Complying
	09.03.2023	21.02.2023	580 dt. 01.03.2023		7.6	48	7.3	16	90	ND	Complying	Complying
	22.03.2023	09.03.2023	775 dt. 21.03.2023		7.8	48	6.57	15	90	ND	Complying	Complying
	21.04.2023	05.04.2023	1131 dt. 20.04.2023		7.6	40	6.9	16	70	ND	Complying	Complying
	06.06.2023	17.05.2023	1566 dt. 29.05.2023		7.8	32	6.83	14	90	ND	Complying	Complying
	22.06.2023	03.06.2023	1765 dt. 13.06.2023		7.6	44	7.01	15	90	ND	Complying	Complying
	21.07.2023	06.07.2023	2153 dt. 17.07.2023		8.5	48	7.14	17	90	ND	Complying	Complying
	29.08.2023	14.08.2023	2508 dt. 23.08.2023		9	32	6.94	11	80	ND	Complying	Complying
	19.09.2023	02.09.2023	2741 dt. 13.09.2023		8	36	7.27	16	90	0.38	Complying	Complying
	03.11.2023	12.10.2023	3198 dt. 28.10.2023		7.5	40	6.7	14	90	ND	Complying	Complying
	23.11.2023	06.11.2023	3455 dt. 15.11.2023		7.6	40	7.52	13	80	ND	Complying	Complying
	21.12.2023	04.12.2023	3759 dt. 14.12.2023		7.6	40	7.54	12	60	ND	Complying	Complying
		02.04.2024	29 dt. 10.04.2024		6.2	36	7.1	10	80	ND	Complying	Complying
		06.05.2024	202 dt. 15.05.2024		7	48	7.15	12	80	ND	Complying	Complying
		19.06.2024	416 dt. 02.07.2024		6.5	36	7.3	13		ND	Complying	Complying
		09.07.2024	572 dt. 22.07.2024		7.4	44	6.86	15		ND	Complying	Complying
		8.08.2024	838 dt. 20.08.2024		7	48	6.12	13		ND	Complying	Complying
		05.09.2024	1040 dt. 13.09.2024		8	44	6.18	16			Complying	Complying
		09.10.2024	1222 dt. 16.10.2024		7.2	40	7.26	13			Complying	Complying
		23.11.2024	1510 dt. 10.12.2024		4	28	7.12	10		ND	Complying	Complying
		04.12.2024	1590 dt. 16.12.2024		6.2	36	6.99	11			Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		09.01.2025	1825 dt. 16.01.2025		7	48	8.13	16			Complying	Complying
		06.02.2025	2072 dt. 14.02.2025		7.8	48	6.03	18		ND	Complying	Complying
69	(FTB-STP-002) 10 MLD STP Vill.Amani, Tohana, Distt. Fatehabad by PHED in 1.4.2013	12.01.2021	1059-1060 dt. 20.01.2021		24	104	7.8	32	22000		Complying	Non complying
		13.02.2021	1295-1296 dt. 19.02.2021		25	112	7.9	48	17000		Complying	Non complying
		13.03.2021	1465-1466 dt. 24.03.2021		27	120	8	52	21000		Complying	Non complying
		06.04.2021	25-26 dt. 15.04.2021		26	104	8.1	46	15000		Complying	Non complying
		11.05.2021	169-170 dt. 21.05.2021	2.42	24	112	8.2	42	13000	7.2	Complying	Non complying
		15.06.2021	366-367 dt. 22.06.2021		28	192	9.3	68	21000	12.6	Complying	Non
	16.08.2021	21.07.2021	649-650 dt. 30.07.2021	6.9	22	128	8.1	52	17000	10.8	Complying	Non
	20.09.2021	25.08.2021	902-903 dt. 07.09.2021		24	136	8.4	64	22000		Non	Non
	27.09.2021	10.09.2021	948-949 dt. 16.09.2021		24	136	8.4	64	22000		Non	Non
	29.10.2021	12.10.2021	1218-1219 dt. 21.10.2021	290	22	128	8.3	52	72000		Non	Non
	20.12.2021	11.11.2021	1389-1390 dt. 24.11.2021	7.29	26	168	8.5	78	9600		Non	Non
	27.12.2021	09.12.2021	1536-1537 dt. 16.12.2021	7	24	128	8.4	68	8200		Non	Non
	03.02.2022	07.01.2022	1760-1761 dt. 14.01.2022	6.1	22	184	8.5	78	7200		Non	Non
	15.04.2022	03.03.2022	4400 dt. 17.03.2022		42	144	7.54	118	1200	9.97	Non	Non
	04.05.2022	08.04.2022	4976 dt. 28.04.2022		26	112	7.4	34	900	3.49	Non	Non
	01.06.2022	06.05.2022	5303 dt. 19.05.2022		14	76	7.44	33	300	1.93	Non	Non
	05.07.2022	06.06.2022	5677 dt. 20.06.2022		7.5	48	7.6	15	80	2.92	Complying	Complying
	05.08.2022	09.07.2022	6145 dt. 18.07.2022	5.8 MLD	7.6	40	7.89	11	50	ND	Complying	Complying
	25.08.2022	07.08.2022	6447 dt. 22.08.2022	6.50 MLD	8	48	7.44	17	80	1.95	Complying	Complying
	10.10.2022	15.09.2022	6880 dt. 29.09.2022	6.40 MLD	15	68	7.09	28	600	2.86	Non	Non
	04.11.2022	10.10.2022	7141 dt. 20.10.2022	6.50 MLD	16	72	6.46	36	600	2.58	Non	Non
	02.12.2022	15.11.2022	7473 dt. 29.11.2022		16	72	7.23	38	700	1.32	Non complying	Non complying
	05.01.2023	14.12.2022	7919 dt. 26.12.2022		5.2	24	7.42	8	70	1.82	Complying	Complying
	24.01.2023	10.01.2023	75 dt. 20.01.2023		8.6	48	7.4	18	90	ND	Complying	Complying
	09.03.2023	22.02.2023	583 dt. 01.03.2023		7.6	36	7	14	80	ND	Complying	Complying
	22.03.2023	09.03.2023	782 dt. 21.03.2023		7.5	48	8.6	15	90	1.05	Complying	Complying
	18.04.2023	03.04.2023	1104 dt. 13.04.2023		7.6	44	6.95	15	70	1.04	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
70	(FTB-STP-003) 6.5 MLD STP Ratia , Fatehabad by PHED in 1.9.2014 (MBBR)	12.01.2021	1063-1064 dt. 20.01.2021		25	112	8.1	34	32000		Complying	Non complying
		13.02.2021	1299-1300 dt. 19.02.2021		22	96	8	32	22000		Complying	Non complying
		13.03.2021	1467-1468 dt. 24.03.2021		20	96	8.1	35	15000		Complying	Non complying
		06.04.2021	29-30 dt. 15.04.2021		24	104	8	38	17000		Complying	Non complying
		11.05.2021	179-180 dt. 21.05.2021		22	96	7.8	32	21000	8.7	Complying	Non complying
		05.06.2021	304-305 dt. 14.06.2021		20	112	7.4	42	15000	8.4	Complying	Non complying
	16.08.2021	21.07.2021	647-648 dt. 30.07.2021		18	96	7.6	34	11000	7.8	Complying	Non complying
	2.09.2021	20.08.2021	881-882 dt. 27.08.2021		16	80	7.4	46	9000	8.2	Non complying	Non complying
	27.09.2021	10.09.2021	946-947 dt. 16.09.2021		18	88	7.6	42	8200		Non complying	Non complying
	29.10.2021	12.10.2021	1220-1221 dt. 21.10.2021	Not Work	26	104	8.4	58	32000		Non complying	Non complying
	20.12.2021	11.11.2021	1387-1388 dt. 24.11.2021	4.09	22	96	8.1	62	6400		Non complying	Non complying
	27.12.2021	09.12.2021	1544-1545 dt. 16.12.2021	4.1	20	88	7.8	46	6200		Non complying	Non complying
	04.02.2022	07.01.2022	1762-1763 dt. 14.01.2022	4.36	8.4	48	7.5	16	90		Complying	Complying
	15.04.2022	03.03.2022	4399 dt. 17.03.2022	4.7 MLD	8	48	7.28	16	90	1.67	Complying	Complying
	04.05.2022	08.04.2022	4978 dt. 28.04.2022	4.15MLD	7.8	44	7.63	17	70	2.26	Complying	Complying
	31.05.2022	02.05.2022	5269 dt. 17.05.2022		7	48	7.6	15	50	1.04	Complying	Complying
	28.06.2022	06.06.2022	5673 dt. 20.06.2022	5.00 MLD	8	48	7.46	14	70	7.48	Complying	Complying
	05.08.2022	09.07.2022	6142 dt. 18.07.2022	4.1 MLD	7.8	40	7.82	15	80	ND	Complying	Complying
	25.08.2022	07.08.2022	6441 dt. 22.08.2022	4.30 MLD	7	28	7.17	14	80	1.41	Complying	Complying
	10.10.2022	15.09.2022	6879 dt. 29.09.2022	4.4	16	80	7.43	24	400	2.36	Non complying	Non complying
	25.10.2022	08.10.2022	7121 dt. 19.10.2022	4.30 MLD	7.5	44	7.08	15	90	1.28	Complying	Complying
	02.12.2022	15.11.2022	7472 dt. 29.11.2022	5.5 MLD	7	48	7.48	16	60	1.23	Complying	Complying
	27.12.2022	08.12.2022	7770 dt. 21.12.2022		7.8	48	7.5	15	90	1.46	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
71	(FTB-STP-004) 10 MLD STP Majra, Fatehabad by HUDA in 16.12.17	18.01.2021	1094-1095 dt. 25.01.2021		5	32	7.7	9	86		Complying	Complying
		03.02.2021	1251-1252 dt. 09.02.2021		6	32	7.9	10	90		Complying	Complying
		12.03.2021	1459-1460 dt. 19.03.2021		72	48	8	14	120		Non complying	Non complying
		06.04.2021	31-32 dt. 15.04.2021		8	32	7.8	9	90		Complying	Complying
		11.05.2021	197-198 dt. 21.05.2021		6.9	32	7.2	9	1300	1.4	Complying	Complying
		11.05.2021	171-172 dt. 21.05.2021	2.2	7.6	40	7.9	16	80	1.9	Complying	Complying
		05.06.2021	306-307 dt. 14.06.2021		6.8	32	7.9	10	55	2.1	Complying	Complying
		20.07.2021	639-640 dt. 28.07.2021	2	9.4	48	8.1	16	720	3.4	Complying	Complying
		21.08.2021	883-884 dt. 27.08.2021		9	40	7.8	18	860	3.6	Complying	Complying
	27.09.2021	10.09.2021	952-953 dt. 16.09.2021	769	7.6	32	7.6	14	900		Complying	Complying
	29.10.2021	12.10.2021	1222-1223 dt. 21.10.2021	563.3	7.2	40	7.5	12	2500		Complying	Complying
	20.12.2021	11.11.2021	1385-1386 dt. 24.11.2021	51.9	7.5	48	7.6	18	90		Complying	Complying
	27.12.2021	09.12.2021	1542-1543 dt. 16.12.2021	2.2	6.9	24	7.8	12	64		Complying	Complying
	04.02.2022	07.01.2022	1768-1769 dt. 14.01.2022	2.2	7.2	24	7.6	10	84		Complying	Complying
	15.04.2022	03.03.2022	4397 dt. 17.03.2022	2.3 MLD	6	46	7.51	18	90	1.02	Complying	Complying
	04.05.2022	08.04.2022	4981 dt. 28.04.2022	2.0MLD	7.2	40	6.93	17	60	2.11	Complying	Complying
	01.06.2022	06.05.2022	5304 dt. 19.05.2022		7.8	48	7.98	17	80	1.95	Complying	Complying
	28.06.2022	06.06.2022	5672 dt. 20.06.2022	2.10 MLD	8.2	48	7.88	18	50	1.46	Complying	Complying
	05.08.2022	09.07.2022	6143 dt. 18.07.2022	2.5 MLD	6	28	7.95	9	70	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	25.08.2022	04.08.2022	6415 dt. 16.08.2022	2.60 MLD	7.5	40	7.79	15	70	1.32	Complying	Complying
	10.10.2022	15.09.2022	6884 dt. 29.09.2022	2.0 MLD	15	72	8.16	32	400	3.56	Non complying	Non complying
	25.10.2022	08.10.2022	7124 dt. 19.10.2022	2.2 MLD	6.2	28	7.88	12	90	0.92	Complying	Complying
	23.11.2022	08.11.2022	7349 dt. 21.11.2022		7	36	7.68	11	80	1.24	Complying	Complying
	27.12.2022	08.12.2022	7771 dt. 21.12.2022		8.2	44	7.53	17	80	1.29	Complying	Complying
	24.01.2023	10.01.2023	72 dt. 20.01.2023		8	44	6.75	15	80	ND	Complying	Complying
	09.03.2023	21.02.2023	578 dt. 01.03.2023		8	44	7.6	13	90	ND	Complying	Complying
	24.03.2023	09.03.2023	777 dt. 21.03.2023		7.4	40	7.37	13	80	ND	Complying	Complying
	18.04.2023	03.04.2023	1105 dt. 13.04.2023		7.2	40	7.39	14	80	ND	Complying	Complying
	06.06.2023	17.05.2023	1563 dt. 29.05.2023		7.6	40	7.12	16		ND	Complying	Complying
	22.06.2023	03.06.2023	1763 dt. 13.06.2023		7	32	7.18	13	80	ND	Complying	Complying
	21.07.2023	06.07.2023	2148 dt. 17.07.2023		7.8	44	7.15	12	80	ND	Complying	Complying
	29.08.2023	14.08.2023	2509 dt. 23.08.2023		8.2	40	6.82	13	60	0.34	Complying	Complying
	19.09.2023	02.09.2023	2744 dt. 13.09.2023		7.5	32	7.15	14	80	0.28	Complying	Complying
	03.11.2023	09.10.2023	3153 dt. 27.10.2023		7.8	44	7.34	15	90	ND	Complying	Complying
	23.11.2023	06.11.2023	3456 dt. 15.11.2023		8.2	44	7.58	15	90	ND	Complying	Complying
	21.12.2023	04.12.2023	3761 dt. 14.12.2023		7.8	40	7.4	14	70	ND	Complying	Complying
		02.04.2024	32 dt. 10.04.2024		6	564	7.42	219	60	ND	Complying	Complying
		06.05.2024	206 dt. 15.05.2024		5.8	32	6.95	10	60	ND	Complying	Complying
		19.06.2024	419 dt. 02.07.2024		6	32	7.58	14		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		09.07.2024	570 dt. 22.07.2024		7.2	44	6.98	15		1.08	Complying	Complying
		8.08.2024	843 dt. 20.08.2024		6.5	36	7.15	13		ND	Complying	Complying
		05.09.2024	1037 dt. 13.09.2024		7.2	40	7.36	13			Complying	Complying
		09.10.2024	1227 dt. 16.10.2024		7.4	44	7.56	15			Complying	Complying
		23.11.2024	1504 dt. 10.12.2024		6.2	36	7.09	11		ND	Complying	Complying
		04.12.2024	1593 dt. 16.12.2024		6.8	40	6.78	11			Complying	Complying
		09.01.2025	1828 dt. 16.01.2025		7.6	48	6.57	17			Complying	Complying
		06.02.2025	2070 dt. 14.02.2025		7.2	36	7.03	12		ND	Complying	Complying
72	(FTB-STP-005) 5 MLD STP Kharati Khera Road, Fatehabad by PHED in 31.10.2018	18.01.2021	1096-1097 dt. 25.01.2021		6	24	7.8	8	800		Complying	Complying
		03.02.2021	1249-1250 dt. 09.02.2021		8	16	7.7	10	1100		Complying	Complying
		12.03.2021	1461-1462 dt. 19.03.2021		8.4	24	7.6	9	720		Complying	Complying
		02.04.2021	13-14 dt. 12.04.2021		7.9	24	7.5	8	350		Complying	Complying
		11.05.2021	175-176 dt. 21.05.2021		7.1	24	7.2	8	280	2.5	Complying	Complying
		05.06.2021	302-303 dt. 14.06.2021		6.2	32	6.8	8	90	2.4	Complying	Complying
		20.07.2021	641-642 dt. 28.07.2021		6.8	40	7.4	14	78	2.6	Complying	Complying
		21.08.2021	887-888 dt. 27.08.2021		7.5	32	7.7	10	45	2.4	Complying	Complying
	27.09.2021	10.09.2021	942-943 dt. 16.09.2021		7	32	8	14	58		Complying	Complying
	29.10.2021	12.10.2021	1212-1213 dt. 21.10.2021	504.3	6.2	24	8	10	43		Complying	Complying
	20.12.2021	11.11.2021	1381-1382 dt. 24.11.2021	1.2	6.8	24	8.1	12	45		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	27.12.2021	09.12.2021	1538-1539 dt. 16.12.2021	No Flow	6.4	36	8.2	10	56		Complying	Complying
	04.02.2022	07.01.2022	1764-1765 dt. 14.01.2022	2.5	6.8	24	8.1	9	74		Complying	Complying
	15.04.2022	03.03.2022	4395 dt. 17.03.2022	2.20 MLD	5	44	7.04	14	70	1.59	Complying	Complying
	04.05.2022	08.04.2022	4979 dt. 28.04.2022	2.70MLD	7.6	48	7.53	15	600	1.88	Complying	Complying
	31.05.2022	02.05.2022	5265 dt. 17.05.2022		7.5	44	7.86	15	60	0.25	Complying	Complying
	05.07.2022	07.06.2022	5674 dt. 20.06.2022	2.0 MLD	7.6	44	8.17	16	80	1.34	Complying	Complying
	05.08.2022	09.07.2022	6144 dt. 18.07.2022	2.80 MLD	7.5	44	8.02	13	90	ND	Complying	Complying
	25.08.2022	04.08.2022	6416 dt. 16.08.2022	2.65	6	32	8.07	12	80	1.06	Complying	Complying
	10.10.2022	15.09.2022	6886 dt. 29.09.2022	3.72 MLD	7.6	44	7.68	15	90	1.03	Complying	Complying
	25.10.2022	08.10.2022	7122 dt. 19.10.2022	2.4 MLD	7.8	36	7.24	14	70	1.87	Complying	Complying
	23.11.2022	08.11.2022	7348 dt. 21.11.2022		5.2	18	7	9	90	1.22	Complying	Complying
	27.12.2022	08.12.2022	7772 dt. 21.12.2022		7.6	40	7.34	14	70	1.72	Complying	Complying
	24.01.2023	10.01.2023	73 dt. 20.01.2023		7.8	32	7.18	13	70	ND	Complying	Complying
	09.03.2023	21.02.2023	581 dt. 01.03.2023		7.8	40	7.23	16	80	ND	Complying	Complying
	24.03.2023	09.03.2023	776 dt. 21.03.2023		7.6	44	7.52	14	90	1.27	Complying	Complying
	21.04.2023	05.04.2023	1130 dt. 20.04.2023		6.2	32	6.85	14	80	ND	Complying	Complying
	06.06.2023	17.05.2023	1564 dt. 29.05.2023		7.8	44	6.86	15	80	ND	Complying	Complying
	22.06.2023	03.06.2023	1764 dt. 13.06.2023		7.2	36	7.13	14	90	ND	Complying	Complying
	21.07.2023	06.07.2023	2150 dt. 17.07.2023		8.5	48	6.74	16	80	ND	Complying	Complying
	29.08.2023	14.08.2023	2511 dt. 23.08.2023		5.6	24	6.29	11	50	ND	Complying	Complying
	19.09.2023	02.09.2023	2745 dt. 13.09.2023		7.2	36	7.19	15	70	0.72	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	03.11.2023	12.10.2023	3197 dt. 28.10.2023		7	36	6.8	15	90	ND	Complying	Complying
	23.11.2023	06.11.2023	3457 dt. 15.11.2023		6.8	40	7.82	12	60	ND	Complying	Complying
	21.12.2023	04.12.2023	3760 dt. 14.12.2023		9	48	7.18	12	80	ND	Complying	Complying
		02.04.2024	33 dt. 10.04.2024		5	28	7.09	10	40	ND	Complying	Complying
		06.05.2024	205 dt. 15.05.2024		7.6	44	7.11	10	70	ND	Complying	Complying
		19.06.2024	420 dt. 02.07.2024		6.6	40	7.1	13		0.93	Complying	Complying
		09.07.2024	569 dt. 22.07.2024		6.2	32	6.75	13		ND	Complying	Complying
		8.08.2024	839 dt. 20.08.2024		8	48	6.89	17		0.72	Complying	Complying
		05.09.2024	1041 dt. 13.09.2024		7.8	48	6.78	16			Complying	Complying
		09.10.2024	1223 dt. 16.10.2024		6.8	48	7.85	13			Complying	Complying
		23.11.2024	1507 dt. 10.12.2024		6.2	40	6.53	12		ND	Complying	Complying
		04.12.2024	1594 dt. 16.12.2024		6.8	44	6.74	13			Complying	Complying
		09.01.2025	1829 dt. 16.01.2025		7.2	40	6.42	13			Complying	Complying
		06.02.2025	2071 dt. 14.02.2025		7.6	44	6.49	14		ND	Complying	Complying
73	(FTB-STP-006) 3 MLD STPJhakhal Mandi, Kasimpur Road, Fatehabad by PHED in 31.12.2019	12.01.2021	1061-1062 dt. 20.01.2021		8	32	7.7	10	90		Complying	Complying
		13.02.2021	1297-1298 dt. 19.02.2021		9	24	7.6	12	150		Complying	Complying
		13.03.2021	1469-1470 dt. 24.03.2021		8.9	32	7.8	9	220		Complying	Complying
		06.04.2021	27-28 dt. 15.04.2021		8.2	24	7.6	8	140		Complying	Complying
		11.05.2021	177-178 dt. 21.05.2021	1.6	8.6	32	8.2	10	180	2.6	Complying	Complying
		15.06.2021	368-369 dt. 22.06.2021		9.4	56	9.2	24	2500	3.1	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	16.08.2021	21.07.2021	645-646 dt. 30.07.2021	2.6	9	40	8.2	16	180	24	Complying	Complying
		21.08.2021	885-886 dt. 27.08.2021		8	32	7.8	12	210	2.1	Complying	Complying
	27.09.2021	10.09.2021	944-945 dt. 16.09.2021		8.2	40	7.4	10	250		Complying	Complying
	29.10.2021	12.10.2021	1216-1217 dt. 21.10.2021	80.2	7.8	32	7.5	12	90		Complying	Complying
	20.12.2021	11.11.2021	1391-1392 dt. 24.11.2021	184.22	9.5	48	7.4	16	98		Complying	Complying
	27.12.2021	09.12.2021	1534-1535 dt. 16.12.2021	1	9.2	40	7.6	12	84		Complying	Complying
	03.02.2022	07.01.2022	1758-1759 dt. 14.01.2022	1	8.8	48	7.5	18	77		Complying	Complying
	15.04.2022	03.03.2022	4398 dt. 17.03.2022	1.10 MLD	4	46	7.84	14	80	0.56	Complying	Complying
	04.05.2022	08.04.2022	4977 dt. 28.04.2022	1.1MLD	7.5	44	7.37	18	90	1.02	Complying	Complying
	31.05.2022	02.05.2022	5268 dt. 17.05.2022		6.8	44	7.96	13	60	1.41	Complying	Complying
	05.07.2022	07.06.2022	5676 dt. 20.06.2022	1.35 MLD	8	44	7.36	17	90	2.36	Complying	Complying
	05.08.2022	09.07.2022	6146 dt. 18.07.2022	1.1 MLD	8.2	48	7.7	15	50	1.47	Complying	Complying
	25.08.2022	07.08.2022	6445 dt. 22.08.2022	1.75 MLD	6	24	7.64	12	50		Complying	Complying
	10.10.2022	15.09.2022	6883 dt. 29.09.2022	2.0 MLD	14	68	7.51	31	400	1.86	Non complying	Non complying
	25.10.2022	08.10.2022	7123 dt. 19.10.2022	1.30 MLD	7	40	7.18	14	80	1.22	Complying	Complying
	02.12.2022	15.11.2022	7471 dt. 29.11.2022	2 MLD	8	46	7.6	18	90	1.22	Complying	Complying
	05.01.2023	14.12.2022	7918 dt. 26.12.2022		8.2	48	7.19	18	90	2.24	Complying	Complying
	24.01.2023	10.01.2023	74 dt. 20.01.2023		7.5	36	7.58	14	90	1.12	Complying	Complying
	09.03.2023	21.02.2023	579 dt. 01.03.2023		7.5	40	7.02	17	80	ND	Complying	Complying
	22.03.2023	09.03.2023	771 dt. 21.03.2023		7.8	36	7.92	13	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
74	(FTB-STP-007) 8 MLD STP at Bhuna, Fatehabad by PHED dt. 30.06.2021	02.04.2024	35 dt. 10.04.2024		7.6	40	7.41	12	80	ND	Complying	Complying
		06.05.2024	203 dt. 15.05.2024		6	40	7.25	13	60	ND	Complying	Complying
		19.06.2024	422 dt. 02.07.2024		6.4	36	7.47	15		ND	Complying	Complying
		09.07.2024	568 dt. 22.07.2024		6.89	36	6.13	12		1.02	Complying	Complying
		8.08.2024	842 dt. 20.08.2024		7.6	40	6.64	15		ND	Complying	Complying
		05.09.2024	1035 dt. 13.09.2024		6.5	36	6.7	12			Complying	Complying
		09.10.2024	1224 dt. 16.10.2024		7.2	40	7.38	13			Complying	Complying
		23.11.2024	1508 dt. 10.12.2024		8.6	48	7.13	15		1.36	Complying	Complying
		04.12.2024	1596 dt. 16.12.2024		7.5	44	7.15	13			Complying	Complying
		09.01.2025	1831 dt. 16.01.2025		7.5	44	6.87	15			Complying	Complying
		07.02.2025	2074 dt. 14.02.2025		27	152	6.8	72		ND	non complying	non complying
Other Catchment												
	Bhiwani/Charkhi Dadri											
1	(BHI-STP-001) 10 MLD STP Dhana Road , Bhiwani by PHED in 16.6.2013 (MBBR)	12.03.2021	1455-1456 dt. 19.03.2021		52	176	8.1	124	120000		Non complying	Non complying
		17.05.2021	183-184 dt. 21.05.2021		21	64	8.1	26	56000	6.2	Complying	Non complying
	28.10.2021	28.09.2021	1052-1053 dt. 6.10.2021	9.3	18	72	8.4	28	38000		Non complying	Non complying
	02.02.2022	29.12.2021	1666-1667 dt. 06.01.2021		20	112	8	32	21000		Non complying	Non complying
	15.04.2022	29.03.2022	4743 dt. 07.04.2022		27	164	7	53	800	2.36	Non complying	Non complying
		27.09.2022	685 dt. 04.10.2022		55	208	7.1	152	1400	8.5	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	30.12.2022	19.12.2022	1433 dt. 28.12.2022		68	276.3	7.8	172	1700	9.3	Non complying	Non complying
	24.03.2023	06.03.2023	2118 dt. 14.03.2023		75	323.2	7.6	220	2700	10.8	Non complying	Non complying
	22.06.2023	06.06.2023	298 dt. 14.06.2023		16	80.3	7.3	25	550	2.5	Non complying	Non complying
	17.10.2023	28.09.2023	1212 dt. 09.10.2023		18	104	7.9	29	460	1.8	Non complying	Non complying
	20.12.2023	06.12.2023	1488 dt. 13.12.2023		27	136	7.6	48	630	2.4	Non complying	Non complying
		20.06.2024	351 dt. 28.06.2024		19	84	7.83	31	410	5.6	Non complying	Non complying
		20.07.2024	843 dt. 30.07.2024		16	72	7.19	26	530	8.4	Non complying	Non complying
2	(BHI-STP-002) 10 MLD STP , Bhiwani by PHED in 24.3.2014 (MBBR)	12.03.2021	1457-1458 dt. 19.03.2021		68	208	8.3	142	96000		Non complying	Non complying
		17.05.2021	185-186 dt. 21.05.2021		25	96	8.2	38	42000	7.6	Complying	Non complying
	28.10.2021	28.09.2021	1054-1055 dt. 6.10.2021	9.12	20	88	7.9	26	25000		Non complying	Non complying
	02.02.2022	29.12.2021	1668-1669 dt. 06.01.2021		21	104	8.2	28	21000		Non complying	Non complying
		27.09.2022	684 dt. 04.10.2022		68	272	7.2	178	1500	7.6	Non complying	Non complying
	30.12.2022	19.12.2022	1432 dt. 28.12.2022		78	321.5	7.6	185	1800	8.4	Non complying	Non complying
	24.03.2023	06.03.2023	2119 dt. 14.03.2023		82	371.6	7.3	245	2100	9.6	Non complying	Non complying
	22.06.2023	06.06.2023	297 dt. 14.06.2023		96	413.6	7.8	218	2700	9.3	Non complying	Non complying
	17.10.2023	28.09.2023	1215 dt. 09.10.2023		125	496	7.4	318	3600	12.8	Non complying	Non complying
	20.12.2023	06.12.2023	1487 dt. 13.12.2023		104	416	7.3	282	4200	16.9	Non complying	Non complying
		20.06.2024	349 dt. 28.06.2024		92	368	7.95	185	1700	9.8	Non complying	Non complying
		20.07.2024	842 dt. 30.07.2024		72	312	8.42	165	1500	11.2	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
3	(BHI-STP-003) 15 MLD Phase-II, Bhiwani by PHED in 1.6.2014	03.03.2021	1403-1404 dt. 12.03.2021		9.1	32	8.3	11	2800		Complying	Complying
		16.06.2021	372-373 dt. 23.06.2021		7	24	8.1	9	2500	2.1	Complying	Complying
	20.09.2021	24.08.2021	900-901 dt. 2.09.2021	347	7.2	32	8	10	1800	0.6	Complying	Complying
	02.02.2022	29.12.2021	1672-1673 dt. 06.01.2021		6.8	16	7.8	8	94		Complying	Complying
	15.04.2022	29.03.2022	4745 dt. 07.04.2022	8.9 MLD	8.2	48	6.86	11	90	2.12	Complying	Complying
	12.07.2022	29.06.2022	87 dt. 07.07.2022		17	80	7.3	28	130		Non complying	Non complying
		27.09.2022	692 dt. 04.10.2022		15	64	7.5	37	180	2.2	Non complying	Non complying
	30.12.2022	19.12.2022	1430 dt. 28.12.2022		7	42.6	7.2	16	90	1.8	Complying	Complying
	24.03.2023	06.03.2023	2117 dt. 14.03.2023		8	45.3	7.1	13	77	1.4	Complying	Complying
	22.06.2023	06.06.2023	300 dt. 14.06.2023		7	40.1	7.5	16	85	2.3	Complying	Complying
	17.10.2023	28.09.2023	1218 dt. 09.10.2023		104	432	7.2	246	390	5.8	Non complying	Non complying
	20.12.2023	06.12.2023	1491 dt. 13.12.2023		132	528	7.3	320	1200	9.2	Non complying	Non complying
		26.07.2024	924 dt. 05.08.2024		5	40	7.43	17	79	8.4	Complying	Complying
4	(BHI-STP-004) 15 MLD Phase-I, Bhiwani by PHED in 1.10.2013	03.03.2021	1413-1414 dt. 12.03.2021	1420	6	24	8.1	7	2500		Complying	Complying
		16.06.2021	370-371 dt. 23.06.2021		8	32	8.2	10	2100	2.8	Complying	Complying
	28.10.2021	28.09.2021	1056-1057 dt. 6.10.2021	9.72	7.2	24	7.8	10	1800		Complying	Complying
	02.02.2022	29.12.2021	1670-1671 dt. 06.01.2021	10.3	6.4	32	8.2	10	90		Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	15.04.2022	29.03.2022	4747 dt. 07.04.2022	8 MLD	7.6	44	7	18	60	2.36	Complying	Complying
	09.07.2022	29.06.2022	86 dt. 07.07.2022		8	40	7.3	38	70		Complying	Complying
		27.09.2022	683 dt. 04.10.2022		7	36	7.4	35	90	2.6	Complying	Complying
	30.12.2022	19.12.2022	1434 dt. 28.12.2022		65	269.2	7.7	210	2900	10.4	Non complying	Non complying
	24.03.2023	06.03.2023	2116 dt. 14.03.2023		9	41.2	7.2	17	700	4.5	Non complying	Non complying
	22.06.2023	06.06.2023	299 dt. 14.06.2023		8	48.1	7.5	18	93	3.3	Complying	Complying
	17.10.2023	29.09.2023	1219 dt. 09.10.2023		7	44	7.1	19	80	2.5	Complying	Complying
	20.12.2023	06.12.2023	1491 dt. 13.12.2023		6	36	7.2	17	60	1.7	Complying	Complying
		26.07.2024	925 dt. 05.08.2024		7	44	7.6	16	63	4.2	Complying	Complying
5	(BHI-STP-005) 10 MLD Bhiwani by HUDA in 1.1.2015 (SBR)	24.03.2021	1530-1531 dt. 02.04.2021		6.8	32	7.8	9	1200		Complying	Complying
		11.06.2021	358-359 dt. 18.06.2021		7	32	7.9	10	1100	1.8	Complying	Complying
	29.10.2021	30.09.2021	1107-1108 dt. 08.10.2021	Not Work	6.4	32	7.8	10	900		Complying	Complying
	03.02.2022	30.12.2021	1678-1679 dt. 06.01.2021	0.67	6.2	32	7.9	10	77		Complying	Complying
	15.04.2022	29.03.2022	4746 dt. 07.04.2022	4 MLD	7.8	36	7.06	9	90	2.48	Complying	Complying
	19.07.2022	30.06.2022	93 dt. 08.07.2022		8	44	6.8	17	80	3.2	Complying	Complying
		28.09.2022	711 dt. 07.10.2022	0.8	6	36	7.6	15	60	2.5	Complying	Complying
	30.12.2022	19.12.2022	1431 dt. 28.12.2022		7	39.2	7.2	13	70	2.1	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	Mar, 2024	19.03.2024	2278 dt 27.03.2024		80	320	8.14	126	710	11.76	Non-Complying	Non-Complying
		02.07.2024	496 dt 15.07.2024		68	276	7.16	150	4700	12.02	Non-Complying	Non-Complying
		17.09.2024	1365 dt 25.09.2024		52	268	7.76	105	2100	11.2	Non-Complying	Non-Complying
		23.10.2024	1611 dt 30.10.2024		48	240	7.42	120	1700	14.01	Non-Complying	Non-Complying
		31.12.2024	531 15.01.2025		42	208	7.48	105	1400	12.6	Non-Complying	Non-Complying
		23.01.2025	2241 dt 29.01.2025		68	280.5	7.36	115	2100	15.61	Non-Complying	Non-Complying
		27.02.2025	2527 dt 10.03.2025		75	314.4	7.69	120	1700	14.01	Non-Complying	Non-Complying
8	(BHI-STP-008) 4.5 MLD STP Bawani Khera by PHED in 31.12.2015	30.03.2021	1546-1547 dt. 02.04.2021	2.1	22	104	7.4	48	45000		Complying	Non-Complying
		18.06.2021	382-383 dt. 25.06.2021		24	112	7.1	58	42000		Complying	Non-Complying
	28.10.2021	28.09.2021	1060-1061 dt. 6.10.2021	2.1	25	128	6.8	64	60000		Non-Complying	Non-Complying
	03.02.2022	30.12.2021	1676-1677 dt. 06.01.2021	3	22	120	7.8	54	42000		Non-Complying	Non-Complying
	15.04.2022	29.03.2022	4744 dt. 07.04.2022		13	56	7.01	25	300	1.67	Non-Complying	Non-Complying
	09.07.2022	29.06.2022	83 dt. 07.07.2022		28	120	7.8	35	1200	2.9	Non-Complying	Non-Complying
	29.09.2022	19.09.2022	653 dt. 28.09.2022		27	128	7.3	56	1300	3.2	Non-Complying	Non-Complying
	16.01.2023	29.12.2022	1547 dt. 09.01.2023		28	162.3	7.5	65	1700	3.5	Non-Complying	Non-Complying
	08.04.2023	24.03.2023	2289 dt. 05.04.2023		82	332.6	7.4	120	1400	3.9	Non-Complying	Non-Complying
	22.06.2023	07.06.2023	308 dt. 15.06.2023		19	105.4	7.3	36	550	2.1	Non-Complying	Non-Complying
	17.10.2023	28.09.2023	1214 dt. 09.10.2023		17	80	7	42	690	1.8	Non-Complying	Non-Complying
	08.01.2024	20.12.2023	1575 dt. 28.12.2023		16	92	7.1	30	360	1.4	Non-Complying	Non-Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
10	(BHI-STP-010) 3 MLD STP Tosham, Bhiwani by PHED on 01.07.2014	11.03.2021	1451-1452 dt. 18.03.2021	1.5	9	72	8	14	72000		Complying	Complying
		29.06.2021	449-450 dt. 07.07.2021		7	48	7.9	9	35000	2.6	Complying	Complying
	20.09.2021	31.08.2021	908-909 dt. 07.09.2021	Not Work	7	32	8	12	12000	BDL	Complying	Complying
	03.02.2022	30.12.2021	1674-1675 dt. 06.01.2021		6.4	40	8	12	90		Complying	Complying
	15.04.2022	29.03.2022	4742 dt. 07.04.2022		7.8	36	7.06	14	80	2.48	Complying	Complying
	09.07.2022	29.06.2022	85 dt. 07.07.2022		9	44	7.2	18	90		Complying	Complying
	29.09.2022	19.09.2022	655 dt. 28.09.2022		11	52	7.4	16	300	6.9	Non Complying	Non Complying
	16.01.2023	29.12.2022	1546 dt. 09.01.2023		9	48.4	7.1	15	77		Complying	Complying
	08.04.2023	24.03.2023	2288 dt. 05.04.2023		9	48.4	7.4	18	90		Complying	Complying
	22.06.2023	06.06.2023	296 dt. 14.06.2023		7	36.3	7.1	16	83		Complying	Complying
	17.10.2023	28.09.2023	1213 dt. 09.10.2023		8	44	7.5	19	80	BDL	Complying	Complying
	08.01.2024	20.12.2023	1574 dt. 28.12.2023		9	48	7.2	17	93	1.3	Complying	Complying
		18.06.2024	336 dt. 25.06.2024		9	44	7.58	18	63	4.2	Complying	Complying
		19.07.2024	814 dt. 29.07.2024		7	40	7.43	16	79	5.6	Complying	Complying
11	(BHI-STP-011) 4 MLD STP Siwani Bhiwani by PHED in 9.9.2014	03.03.2021	1405-1406 dt. 12.03.2021		12	64	8.1	44	96000		Complying	Non Complying
		30.06.2021	459-460 dt. 07.07.2021		16	72	8	32	80000	4.8	Non Complying	Non Complying
	29.10.2021	30.09.2021	1105-1106 dt. 08.10.2021	3.2	22	96	8.1	38	48000		Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	03.02.2022	31.12.2021	1698-1699 dt. 07.01.2021		20	88	7.6	28	39000		Non Complying	Non Complying
		31.03.2022	4799 dt. 13.04.2022	2.7 MLD	14	68	7.57	29	300	2.18	Non Complying	Non Complying
	05.07.2022	24.06.2022	65 dt. 04.07.2022		45	176	7.1	64	1600		Non Complying	Non Complying
	29.09.2022	19.09.2022	656 dt. 28.09.2022		26	112	7.5	42	1300	4.2	Non Complying	Non Complying
	19.01.2023	30.12.2022	1559 dt. 10.01.2023		26	132.7	7.2	78	1900	5.4	Non Complying	Non Complying
	08.04.2023	24.03.2023	2286 dt. 05.04.2023		21	108.5	7.6	35	750	3.6	Non Complying	Non Complying
	22.06.2023	07.06.2023	307 dt. 15.06.2023		22	117.1	7.3	41	630	3.2	Non Complying	Non Complying
	17.10.2023	28.09.2023	1211 dt. 09.10.2023		17	96	7.1	32	520	4.6	Non Complying	Non Complying
	08.01.2024	20.12.2023	1573 dt. 28.12.2023		15	80	7.3	39	540	2.9	Non Complying	Non Complying
		18.06.2024	338 dt. 25.06.2024		52	276	8.08	145	930	7	Non Complying	Non Complying
		19.07.2024	817 dt. 29.07.2024		58	312	8.84	180	1300	5.6	Non Complying	Non Complying
	Mohindergarh											
12	(MHD-STP-001) 6.5 MLD STP, Dulana Road, Mohindergarh by PHED in 1.9.2014	20.02.2021	2014-2015 dt. 26.02.2021	3	20	112	7.1	53	97000		Complying	Non Complying
		29.06.2021	253-254 dt. 05.07.2021	2.8	17	108	7.4	45	72000		Complying	Non Complying
		28.09.2021	907-908 dt. 04.10.2021	3.9	21	116	7.7	59	64000	7.8	Non Complying	Non Complying
	21.01.2022	30.12.2021	3539 dt. 10.01.2022		7.6	44	7.92	12	40	1.99	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	15.04.2022	30.03.2022	4797 dt. 08.04.2022		7.5	48	7.38	16	40	1.41	Complying	Complying
	13.07.2022	01.07.2022	130 dt. 11.07.2022		46	184	7.8	52	1300	4.2	Non Complying	Non Complying
	07.01.2023	27.12.2022	1493 dt. 04.01.2023		76	297.2	7.1	82	4600	8.2	Non Complying	Non Complying
	08.04.2023	28.03.2023	2334 dt. 07.04.2023		19	88.2	7.9	42	1300	4.7	Non Complying	Non Complying
	15.07.2023	27.06.2023	419 dt. 05.07.2023		20	96.9	7.7	36	900	4.2	Non Complying	Non Complying
	02.11.2023	29.09.2023	1230 dt. 19.10.2023		20	96.9	7.7	36	900	4.2	Non Complying	Non Complying
	10.01.2024	29.12.2023	1644 dt. 08.01.2024		17	76	7.6	35	360	2.1	Non Complying	Non Complying
	Jan, 2024											
	Feb, 2024											
	Mar, 2024	21.03.2024	2299 dated 01.04.2024		19	92	7.48	38	400	8.2	Non Complying	Non Complying
13	(MHD-STP-002) 2 MLD STP, Ateli Mandi, Mohindergarh by PHED in 30.6.2016	18.02.2021	2001-2002 dt. 23.02.2021		24	136	7.2	61	88000		Complying	Non Complying
		29.06.2021	255-256 dt. 05.07.2021	0.9	20	108	7.1	52	67000		Complying	Non Complying
		28.09.2021	909-910 dt. 04.10.2021	0.9	19	100	7.4	46	59000	6.6	Non Complying	Non Complying
	21.01.2022	29.12.2021	3536 dt. 10.01.2022		7.5	44	7.78	12	60	N.D.	Complying	Complying
	15.04.2022	30.03.2022	4796 dt. 08.04.2022		7.4	44	7.2	15	60	0.12	Complying	Complying
	13.07.2022	01.07.2022	127 dt. 11.07.2022		27	104	7.1	39	700	4.2	Non Complying	Non Complying
	12.10.2022	30.09.2022	740 dt. 11.10.2022		21	88	8.2	38	600	4.5	Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	07.01.2023	27.12.2022	1495 dt. 04.01.2023		82	329.1	7.6	135	5500	9.4	Non Complying	Non Complying
	08.04.2023	28.03.2023	2336 dt. 07.04.2023		41	164.6	7.9	80	1700	8.2	Non Complying	Non Complying
	15.07.2023	27.06.2023	417 dt. 05.07.2023		43	174.2	7.7	92	2100	6.9	Non Complying	Non Complying
	02.11.2023	29.09.2023	1231 dt. 19.10.2023		34	148	7.5	72	1900	3.2	Non Complying	Non Complying
	10.01.2024	29.12.2023	1643 dt. 08.01.2024		52	208	7.2	65	1500	5.3	Non Complying	Non Complying
	Jan, 2024											
	Feb, 2024											
	Mar, 2024											
14	(MHD-STP-003) 3 MLD STP Kanina, Mohindergarh by PHED in 30.4.2016	20.02.2021	2012-2013 dt. 26.02.2021	1.6	20	128	7	63	72000		Complying	Non Complying
		29.06.2021	251-252 dt. 05.06.2021		19	116	7.2	55	84000		Complying	Non Complying
		28.09.2021	911-912 dt. 04.10.2021	1.5	22	108	7.3	51	76000	7.2	Non Complying	Non Complying
	21.01.2022	30.12.2021	3538 dt. 10.01.2022		7.8	40	7.74	13	40	2.3	Complying	Complying
	15.04.2022	30.03.2022	4795 dt. 08.04.2022		7.8	48	7.5	17	80	1.04	Complying	Complying
	13.07.2022	01.07.2022	128 dt. 11.07.2022		42	160	8.2	56	1100	2.9	Non Complying	Non Complying
	12.10.2022	30.09.2022	741 dt. 11.10.2022		25	108	7.6	42	700	3.7	Non Complying	Non Complying
	07.01.2023	27.12.2022	1494 dt. 04.01.2023		29	166.9	7.4	55	3500	6.4	Non Complying	Non Complying
	08.04.2023	28.03.2023	2333 dt. 07.04.2023		24	112.4	8.2	48	2100	6.8	Non Complying	Non Complying
	15.07.2023	27.06.2023	418 dt. 05.07.2023		17	88.8	7.5	34	1100	5.7	Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
16	(MHD-STP- 005) 6 MLD Near Chinkara Rest House, Rewari Road, Narnaul by ULBD, Aug., 2020	01.12.2020	1257-1258 dt. 08.12.2020	452700(cuse c)	7	44	7	14	9000	3.4	Complying	Complying
				Non-Operational and effluent being treated in 7.5 MLD STP Narnaul								
	Rewari											
17	(REW-STP-001) 9.5 MLD Kharkhara, Dharuhera , Rewari by PHED in 30.6.2017	08.02.2021	1945-1946 dt. 17.02.2021		15	80	7.2	19	9000	6.4	Non Complying	Non Complying
		30.06.2021	259-260 dt. 06.07.2021	1.1	9	48	7.2	17	9600	1.6	Complying	Complying
		29.09.2021	932-933 dt. 07.10.2021	1	8	44	7.4	15	7200	2.8	Complying	Complying
	21.01.2022	29.12.2021	3532 dt. 10.01.2022		8	52	7.74	16	200	6.18	Complying	Complying
	20.04.2022	31.03.2022	4828 dt. 13.04.2022		16	72	7.43	36	400	1.95	Non Complying	Non Complying
	12.07.2022	30.06.2022	112 dt. 09.07.2022		44	176	7.6	68	600	2.1	Non Complying	Non Complying
	13.10.2022	30.09.2022	750 dt. 12.10.2022		52	208	7.9	78	900	2.6	Non Complying	Non Complying
	13.12.2022	25.11.2022	1165 dt. 05.12.2022		32	149.4	7.1	38	2100	2.6	Non Complying	Non Complying
	12.04.2023	27.03.2023	2321 dt. 06.04.2023		36	156.6	8.2	140	1100	6.9	Non Complying	Non Complying
	28.04.2023	13.04.2023	69 dt. 21.04.2023		13	68.6	7.6	32	270	5.1	Non Complying	Non Complying
	29.09.2023	12.09.2023	1103 dt. 20.09.2023		17	80	7.4	40	360	4.7	Non Complying	Non Complying
	09.01.2024	21.12.2023	1585 dt. 02.01.2024		9	48	6.9	17	80	2.3	Complying	Complying
	Mar, 2024	28.03.2024	2327 dated 04.04.2024		7	36	7.35	15	84	4.2	Complying	Complying
		01.07.2024	481 dt. 11.07.2024		29	144	7.04	48	190	7	Non Complying	Non Complying
		30.09.2024	1486 dt. 09.10.2024		26	128	7.32	52	210	8.4	Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		04.11.2024	1677 dt. 12.11.2024		105	456	7.66	155	5300	19.61	Non Complying	Non Complying
18	(REW-STP-002) 3 MLD STP Bawal , Rewari by PHED in 31.3.2014	31.03.2021	2161-2162 dt. 08.04.2021	1.8	19	100	7	51	82000	3.6	Complying	Non Complying
		30.06.2021	268-269 dt. 06.07.2021	2.6	12	56	7.6	29	22000	0.9	Complying	Non Complying
		05.08.2021	607-608 dt. 11.08.2021	2.7	13	64	7.4	39	17000	1.2	Non Complying	Non Complying
		27.09.2021	899-900 dt. 04.10.2021	2.5	12	64	7.5	31	21000	5.2	Non Complying	Non Complying
	21.01.2022	30.12.2021	3537 dt. 10.01.2022		17	60	7.88	18	200	1.88	Non Complying	Non Complying
	15.04.2022	30.03.2022	4786 dt. 08.04.2022		8	44	7.31	16	200	1.44	Non Complying	Non Complying
	12.07.2022	30.06.2022	110 dt. 09.07.2022		95	360	7.4	288	900	11.8	Non Complying	Non Complying
	13.10.2022	30.09.2022	745 dt. 12.10.2022		102	392	7.6	170	2100	13.4	Non Complying	Non Complying
	13.04.2023	30.03.2023	2392 dt. 11.04.2023		70	311.8	7.9	120	3300	8.1	Non Complying	Non Complying
	10.01.2024	29.12.2023	1639 dt. 08.01.2024		48	192	7.8	64	3200	4.5	Non Complying	Non Complying
		01.07.2024	482 dt. 11.07.2024		4	24	7.29	13	22	1.4	Complying	Complying
		30.09.2024	1484 dt. 09.10.2024		14	72	7.06	29	190	8.4	Non Complying	Non Complying
		04.11.2024	1679 dt. 12.11.2024		9	40	7.56	7	1700	16.81	Non Complying	Non Complying
19	(REW-STP-003) 6.5 MLD STP Rewari by PHED on 1.10.2014	08.02.2021	1943-1944 dt. 17.02.2021		38	160	6.9	141	72000		Non Complying	Non Complying
		21.06.2021	224-225 dt. 30.06.2021	7.9	48	288	7.4	145	110000	13.6	Non Complying	Non Complying
		29.09.2021	926-927 dt. 07.10.2021	12	90	312	7.2	208	140000	37.8	Non Complying	Non Complying
	21.01.2022	29.12.2021	3531 dt. 10.01.2022		130	572	7.48	76	3300	7.48	Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	20.04.2022	31.03.2022	4830 dt. 13.04.2022		64	260	7	114	900	2.35	Non Complying	Non Complying
	12.07.2022	30.06.2022	113 dt. 09.07.2022		46	208	7.8	80	1300	3.4	Non Complying	Non Complying
	12.10.2022	30.09.2022	739 dt. 11.10.2022		16	68	7.9	31	900	4.8	Non Complying	Non Complying
	13.10.2022	30.09.2022	748 dt. 12.10.2022		55	224	7.3	132	1800	4.9	Non Complying	Non Complying
	05.12.2022	25.11.2022	1159 dt. 05.12.2022		70	294.9	7.8	125	2400	5.6	Non Complying	Non Complying
	13.04.2023	30.03.2023	2393 dt. 11.04.2023		58	236	7.4	146	2100	4.7	Non Complying	Non Complying
	28.04.2023	13.04.2023	70 dt. 21.04.2023		29	137.3	7.5	48	880	4.7	Non Complying	Non Complying
	29.09.2023	12.09.2023	1102 dt. 20.09.2023		26	112	7.1	42	730	3.8	Non Complying	Non Complying
	Jan, 2024	01.07.2024	479 dt. 11.07.2024		27	136	7.48	65	530		Non Complying	Non Complying
		30.09.2024	1482 dt. 09.10.2024		75	304	7.23	160	2900	14.01	Non Complying	Non Complying
		04.11.2024	1678 dt. 12.11.2024		80	328	7.44	115	4100	28.02	Non Complying	Non Complying
20	(REW-STP-004) 8 MLD STP Rewari by PHED 14.12.2007	17.02.2021	1939-1940 dt. 17.02.2021		28	136	7.2	65	210000		Non Complying	Non Complying
		29.06.2021	245-246 dt. 06.07.2021	5.1	21	124	7.4	57	87000	5.2	Non Complying	Non Complying
		29.09.2021	922-923 dt. 07.10.2021	5	18	96	7.5	46	9200	8.6	Non Complying	Non Complying
	21.01.2022	29.12.2021	3530 dt. 10.01.2022		12	60	7.4	17	400	1.44	Non Complying	Non Complying
	20.04.2022	31.03.2022	4826 dt. 13.04.2022		15	76	7.39	33	900	1.41	Non Complying	Non Complying
	12.07.2022	30.06.2022	115 dt. 09.07.2022		26	112	7.4	48	1300	1.68	Non Complying	Non Complying
	13.10.2022	30.09.2022	744 dt. 12.10.2022		27	128	7.5	55	1500	2.1	Non Complying	Non Complying
	05.12.2022	25.11.2022	1160 dt. 05.12.2022		19	88.8	7.4	35	2000	2.6	Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	13.04.2023	30.03.2023	2395 dt. 11.04.2023		27	116	7.1	41	1500	2.9	Non Complying	Non Complying
	28.04.2023	13.04.2023	73 dt. 21.04.2023		7	44.4	7.4	15	86	2.6	Complying	Complying
	29.09.2023	12.09.2023	1101 dt. 20.09.2023		9	48	7.2	18	93	3.1	Complying	Complying
	09.01.2024	22.12.2023	1587 dt. 02.01.2024		8	44	7.1	14	90	2.5	Complying	Complying
	Mar, 2024	28.03.2024	2331 dated 04.04.2024		6	48	7.25	16	84	2.8	Complying	Complying
		01.07.2024	485 dt. 11.07.2024		4	24	7.27	12	63	1.4	Complying	Complying
		30.09.2024	1480 dt. 09.10.2024		6	32	7.65	14	63	7	Complying	Complying
		04.11.2024	1675 dt. 06.11.2024		12	48	7.42	8	2100	29.42	Complying	Complying
21	(REW-STP-005) 16 MLD STP Rewari by PHED in Sep. 2014	08.02.2021	1941-1942 dt. 17.02.2021		22	140	7.1	59	64000	5.8	Non Complying	Non Complying
		29.06.2021	249-250 dt. 06.07.2021	11.1	45	216	7.3	154	96000	9.4	Non Complying	Non Complying
		29.09.2021	924-925 dt. 07.10.2021	10	9	48	7.5	18	9000	5.2	Complying	Complying
	21.01.2022	29.12.2021	3529 dt. 10.01.2022		8	48	7.43	16	200	1.46	Complying	Complying
	20.04.2022	31.03.2022	4827 dt. 13.04.2022		13	64	7.4	32	400	1.32	Non Complying	Non Complying
	12.07.2022	30.06.2022	116 dt. 09.07.2022		32	136	7.2	52	600	2.5	Non Complying	Non Complying
	13.10.2022	30.09.2022	743 dt. 12.10.2022		17	68	7.4	34	200	2.5	Non Complying	Non Complying
	05.12.2022	25.11.2022	1157 dt. 05.12.2022		46	185.8	7.2	60	1700	3.7	Non Complying	Non Complying
	13.04.2023	30.03.2023	2394 dt. 11.04.2023		24	92	7.4	50	1300	2.9	Non Complying	Non Complying
	28.04.2023	13.04.2023	74 dt. 21.04.2023		9	48.4	7.5	18	90	2.5	Complying	Complying
	07.10.2023	12.09.2023	1105 dt. 20.09.2023		8	44	7.3	16	72	3.2	Complying	Complying
	09.01.2024	22.12.2023	1586 dt. 02.01.2024		6	36	7	12	60	BDL	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
23	(REW-STP-007) 5 MLD STP , HUDA, Sec-6, Dharuhera in 2020		558-559 dt. 03.01.2020		80	296	8.4	250			Non Complying	Non Complying
			1981-82 dated 13.04.2020		55	168	6.9	142			Non Complying	Non Complying
			283-284 dt. 03.07.2020		48	204	7.8	160	120000		Non Complying	Non Complying
		31.03.2021	2155-2156 dt. 06.04.2021	3.3	9	48	7	17	11000	2.9	Complying	Complying
		28.06.2021	235-236 dt. 06.07.2021	1.9	7	40	7.5	14	9000	1.1	Complying	Complying
		29.09.2021	930-931 dt. 07.10.2021	3	7	40	7.4	10	96	1.1	Complying	Complying
	21.01.2022	29.12.2021	3533 dt. 10.01.2022		7.6	36	7.65	12	200	1.44	Complying	Complying
	20.04.2022	31.03.2022	4829 dt. 13.04.2022		14	68	7.38	44	300	1.06	Non Complying	Non Complying
	12.07.2022	30.06.2022	109 dt. 09.07.2022		18	80	7.4	26	600	3.6	Non Complying	Non Complying
	13.10.2022	30.09.2022	746 dt. 12.10.2022		8	40	8.1	16	86	3.4	Complying	Complying
	05.12.2022	25.11.2022	1158 dt. 05.12.2022		28	117.1	7.1	55	1500	4.6	Non Complying	Non Complying
	08.04.2023	28.03.2023	2335 dt. 07.04.2023		32	132.5	7.3	64	1500	7.4	Non Complying	Non Complying
	13.04.2023	29.03.2023	2355 dt. 08.04.2023		19	80.1	7.3	24	88	3.9	Non Complying	Non Complying
	28.04.2023	13.04.2023	72 dt. 21.04.2023		8	43.1	7.9	17	77	3.1	Complying	Complying
	15.07.2023	27.06.2023	413 dt. 05.07.2023		18	91.8	6.7	29	770	7.1	Non Complying	Non Complying
	07.10.2023	12.09.2023	1104 dt. 20.09.2023		7	40	7.6	19	80	2.4	Complying	Complying
	02.11.2023	29.09.2023	1233 dt. 19.10.2023		21	104	7.1	37	840	5.4	Non Complying	Non Complying
	09.01.2024	22.12.2023	1584 dt. 02.01.2024		5	32	7.1	14	93	1.6	Complying	Complying
	Mar, 2024	28.03.2024	2328 dated 04.04.2024		9	48	7.53	18	70	2.8	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		01.07.2024	480 dt. 11.07.2024		5	28	7.13	13	63	4.2	Complying	Complying
		30.09.2024	1487 dt. 09.10.2024		6	32	7.72	17	79	9.8	Complying	Complying
		04.11.2024	1676 dt. 12.11.2024		25	120	7.48	28	3300	43.43	Complying	Complying
	Ambala											
24	(AMB-STP-013) 4 MLD STP, PHED, Barara, Ambala in 30.11.2019	21.12.2020	4695 dt. 05.01.2021		4	28	7.29	12	1700	2.14	Complying	Complying
		26.02.2021	478 dt. 08.03.2021		9	52	7.7	21	40	0.88	Complying	Complying
		25.03.2021	730 dt. 02.04.2021		12	76	7.79	8	20	1.84	Non Complying	Non Complying
		26.05.2021	1197 dt. 08.06.2021	1.05 MLD	11	64	7.8	32	70	N.D.	Non Complying	Non Complying
	07.09.2021	28.07.2021	1842 dt. 18.08.2021		7	36	7.09	9	90	0.23	Complying	Complying
	30.09.2021	26.08.2021	2213 dt. 10.09.2021		3.5	16	7.41	7	Absent	N.D.	Complying	Complying
	25.10.2021	21.09.2021	2478 dt. 06.10.2021	1 MLD	8.5	48	7.8	16	Absent	1.32	Complying	Complying
	30.11.2021	28.10.2021	2871 dt. 12.11.2021		8	48	8.04	14	400	2.14	Complying	Complying
	24.12.2021	26.11.2021	3135 dt. 07.12.2021		5.8	28	7.83	14	200	0.31	Complying	Complying
	18.01.2021	23.12.2021	3468 dt. 31.12.2021		7.5	46	7.36	15	60	0.25	Complying	Complying
	10.02.2022	27.01.2022	3923 dt. 08.02.2022		6.5	40	7.44	10	80	2.14	Complying	Complying
	05.04.2022	24.02.2022	4273 dt. 09.03.2022		6.8	40	7.62	17	70	N.D.	Complying	Complying
	15.04.2022	29.03.2022	4749 dt. 07.04.2022		7.5	40	7.5	16	80	1.12	Complying	Complying
	22.06.2022	25.05.2022	5563 dt. 07.06.2022		6.8	36	6.79	13	80	2.24	Complying	Complying
	18.07.2022	29.06.2022	6023 dt. 12.07.2022		7.4	36	7.35	14	50	ND	Complying	Complying
	05.08.2022	13.07.2022	6239 dt. 21.07.2022		7.2	40	7.33	13	90	1.27	Complying	Complying
	06.09.2022	23.08.2022	6585 dt. 01.09.2022		7.8	40.8	7.05	16	80	1.07	Complying	Complying
	18.10.2022	28.09.2022	7037 dt. 11.10.2022		7.6	44	7.12	15	90	1.08	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	23.11.2022	15.10.2022	7244 dt. 26.10.2022		7.5	48	6.98	13	90	1.18	Complying	Complying
	23.12.2022	30.11.2022	7653 dt. 13.12.2022		7.6	28	7.18	13	90	ND	Complying	Complying
	13.01.2023	24.12.2022	8025 dt. 03.01.2023		6.8	44	7.3	13	80	ND	Complying	Complying
	10.02.2023	31.01.2023	303 dt. 08.02.2023		7.2	36	7.68	15	80	ND	Complying	Complying
	18.04.2023	31.03.2023	1086 dt. 13.04.2023		6.2	28	7.3	11	90	ND	Complying	Complying
	12.05.2023	28.04.2023	1399 dt. 09.05.2023		7.5	36	7.6	13	90	ND	Complying	Complying
	14.06.2023	29.05.2023	1715 dt. 07.06.2023		7.5	44	7.56	15	90	ND	Complying	Complying
	03.07.2023	12.06.2023	1866 dt. 20.06.2023		7.5	44	7.52	13	70	ND	Complying	Complying
	14.08.2023	27.07.2023	2364 dt. 03.08.2023		7.2	44	7.17	13	90	ND	Complying	Complying
	29.08.2023	16.08.2023	2514 dt. 24.08.2023		7.5	40	7.23	12	70	0.52	Complying	Complying
	10.11.2023	23.10.2023	3302 dt. 31.10.2023		8.2	44	7.19	14	80	0.46	Complying	Complying
	14.12.2023	21.11.2023	3626 dt. 01.12.2023		36	144	7.26	58	600	2.16	Non Complying	Non Complying
	20.12.2023	04.12.2023	3729 dt. 13.12.2023		8.2	44	7.06	13	80	ND	Complying	Complying
		19.04.2024	84 dt. 25.04.2024		6.9	40	7.23	11	50	ND	Complying	Complying
		03.05.2024	183 dt. 09.05.2024		6	36	7.1	10	50	ND	Complying	Complying
		12.06.2024	349 dt. 24.06.2024		5.8	36	6.06	12		ND	Complying	Complying
		08.07.2024	557 dt. 19.07.2024		7.2	44	6.88	13		0.72	Complying	Complying
		29.08.2024	950 dt. 05.09.2024		7	48	6.89	13		ND	Complying	Complying
		09.09.2024	1063 dt. 18.09.2024		6.8	40	7.08	15		ND	Complying	Complying
		07.10.2024	1192 dt. 15.10.2024		6.8	48	7.16	17		ND	Complying	Complying
		07.11.2024	1404 dt. 14.11.2024		5.2	28	7.36	11		ND	Complying	Complying
		24.12.2024	1743 dt. 31.12.2024		52	240	6.65	113		7.82	Non Complying	Non Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		15.01.2025	1916 dt. 22.01.2025		14	64	6.7	34		ND	Non Complying	Non Complying
	Karnal											
25	(KRN-STP-010) 5 MLD STP Assandh, Karnal by PHED in 2.4.2014	27.01.2021	205 dt. 04.02.2021		8	40	8.3	11	1100	2.26	Complying	Complying
		09.02.2021	367 dt. 19.02.2021		7	48	7.66	16	130	1.86	Complying	Complying
		19.03.2021	720 dt. 31.03.2021		6.2	28	7.59	11	170	2.34	Complying	Complying
		12.04.2021	920 dt. 17.04.2021		6.8	40	7.19	7	270	1.16	Complying	Complying
		18.05.2021	1151 dt. 01.06.2021		7.6	48	7.15	11	1400	N.D.	Complying	Complying
		10.06.2021	1323 dt. 21.06.2021		7.5	36	8.48	11	500	0.79	Complying	Complying
	07.09.2021	20.07.2021	1720 dt. 30.07.2021		6.8	32	7.75	13	1100	1.97	Complying	Complying
	30.09.2021	19.08.2021	2175 dt. 06.09.2021		24	112	7.43	39	6300	2.16	Non Complying	Non Complying
	25.10.2021	30.09.2021	2546 dt. 12.10.2021		4.6	20	7.43	6	90	0.22	Complying	Complying
	25.10.2021	09.10.2021	2678 dt. 22.10.2021		7	44	7.83	15	500	1.04	Complying	Complying
	09.12.2021	10.11.2021	2947 dt. 24.11.2021		7.5	44	7.62	14	70	1.2	Complying	Complying
	19.01.2022	17.12.2021	3407 dt. 29.12.2021		9	46	7.67	18	80	1.95	Complying	Complying
	09.02.2022	13.01.2022	3693 dt. 25.01.2022		7.6	44	7.06	12	40	N.D.	Complying	Complying
	05.04.2022	16.02.2022	4171 dt. 24.02.2022		7.6	44	7.49	12	90	N.D.	Complying	Complying
	13.04.2022	08.03.2022	4511 dt. 21.03.2022		7	40	7.6	14	60	0.23	Complying	Complying
	18.05.2022	16.04.2022	5105 dt. 06.05.2022		7.8	48	7.16	17	60	1.44	Complying	Complying
	10.06.2022	17.05.2022	5459 dt. 28.05.2022	80.9m ³ /h	7.8	40	6.92	12	70	1.43	Complying	Complying
	18.07.2022	28.06.2022	6000 dt. 11.07.2022		7	44	7.34	13	90	1.92	Complying	Complying
	05.08.2022	26.07.2022	6321 dt. 03.08.2022		14	68	7.28	33	400	2.12	Non complying	Non complying
	05.09.2022	16.08.2022	6557 dt. 25.08.2022		7.5	36	6.38	9	200	2.76	Non complying	Non complying
	06.10.2022	09.09.2022	6816 dt. 21.09.2022		8.5	48	7.36	15	400	1.08	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	16.11.2022	20.10.2022	7266 dt. 28.10.2022	130m3	8.5	48	7.12	16	90	1.08	Complying	Complying
	05.12.2022	18.11.2022	7498 dt. 30.11.2022		7.8	44	7.3	15	80	0.82	Complying	Complying
	07.12.2022	25.11.2022	7567 dt. 07.12.2022		7.5	48	7.34	12	90	ND	Complying	Complying
	05.01.2023	16.12.2022	7940 dt. 27.12.2022		8	44	7.26	17	90	1.36	Complying	Complying
	01.02.2023	20.01.2023	199 dt. 31.01.2023		8	48	8.01	17	200	1.72	Complying	Complying
	21.03.2023	03.03.2023	764 dt. 15.03.2023		12	60	7.14	28	400	1.12	Non complying	Non complying
	04.05.2023	20.04.2023	1303 dt. 01.05.2023		7.8	48	7.12	15	90	ND	Complying	Complying
	12.06.2023	24.05.2023	1623 dt. 01.06.2023	148.6	7.8	28	7.12	13	90	ND	Complying	Complying
	12.07.2023	21.06.2023	1974 dt. 28.06.2023	147.6	8	44	7.3	15	80	ND	Complying	Complying
	14.08.2023	25.07.2023	2342 dt. 02.08.2023	130 m3/hr	7.6	44	7.41	13	90	ND	Complying	Complying
	25.08.2023	10.08.2023	2486 dt. 21.08.2023		7.6	40	6.88	16	90	ND	Complying	Complying
	19.10.2023	28.09.2023	3061 dt. 14.10.2023		7.4	36	7.56	11	70	0.53	Complying	Complying
	10.11.2023	27.10.2023	3373 dt. 07.11.2023		7.8	40	6.67	13	80	ND	Complying	Complying
	14.12.2023	21.11.2023	3632 dt. 01.12.2023		6.4	32	7.24	12	70	ND	Complying	Complying
	22.12.2023	06.12.2023	3806 dt. 19.12.2023		8	44	7.52	12	90	ND	Complying	Complying
		24.01.2024	4290 dt. 30.01.2024		5	28	7.1	10	60	ND	Complying	Complying
		21.02.2024	4648 dt. 12.03.2024		8.6	48	6.6	13	90	ND	Complying	Complying
		17.05.2024	263 dt. 23.05.2024		5.8	32	7.03	10	60	ND	Complying	Complying
		26.07.2024	757 dt. 06.08.2024		7.6	32	6.86	14		ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		10.09.2024	1071 dt. 18.09.2024		7.5	44	7.4	17		ND	Complying	Complying
		15.10.2024	1269 dt. 24.10.2024		7	44	7.07	13		ND	Complying	Complying
		12.11.2024	1427 dt. 19.11.2024		5.8	36	6.13	14		ND	Complying	Complying
	Gurgaon North											
26	(GRN-STP-004) 6 MLD STP Sohna Gurgaon (North) by PHED in 1.3.2014	25.01.2021	1829-1830 dt. 01.02.2021		21	116	7.1	45	42000		Complying	Non complying
		28.02.2021	2058 dt. 10.03.2021	3.5	22	132	7.3	51	57000		Complying	Non complying
		22.03.2021	2138-2139 dt. 30.03.2021	3.4	18	104	7.1	43	88000	4.1	Complying	Non complying
		10.04.2021	37-38 dt. 19.04.2021	3.4	19	124	7.2	45	92000	1.7	Complying	Non complying
		10.05.2021	103-104 dt. 17.05.2021	3	19	108	7.1	47	88000	1.1	Complying	Non complying
		09.06.2021	202-203 dt. 16.06.2021	3.2	20	112	7	42	72000	1.4	Complying	Non complying
		12.07.2021	444-445 dt. 19.07.2021	3.8	19	108	7	56	64000	1.2	Complying	Non complying
		18.08.2021	675-676 dt. 25.08.2021	5.1	15	88	7.3	37	29000	0.8	Complying	Non complying
		10.09.2021	805-806 dt. 16.09.2021	5.3	12	68	7.1	36	9800	5.6	Non complying	Non complying
		08.10.2021	963-964 dt. 13.10.2021	5.2	19	104	7.5	46	11000	7.6	Non complying	Non complying
	23.11.2021	10.11.2021	1094-1095 dt. 16.11.2021	-	17	84	7.2	51	8800	8.1	Non complying	Non complying
	15.12.2021	02.12.2021	1187-1188 dt. 09.12.2021	-	18	92	7.3	46	7600	8.8	Non complying	Non complying
	18.01.2021	23.12.2021	3454 dt. 31.12.2021		8	48	6.96	24	90	1.04	complying	complying
	06.04.2022	22.02.2022	4225 dt. 03.03.2022		8.2	48	6.91	17	80	1.41	complying	complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	15.04.2022	29.03.2022	4762 dt. 08.04.2022		21	96	7.63	45	600	N.D.	Non complying	Non complying
		30.05.2022	5635 dt. 13.06.2022	4.9MLD	16	64	7.43	13	600	2.43	Non complying	Non complying
	08.07.2022	16.06.2022	5893 dt. 27.06.2022	5.4MLD	15	68	7.27	39	1200	2.84	Non complying	Non complying
	09.08.2022	29.07.2022	426 dt. 08.08.2022		26	128	7.6	37	1700	4.8	Non complying	Non complying
	08.09.2022	25.08.2022	556 dt. 02.09.2022		25	132	7.2	31	1800	3.9	Non complying	Non complying
	12.10.2022	30.09.2022	738 dt. 11.10.2022		13	64	7.9	38	630	3.8	Non complying	Non complying
	08.12.2022	29.11.2022	1203 dt. 08.12.2022		27	153.5	7.5	48	2100	4.2	Non complying	Non complying
	14.02.2023	28.01.2023	1825 dt. 04.02.2023		28	184.7	7.9	66	2300	3.2	Non complying	Non complying
	13.04.2023	31.03.2023	2412 dt. 11.04.2023		28	197.5	7.9	86	3000	4.2	Non complying	Non complying
	16.06.2023	30.05.2023	253 dt. 06.06.2023		21	132.5	7.4	64	2700	3.2	Non complying	Non complying
	03.11.2023	30.09.2023	1238 dt. 20.10.2023		21	96	7.5	39	1800	3.6	Non complying	Non complying
	09.11.2023	27.10.2023	1331 dt. 06.11.2023		24	108	7.2	32	2400	2.8	Non complying	Non complying
	15.12.2023	29.11.2023	1452 dt. 08.12.2023		17	80	7.1	28	2900	1.8	Non complying	Non complying
	19.01.2024	30.12.2023	1658 dt. 09.01.2024		27	136	7.5	64	1700	2.1	Non complying	Non complying
		31.01.2024	2002 dt. 06.02.2024		19	92	7.18	32	1500	2.6	Non complying	Non complying
		30.04.2024	116 dt. 06.05.2024		18	72	7.97	24	930	8.4	Non complying	Non complying
		30.05.2024	250 dt. 07.06. 2024		26	144	8.23	38	840	9.8	Non complying	Non complying
		26.06.2024	473 dt. 11.07.2024		23	104	8.02	42	770	5.6	Non complying	Non complying
		29.08.2024	1263 dt. 05.09.2024		19	92	8.31	38	930	8.4	Non complying	Non complying
		30.09.2024	1488 dt. 09.10.2024		24	116	7.84	44	290	9.8	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		30.10.2024	1664 dt. 06.11.2024		23	104	7.62	55	490	11.2	Non complying	Non complying
		29.11.2024	1826 dt. 05.12.2024		25	108	8.02	62	330	12.6	Non complying	Non complying
Gurgaon South												
27	(GRS-STP-007) 4.5 MLD STP Pataudi Gurgaon by PHED in 30.6.2017 (South)	11.01.2021	96 dt. 22.01.2021		8	44	7.38	42	1100	1.84	complying	complying
		24.02.2021	2020-2021 dt. 02.03.2021	1.7	19	108	7.1	49	72000		complying	Non complying
		08.03.2021	2083-2084 dt. 15.03.2021	2.4	20	96	7.2	45	82000	7.2	complying	Non complying
		13.04.2021	53-54 dt. 22.04.2021	2.8	19	100	7	39	92000	6.4	complying	Non complying
		12.05.2021	120-121 dt. 18.05.2021	2.9	20	108	7.2	44	96000	5.4	complying	Non complying
		04.06.2021	170-171 dt. 10.06.2021	3	18	104	7	46	84000	4.2	complying	Non complying
		29.07.2021	563-564 dt. 05.08.2021	2.9	16	84	7.5	41	52000	2.2	complying	Non complying
		20.08.2021	684-685 dt. 26.08.2021	3.1	12	60	7.7	37	29000	1.1	complying	Non complying
		06.09.2021	768-769 dt. 13.09.2021	3.2	13	72	7.5	42	35000	1.9	Non complying	Non complying
		13.10.2021	988-989 dt. 21.10.2021	-	12	68	7.4	37	27800	2.2	Non complying	Non complying
		09.11.2021	1079-1080 dt. 16.11.2021	-	15	72	7.1	43	19400	5.1	Non complying	Non complying
		09.12.2021	1211-1212 dt. 15.12.2021	-	13	64	7	45	7200	6.8	Non complying	Non complying
	08.02.2022	13.01.2022	3679 dt. 21.01.2022	3.5 MLD	13	68	6.69	36	80	1.95	Non complying	Non complying
	05.04.2022	04.02.2022	4030 dt. 15.02.2022	3.2	9	56	7.54	13	90	1.41	Complying	Complying
	15.04.2022	11.03.2022	4558 dt. 25.03.2022		13	56	7.75	33	70	1.32	Non complying	Non complying
	04.05.2022	04.04.2022	4858 dt. 20.04.2022	3.2	8.5	56	7.5	34	90	1.31	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	08.06.2022	12.05.2022	5434 dt. 26.05.2022		7.5	40	7.08	12	400	2.42	Complying	Complying
	14.07.2022	09.06.2022	5792 dt. 23.06.2022		7.5	40	7.86	13	90	1.36	Complying	Complying
	26.07.2022	11.07.2022	236 dt. 20.07.2022		13	68	7.7	18	700	0	Non complying	Non complying
	10.08.2022	02.08.2022	461 dt. 10.08.2022		16	84	7.2	35	860	0	Non complying	Non complying
	04.10.2022	22.09.2022	678 dt. 01.10.2022		14	72	7.6	25	920		Non complying	Non complying
	28.10.2022	13.10.2022	823 dt. 21.10.2022		16	80	7.2	32	1100	2.3	Non complying	Non complying
	24.11.2022	16.11.2022	1044 dt. 24.11.2022		17	76.4	7.5	28	1300	2.1	Non complying	Non complying
	20.12.2022	08.12.2022	1311 dt. 20.12.2022		21	90.1	7.2	42	1500	2.4	Non complying	Non complying
	01.02.2023	20.01.2023	1785 dt. 31.01.2023		24	110.1	7.4	48	1900	3.1	Non complying	Non complying
	20.02.2023	09.02.2023	1949 dt. 17.02.2023		27	145.4	7.2	42	1700	2.9	Non complying	Non complying
	13.03.2023	02.03.2023	2100 dt. 10.03.2023		25	133.3	7.4	54	2100	3.4	Non complying	Non complying
	20.04.2023	07.04.2023	35 dt. 17.04.2023		21	88.8	7.2	46	670	2.7	Non complying	Non complying
	24.05.2023	03.05.2023	130 dt. 11.05.2023		19	72.7	7.5	42	630	2.9	Non complying	Non complying
	23.06.2023	07.06.2023	313 dt. 15.06.2023		18	64.6	7.8	31	770	3.3	Non complying	Non complying
	11.08.2023	21.07.2023	769 dt. 01.08.2023		16	70.5	7.5	38	430	2.8	Non complying	Non complying
	01.09.2023	21.08.2023	962 dt. 28.08.2023		18	80	7.1	42	462	3.2	Non complying	Non complying
	10.10.2023	19.09.2023	1139 dt. 04.10.2023		17	72	7.3	36	340	2.5	Non complying	Non complying
	09.11.2023	27.10.2023	1330 dt. 06.11.2023		19	88	7.4	48	420	2.8	Non complying	Non complying
	01.12.2023	20.11.2023	1402 dt. 28.11.2023		21	96	7.6	38	380	3.4	Non complying	Non complying
	10.01.2024	28.12.2023	1629 dt. 05.01.2024		24	108	7.2	56	260	2.3	Non complying	Non complying
	20.02.2024	06.02.2024	2046 dt. 13.02.2024		29	128	7.82	48	253	3.4	Non complying	Non complying
		05.06.2024	269 dt. 12.06.2024		24	120	7.28	38	390	4.2	Non complying	Non complying
		29.07.2024	989 dt. 08.08.2024		21	92	7.41	33	470	7	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		01.08.2024	1027 dt. 09.08.2024		23	104	7.62	35	580	9.8	Non complying	Non complying
		30.09.2024	1489 dt. 09.10.2024		25	120	7.22	31	710	8.4	Non complying	Non complying
		23.10.2024	1609 dt. 30.10.2024		26	136	7.8	48	630	12.6	Non complying	Non complying
		25.01.2025	2269 dt. 30.01.2025		50	209.4	7.48	140	1100	14.01	Non complying	Non complying
		07.02.2025	2418 dt. 19.02.2025		16	84.8	7.84	48	840	11.20	Non complying	Non complying
28	(GRS-STP-008) 3 MLD STP at Farrukhnagar , Gurugram by PHED in 30.06.2018 (South)	11.01.2021	97 dt. 22.01.2021		11	56	7.63	38	1400	1.97	Non complying	Non complying
		24.02.2021	2018-2019 dt. 02.03.2021		8	40	7.1	14	9000	1.2	Complying	Complying
		08.03.2021	2085-2086 dt. 15.03.2021	657.3 LPM	7	36	7.3	16	15000	1.5	Complying	Complying
		13.04.2021	51-52 dt. 22.04.2021	2.16	7	40	7.6	15	12000	1.7	Complying	Complying
		12.05.2021	105-106 dt. 18.05.2021	2.2	8	44	7.1	17	8800	0.9	Complying	Complying
		02.06.2021	156-157 dt. 10.06.2021	1.6	7	40	7	15	8200	1.1	Complying	Complying
		30.07.2021	569-570 dt. 05.08.2021	1.9	6	36	7.5	11	8900	0.9	Complying	Complying
		17.08.2021	664-665 dt. 23.08.2021	2.2	5	32	7.4	16	7200	1.1	Complying	Complying
		06.09.2021	770-771 dt. 13.09.2021	1.7	6	36	7.3	12	6400	0.9	Complying	Complying
		05.10.2021	952-953 dt. 11.10.2021	1.6	5	32	7.3	14	5800	1.1	Complying	Complying
	24.11.2021	11.11.2021	1102-1103 dt. 16.11.2021	-	7	36	7.4	15	2700	2.1	Complying	Complying
	19.01.2022	15.12.2021	3374 dt. 29.12.2021		5.6	36	6.94	13	Absent	0.64	Complying	Complying
	08.02.2022	13.01.2022	3681 dt. 21.01.2022	2.1 MLD	14	80	6.5	41	90	3.93	Non complying	Non complying
	05.04.2022	24.02.2022	4266 dt. 09.02.2022	2.3 app.	8	44	7.6	14	50	N.D.	Complying	Complying
	15.04.2022	11.03.2022	4556 dt. 25.03.2022		14	64	7.67	34	1400	3.9	Non complying	Non complying
	04.05.2022	04.04.2022	4856 dt. 20.04.2022	1.5	13	64	7.38	31	800	1.87	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	08.06.2022	12.05.2022	5433 dt. 26.05.2022		8.6	48	7.05	18	400	1.88	Complying	Complying
	14.07.2022	09.06.2022	5797 dt. 23.06.2022		8	48	7.4	14	400	2.77	Complying	Complying
	26.07.2022	11.07.2022	238 dt. 20.07.2022		8	40	7.1	17	90	2.3	Complying	Complying
	10.08.2022	02.08.2022	462 dt. 10.08.2022		7	36	7.1	14	77	2.1	Complying	Complying
	04.10.2022	22.09.2022	679 dt. 01.10.2022		8	44	7.1	16	90	2.7	Complying	Complying
	28.10.2022	13.10.2022	822 dt. 21.10.2022		9	47.5	7.2	15	80	2.9	Complying	Complying
	24.11.2022	16.11.2022	1043 dt. 24.11.2022		8	36.3	7.4	14	72	2.1	Complying	Complying
	20.12.2022	08.12.2022	1312 dt. 20.12.2022		9	43.5	7.2	17	77	2.3	Complying	Complying
	01.02.2023	20.01.2023	1787 dt. 31.01.2023		22	92.9	7.8	37	270	4.1	Non complying	Non complying
	20.02.2023	09.02.2023	1951 dt. 17.02.2023		16	70.5	7.6	33	220	3.2	Non complying	Non complying
	13.03.2023	02.03.2023	2101 dt. 10.03.2023		22	96.9	7.5	46	390	3.8	Non complying	Non complying
	20.04.2023	07.04.2023	32 dt. 17.04.2023		8	41.2	7.4	17	77	2.6	Complying	Complying
	24.05.2023	03.05.2023	129 dt. 11.05.2023		9	32.3	7.3	16	57	2.4	Complying	Complying
	23.06.2023	07.06.2023	312 dt. 15.06.2023		6	36.3	7.1	18	70	2.7	Complying	Complying
	11.08.2023	21.07.2023	767 dt. 01.08.2023		8	45.3	7.3	16	83	3.1	Complying	Complying
	01.09.2023	21.08.2023	961 dt. 28.08.2023		7	36	7.1	13	72	1.8	Complying	Complying
	15.09.2023	04.09.2023	1064 dt. 13.09.2023		9	48	7.2	16	80	1.4	Complying	Complying
	03.11.2023	06.10.2023	1256 dt. 21.10.2023		8	44	7.1	18	93	BDL	Complying	Complying
	01.12.2023	20.11.2023	1401 dt. 28.11.2023		9	48	7.5	16	70	1.8	Complying	Complying
	20.12.2023	07.12.2023	1496 dt. 14.12.2023		7	40	7.3	19	86	BDL	Complying	Complying
	20.02.2024	06.02.2024	2044 dt. 13.02.2024		5	44	7.18	18	91	ND	Complying	Complying
		04.07.2024	559 dt. 16.07.2024		8	44	7.44	18	84	7	Complying	Complying
		01.08.2024	1026 dt. 09.08.2024		9	48	7.18	15	58	4.2	Complying	Complying
		23.10.2024	1610 dt. 30.10.2024		8	48	7.73	19	70	8.4	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		19.11.2024	1743 dt. 27.11.2024		7	40	7.65	15	63	7	Complying	Complying
		23.12.2024	1964 dt 01.01.2025		48	256.5	7.63	110	1500	12.60	Non complying	Non complying
		23.12.2024	1995 dt 01.01.2025		9.4	48.01	7.42	17	84	9.8	Complying	Complying
		25.01.2025	2268 dt. 30.01.2025		9.0	43.4	7.5	15	63	7	Complying	Complying
		07.02.2025	2420 dt. 19.02.2025		8.2	36.9	7.46	17	79	8.40	Complying	Complying
29	(GRS-STP-009) 5.5 MLD STP at Haily Mandi , Gurugram by PHED in 30.06.2018 (South)	19.02.2021	2004-2005 dt. 26.02.2021		8	48	6.9	14	1200	2.8	Complying	Complying
		08.03.2021	2087-2088 dt. 15.03.2021		9	44	7.2	15	1600	2.1	Complying	Complying
		13.04.2021	49-50 dt. 22.04.2021	4.9	8	40	7.4	13	1300	1.1	Complying	Complying
		12.05.2021	107-108 dt. 18.05.2021	4.8	8	48	7.3	15	1100	1.4	Complying	Complying
		04.06.2021	174-175 dt. 10.06.2021	2.1	6	40	7	12	700	0.4	Complying	Complying
		29.07.2021	565-566 dt. 05.08.2021	2	5	36	7.4	9	680	36	Complying	Complying
		17.08.2021	666-667 dt. 23.08.2021	1.9	4	28	7	13	590	0.8	Complying	Complying
		06.09.2021	772 dt. 13.09.2021	5.1	5	32	7.4	11	450	1	Complying	Complying
		13.10.2021	992-993 dt. 21.10.2021	-	5	32	7.4	12	640	1.4	Complying	Complying
		10.11.2021	1084-1085 dt. 17.11.2021	-	7	36	7.1	10	720	2.1	Complying	Complying
		09.12.2021	1209-1210 dt. 15.12.2021	-	7	32	7	9	790	1.9	Complying	Complying
	08.02.2022	13.01.2022	3680 dt. 21.01.2022	5.2 MLD	6.2	36	7	10	40	1.15	Complying	Complying
	05.04.2022	04.02.2022	4029 dt. 15.02.2022	5.2 appro	8	48	7.62	23	200	2.83	Complying	Complying
	15.04.2022	11.03.2022	4557 dt. 25.03.2022		7.8	48	7.77	11	400	1.04	Complying	Complying
	04.05.2022	04.04.2022	4857 dt. 20.04.2022	4.1	8	44	7.45	17	200	2.92	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	07.06.2022	12.05.2022	5435 dt. 26.05.2022		8	48	7.28	16	200	1.98	Complying	Complying
	14.07.2022	09.06.2022	5793 dt. 23.06.2022		7.4	36	7.58	12	200	1.23	Complying	Complying
	26.07.2022	11.07.2022	237 dt. 20.07.2022		13	72	7.6	15	170	3.1	Non complying	Non complying
	10.08.2022	02.08.2022	463 dt. 10.08.2022		12	68	6.8	17	150	2.8	Non complying	Non complying
	29.09.2022	19.09.2022	652 dt. 28.09.2022		9	48	7.1	14	90	3.2	Complying	Complying
	28.10.2022	13.10.2022	821 dt. 21.10.2022		8	39.6	7.4	16	77	2.5	Complying	Complying
	24.11.2022	16.11.2022	1046 dt. 24.11.2022		10	48.4	7.2	18	80	2.3	Complying	Complying
	20.12.2022	08.12.2022	1313 dt. 20.12.2022		8	35.6	7.8	15	67	2.5	Complying	Complying
	01.02.2023	20.01.2023	1786 dt. 31.01.2023		23	97.9	7.2	39	330	4.7	Non complying	Non complying
	20.02.2023	09.02.2023	1950 dt. 17.02.2023		20	83.1	7.4	29	300	3.8	Non complying	Non complying
	13.03.2023	02.03.2023	2102 dt. 10.03.2023		23	113.1	7.6	42	410	3.4	Non complying	Non complying
	20.04.2023	07.04.2023	33 dt. 17.04.2023		7	36.3	7.5	14	63	1.9	Complying	Complying
	24.05.2023	03.05.2023	132 dt. 11.05.2023		6	20.2	7.8	17	70	2.2	Complying	Complying
	23.06.2023	07.06.2023	314 dt. 15.06.2023		8	24.2	7.6	15	88	2.7	Complying	Complying
	11.08.2023	21.07.2023	768 dt. 01.08.2023		7	32.9	7.2	12	73	3.1	Complying	Complying
	01.09.2023	21.08.2023	960 dt. 28.08.2023		9	40	7.5	14	80	2.6	Complying	Complying
	15.09.2023	04.09.2023	1063 dt. 13.09.2023		8	44	7.6	17	60	3.2	Complying	Complying
	03.11.2023	06.10.2023	1257 dt. 21.10.2023		6	36	7.9	14	80	1.8	Complying	Complying
	01.12.2023	20.11.2023	1403 dt. 28.11.2023		8	44	7.2	17	93	BDL	Complying	Complying
	20.12.2023	07.12.2023	1497 dt. 14.12.2023		9	48	7.5	15	65	2.3	Complying	Complying
	20.02.2024	06.02.2024	2045 dt. 13.02.2024		9	48	7.05	14	93	ND	Complying	Complying
		04.07.2024	560 dt. 16.07.2024		6	32	7.67	11	63	4.2	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
		01.08.2024	1025 dt. 09.08.2024		8	44	7.18	17	79	7	Complying	Complying
		23.10.2024	1608 dt. 30.10.2024		6	36	7.84	17	63	5.6	Complying	Complying
		23.12.2024	1966 dt. 01.01.2025		7.2	28.05	7.56	13	63	7	Complying	Complying
		25.01.2025	2267 dt. 30.01.2025		8.5	31.6	7.49	17	79	8.40	Complying	Complying
		07.02.2025	2419 dt. 19.02.2025		7.8	40.8	7.41	13	49	5.6	Complying	Complying
	Jind											
30	(KTL-STP-008) 4 MLD STP Julana ,Jind by PHED in 1.4.2016	25.01.2021	1199-1200 dt. 02.02.2021		20	96	8.1	34	18000		Complying	Non complying
		11.02.2021	1275-1276 dt. 17.02.2021		20	112	8	42	11000		Complying	Non complying
		22.03.2021	1518-1519 dt. 31.03.2021		22	96	7.8	38	9800		Complying	Non complying
		22.04.2021	124-125 dt. 01.05.2021		25	112	8.1	42	12000	8.7	Complying	Non complying
		24.05.2021	239-240 dt. 31.05.2021		23	96	8	34	11000	8.2	Complying	Complying
		22.06.2021	398-399 dt. 29.06.2021		24	96	8.1	38	96000	7.8	Complying	Non complying
		05.07.2021	497-498 dt. 13.07.2021		21	88	8.2	36	36000	7.6	Complying	Non complying
	27.09.2021	26.08.2021	144-145 dt. 07.09.2021	Not Work	38	120	8.1	60	45000		Non complying	Non complying
	25.10.2021	20.09.2021	976-977 dt. 27.09.2021	128.4	23	104	8.1	38	2800		Non complying	Non complying
	30.11.2021	29.10.2021	1296-1297 dt. 09.11.2021	Not Work	22	96	7.7	28	2200		Non complying	Non complying
	27.12.2021	29.11.2021	1482-1483 dt. 09.12.2021		25	104	7.9	36	3900		Non complying	Non complying
	15.04.2022	25.03.2022	4703 dt. 31.03.2022		52	180	7.85	145	600	21.21	Non complying	Non complying
	18.05.2022	28.04.2022	5198 dt. 12.05.2022		16	92	7.25	48	500	1.04	Non complying	Non complying
	18.07.2022	27.06.2022	5985 dt. 06.07.2022		17	76	7.51	32	1100	2.47	Non complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
18.08.2022	28.07.2022	6349 dt. 08.08.2022		16	76	7.48	29	500	10.89	Non complying	Non complying
05.09.2022	23.08.2022	6577 dt. 01.09.2022		25	120	7.16	118	1100	6.75	Non complying	Non complying
18.10.2022	29.09.2022	7050 dt. 11.10.2022		15	96	7	32	500	1.34	Non complying	Non complying
17.11.2022	28.10.2022	7318 dt. 07.11.2022		36	120	7.53	68	600	1.12	Non complying	Non complying
14.12.2022	25.11.2022	7589 dt. 07.12.2022		15	68	7.25	32	500	2.87	Non complying	Non complying
16.02.2023	03.02.2023	334 dt. 14.02.2023		17	108	7.68	35	500	1.35	Non complying	Non complying
13.03.2023	25.02.2023	638 dt. 13.03.2023		25	96	7.62	68	600	3.48	Non complying	Non complying
11.04.2023	27.03.2023	966 dt. 07.04.2023		7	24	7.87	14	90	ND	Complying	Complying
12.05.2023	28.04.2023	1408 dt. 10.5.2023		7	32	7.56	11	70	ND	Complying	Complying
14.06.2023	25.05.2023	1687 dt. 02.06.2023		7.2	44	7.31	13	80	ND	Complying	Complying
13.07.2023	29.06.2023	2043 dt. 07.07.2023		7.8	36	7.5	13	90	ND	Complying	Complying
14.08.2023	29.07.2023	2384 dt. 08.08.2023		8	36	7.27	15	80	ND	Complying	Complying
14.09.2023	30.08.2023	2712 dt. 08.09.2023		6.8	28	7.4	11	80	ND	Complying	Complying
17.10.2023	27.09.2023	3002 dt. 13.10.2023		8.4	44	6.85	14	70	BDL	Complying	Complying
10.11.2023	25.10.2023	3319 dt. 03.11.2023		7.4	40	7.07	12	80	ND	Complying	Complying
14.12.2023	25.11.2023	3676 dt. 06.12.2023		8.2	44	7.47	12	80	ND	Complying	Complying
18.01.2024	28.12.2023	4085 dt. 09.01.2024		8	44	7.09	14	90	ND	Complying	Complying
Jan, 2024	18.06.2024	369 dt. 27.06.2024		7.6	48	7.57	12		0.62	Complying	Complying
	17.07.2024	663 dt. 25.07.2024		6.5	36	6.95	11		ND	Complying	Complying
	22.08.2024	902 dt. 28.08.2024		7.8	48	7.05	16		ND	Complying	Complying
	25.09.2024	1143 dt. 07.10.2024		5.8	40	7.48	14		ND	Complying	Complying
	22.10.2024	1333 dt. 04.11.2024		5.8	32	7.62	11		ND	Complying	Complying
	18.01.2025	1940 dt. 24.01.2025		52	188	7.13	66		ND	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	Hisar											
31	(HSR-STP-006) 6.5 MLD STP Uklana, Hisar by PHED in 1.9.2017	29.01.2021	1227-1228 dt. 05.02.2021		18	104	7.7	28	25000		Non complying	Non complying
		24.02.2021	1355-1356 dt. 05.03.2021		21	112	7.9	36	35000		Non complying	Non complying
		24.03.2021	1532-1533 dt. 02.04.2021		20	96	8	22	28000		Non complying	Non complying
		17.04.2021	99-100 dt. 27.04.2021	4253	18	80	8	24	32000	5.6	Non complying	Non complying
		21.05.2021	223-224 dt. 29.05.2021		16	72	8.1	22	25000	5.2	Non complying	Non complying
		30.06.2021	330-331 dt. 06.07.2021		90	328	7	224			Non complying	Non complying
		21.07.2021	653-654 dt. 30.07.2021	5.6	20	80	8	24	26000	6.8	Non complying	Non complying
		16.08.2021	847-848 dt. 23.08.2021		34	128	8.1	32	35000	8.6	Non complying	Non complying
		07.09.2021	932-933 dt. 13.09.2021	4.9	39	216	8.2	58	72000		Non complying	Non complying
		01.10.2021	1120-1121 dt. 12.10.2021	0.9	35	192	8.1	48	42000		Non complying	Non complying
	20.12.2021	12.11.2021	1393-1394 dt. 26.11.2021	Not Work	21	104	7.8	32	2500		Non complying	Non complying
	27.12.2021	11.12.2021	1558-1559 dt. 20.12.2021	Not Work	38	160	8.3	58	56000		Non complying	Non complying
	03.02.2022	05.01.2022	1738-1739 dt. 13.01.2022	Not Work	17	88	8.1	32	52000		Non complying	Non complying
	15.04.2022	01.03.2022	4369 dt. 15.03.2022		6	48	7.72	16	90	1.97	Complying	Complying
	04.05.2022	04.04.2022	4867 dt. 21.04.2022	4.80MLD	21	112	7.77	34	800	2.83	Non complying	Non complying
	31.05.2022	02.05.2022	5267 dt. 17.05.2022		8.6	48	7.18	14	70	2.68	Complying	Complying
	06.07.2022	09.06.2022	5823 dt. 23.06.2022	4.0MLD	14	76	7.45	29	1100	1.29	Non complying	Non complying
	03.08.2022	08.07.2022	6104 dt. 18.07.2022		15	88	6.79	36	400	2.26	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	25.08.2022	04.08.2022	6412 dt. 16.08.2022	3.97 MLD	7.8	40	7.3	18	90	1.12	Complying	Complying
	10.10.2022	15.09.2022	6881 dt. 29.09.2022	4.40 MLD	22	116	7.34	29	500	2.72	Non complying	Non complying
	25.10.2022	04.10.2022	7060 dt. 17.10.2022	4.80 MLD	14	60	7	33	900	6.45	Non complying	Non complying
	09.12.2022	22.11.2022	7537 dt. 02.12.2022		8.2	48	7.44	16	90	1.16	Complying	Complying
	27.12.2022	02.12.2022	7690 dt. 19.12.2022		8	44	7.26	17	80	1.72	Complying	Complying
	18.01.2023	04.01.2023	21 dt. 13.01.2023		7.5	36	7.38	18	80	1.52	Complying	Complying
	20.02.2023	06.02.2023	368 dt. 16.02.2023		8	32	7.3	14	90	ND	Complying	Complying
	22.03.2023	09.03.2023	774 dt. 21.03.2023		8.2	44	7.5	16	80	ND	Complying	Complying
	18.04.2023	03.04.2023	1107 dt. 13.04.2023		8	48	7.08	18	90	1.24	Complying	Complying
	23.05.2023	05.05.2023	1422 dt. 15.05.2023		8	48	7.73	16	90	ND	Complying	Complying
	22.06.2023	02.06.2023	1756 dt. 12.06.2023		7.4	28	7.04	11	70	ND	Complying	Complying
	21.07.2023	06.07.2023	2152 dt. 17.07.2023		8	44	6.98	16	80	ND	Complying	Complying
	21.08.2023	03.08.2023	2425 dt. 16.08.2023		7.6	44	7.7	12	90	2.92	Complying	Complying
	19.09.2023	03.09.2023	2755 dt. 13.09.2023		6	32	7.07	15	60	ND	Complying	Complying
	03.11.2023	08.10.2023	3142 dt. 27.10.2023		8	44	7.32	15	70	ND	Complying	Complying
	23.11.2023	07.11.2023	3464 dt. 16.11.2023		6.5	32	7.59	11	80	ND	Complying	Complying
	22.12.2023	09.12.2023	3831 dt. 20.12.2023		7	40	7.2	13	80	ND	Complying	Complying
		03.01.2024	4138 dt. 12.01.2024		5	28	7.25	10	60	ND	Complying	Complying
		22.02.2024	4723 dt. 13.03.2024		7.8	40	7.01	13	80	ND	Complying	Complying
		03.04.2024	28 dt. 10.04.2024		8	48	7.38	12	90	ND	Complying	Complying
		03.05.2024	193 dt. 13.05.2024		8	48	7.02	14	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
		12.06.2024	334 dt. 21.06.2024		7.4	32	7.35	11		0.84	Complying	Complying
		13.07.2024	645 dt. 24.07.2024		7.5	44	7.8	15		0.36	Complying	Complying
		02.08.24	771 dt. 12.08.2024		6.6	32	7.29	14			Complying	Complying
		2.09.2024	1012 dt. 10.09.2024		6.4	44	6.74	13		ND	Complying	Complying
		09.10.24	1209 dt. 15.10.2024		7.2	44	7.2	15		ND	Complying	Complying
		06.11.24	1390 dt. 13.11.2024		3.2	20	7.15	6		ND	Complying	Complying
		02.12.24	1562 dt. 13.12.2024		6.8	44	7.35	13		ND	Complying	Complying
		08.01.25	1811 dt. 16.01.2025		6.5	40	6.16	12		ND	Complying	Complying
32	(HSR-STP-007) 6.5 MLD STP Hansi , Hisar by PHED in 31.05.2019	29.01.2021	1223-1224 dt. 05.02.2021		7	48	7.4	14	56000		Complying	Complying
		22.02.2021	1343-1344 dt. 02.03.2021		18	128	7.7	46	35000		Non complying	Non complying
		15.03.2021	1473-1474 dt. 24.03.2021		7.8	48	7.9	16	5500		Complying	Complying
		02.04.2021	5-6 dt. 12.04.2021		18.5	96	8.1	28	18000		Non complying	Non complying
		20.05.2021	201-202 dt. 29.05.2021		9.2	48	7.8	16	9000	6.8	Complying	Complying
		04.06.2021	296-297 dt. 11.06.2021		8.6	32	7.8	14	7200	6.2	Complying	Complying
		03.07.2021	481-482 dt. 12.07.2021		18	112	8.1	28	13000	7.2	Non complying	Non complying
		03.07.2021	481-482 dt. 12.07.2021		8.2	32	7.9	12	900	5.8	Complying	Complying
		03.08.2021	765-766 dt. 11.08.2021		8	32	7.8	10	720	4.8	Complying	Complying
		16.09.2021	960-961 dt. 22.09.2021	3.3	8.4	40	7.5	12	2500		Complying	Complying
		01.10.2021	1120-1121 dt. 12.10.2021	1.1	7.8	32	7.4	10	90		Complying	Complying
	20.12.2021	11.11.2021	1375-1376 dt. 24.11.2021	2.6	18	64	7.8	26	38000		Non complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
28.12.2021	13.12.2021	1568-1569 dt. 22.12.2021	2.98	20	72	7.6	24	42000		Non complying	Non complying
03.02.2022	05.01.2022	1734-1735 dt. 13.01.2022	2.1	24	96	7.9	28	45000		Non complying	Non complying
15.04.2022	02.03.2022	4378 dt. 15.03.2022	3 MLD	14	60	7.56	39	1200	1.22	Non complying	Non complying
04.05.2022	04.04.2022	4869 dt. 21.04.2022	3.80MLD	20	92	7.95	48	400	2.37	Non complying	Non complying
31.05.2022	03.05.2022	5276 dt. 17.05.2022		18	108	7.24	78	1400	1.41	Non complying	Non complying
06.07.2022	09.06.2022	5825 dt. 23.06.2022	4.0MLD	7.5	40	7.44	13	90	0.28	Complying	Complying
03.08.2022	01.07.2022	6041 dt. 13.07.2022	3.50 MLD	8.2	48	7.77	18	80	1.95	Complying	Complying
25.08.2022	08.08.2022	6451 dt. 22.08.2022	3.98 MLD	6.2	24	7.01	12	70	0.36	Complying	Complying
27.09.2022	03.09.2022	6716 dt. 13.09.2022	2.32 MLD	6.8	40	7.06	15	80	1.78	Complying	Complying
25.10.2022	04.10.2022	7059 dt. 17.10.2022	3.2 MLD	21	88	7.3	55	1200	10.89	Non complying	Non complying
02.12.2022	15.11.2022	7480 dt. 29.11.2022		13	60	7.39	26	400	1.23	Non complying	Non complying
27.12.2022	02.12.2022	7686 dt. 19.12.2022		7.6	44	7.84	17	80	ND	Complying	Complying
18.01.2023	02.01.2023	5 dt. 12.01.2023		8	44	7.67	17	90	1.06	Complying	Complying
20.02.2023	06.02.2023	370 dt. 16.02.2023		7.5	44	7.84	16	80	1.22	Complying	Complying
22.03.2023	09.03.2023	779 dt. 21.03.2023		7.5	36	7.6	13	80	1.12	Complying	Complying
18.04.2023	03.04.2023	1097 dt. 13.04.2023		7.2	36	7.4	17	90	ND	Complying	Complying
23.05.2023	05.05.2023	1423 dt. 15.05.2023		7.6	44	7.94	15	80	ND	Complying	Complying
22.06.2023	01.06.2023	1753 dt. 12.06.2023		8	44	7.71	16	90	ND	Complying	Complying
27.07.2023	11.07.2023	2178 dt. 17.07.2023		7.4	36	6.9	12	80	ND	Complying	Complying
21.08.2023	03.08.2023	2424 dt. 16.08.2023		8	48	7.01	15	80	2.25	Complying	Complying
19.09.2023	06.09.2023	2787 dt. 14.09.2023		8	48	7.48	16	90	ND	Complying	Complying
03.11.2023	08.10.2023	3135 dt. 27.10.2023		8.6	48	7.5	17	90	2.53	Complying	Complying
23.11.2023	07.11.2023	3460 dt. 16.11.2023		7	36	7.14	11	90	ND	Complying	Complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	22.12.2023	08.12.2023	3822 dt. 20.12.2023		7.4	40	7.48	12	60	ND	Complying	Complying
		02.01.2024	4111 dt. 12.01.2024		9	48	6.98	15	90	ND	Complying	Complying
		21.02.2024	4671 dt. 12.03.2024		8	44	7.26	11	80	ND	Complying	Complying
		02.04.2024	23 dt. 10.04.2024		8	48	7.6	13	80	ND	Complying	Complying
		2.05.2024	177 dt. 09.05.2024		6.6	40	7.17	11	60	ND	Complying	Complying
		11.06.2024	337 dt. 21.06.2024		7.6	48	7.75	13		1.16	Complying	Complying
		12.07.24	639 dt. 24.07.2024		7.8	32	7.49	11	ND		Complying	Complying
		02.08.24	772 dt. 12.08.2024		7.2	44	7.09	13	ND		Complying	Complying
		2.09.2024	1019 dt. 10.09.2024		7	40	7.24	13		ND	Complying	Complying
		08.10.24	1207 dt. 15.10.2024		8	40	7.09	15	ND		Complying	Complying
		05.11.24	1381 dt. 12.11.2024		6.8	40	7.49	10	ND		Complying	Complying
		10.12.24	1644 dt. 18.12.2024		5.8	32	6.93	12	ND		Complying	Complying
33	(HSR-STP-008) 6 MLD STP Dhani Gram ,Barwala, Hisar by PHED in 9.12.2014	29.01.2021	1225-1226 dt. 05.02.2021		20	128	7.5	42	45000		Complying	Non complying
		24.02.2021	1357-1358 dt. 05.03.2021		26	144	8.2	48	32000		Complying	Non complying
		18.03.2021	1477-1478 dt. 25.03.2021	1.2	36	264	8.9	128	64000		Non complying	Non complying
		17.04.2021	97-98 dt. 27.04.2021		36	112	8.7	148	110000	18.6	Non complying	Non complying
		23.06.2021	408-409 dt. 01.07.2021		25	104	8.3	38	96000	8.6	Non complying	Non complying
		21.07.2021	643-644 dt. 30.07.2021	4.5	18	64	8	32	42000	7.4	Complying	Non complying
		16.08.2021	845-846 dt. 23.08.2021		20	72	8.1	26	1700	6.5	Complying	Non complying
		07.09.2021	930-931 dt. 13.09.2021	5.6	26	104	8.2	42	35000		Non complying	Non complying
		01.10.2021	1117 dt. 12.10.2021		52	256	8.4	170	72000		Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	20.12.2021	12.11.2021	1401-1402 dt. 26.11.2021	Not Work	79	296	8.5	210	210000		Non complying	Non complying
	28.12.2021	11.12.2021	1562 dt. 20.12.2021	Not Work	84	304	8.4	248	220000		Non complying	Non complying
	03.02.2022	05.01.2022	1733 dt. 13.01.2022	Not Work	92	312	8.3	238	180000		Non complying	Non complying
	15.04.2022	01.03.2022	4370 dt. 15.03.2022	5 MLD	26	196	7.72	78	1600	4.67	Non complying	Non complying
	04.05.2022	04.04.2022	4866 dt. 21.04.2022	4.80MLD	18	96	7.33	52	400	2.37	Non complying	Non complying
	31.05.2022	02.05.2022	5266 dt. 17.05.2022		21	108	7.93	58	1200	3.88	Non complying	Non complying
	06.07.2022	09.06.2022	5825 dt. 23.06.2022	4.68MLD	15	80	7.39	36	1700	5.46	Non complying	Non complying
	03.08.2022	08.07.2022	6109 dt. 18.07.2022		24	120	7.4	52	1700	2.19	Non complying	Non complying
	25.08.2022	07.08.2022	6443 dt. 22.08.2022	4.80 MLD	23	100	7.49	56	600	2.37	Non complying	Non complying
	10.10.2022	15.09.2022	6885 dt. 29.09.2022	4.98 MLD	25	128	7.39	68	700	2.93	Non complying	Non complying
	25.10.2022	04.10.2022	7066 dt. 17.10.2022	4.70 MLD	21	124	7.3	78	600	2.79	Non complying	Non complying
	09.12.2022	22.11.2022	7536 dt. 02.12.2022		21	96	7.06	36	500	1.44	Non complying	Non complying
	27.12.2022	02.12.2022	7687 dt. 19.12.2022		17	80	7.49	35	700	1.38	Non complying	Non complying
	18.01.2023	04.01.2023	22 dt. 13.01.2023		20	124	7.4	52	500	2.36	Non complying	Non complying
	20.02.2023	06.02.2023	371 dt. 16.02.2023		22	120	7.67	86	500	7.36	Non complying	Non complying
	22.03.2023	09.03.2023	773 dt. 21.03.2023		34	124	7.49	98	500	2.48	Non complying	Non complying
	18.04.2023	03.04.2023	1102 dt. 13.04.2023		16	76	7.3	76	400	1.85	Non complying	Non complying
	23.05.2023	05.05.2023	1421 dt. 15.05.2023		15	72	7.57	37	500	4.28	Non complying	Non complying
	22.06.2023	01.06.2023	1745 dt. 12.06.2023		12	64	7.86	25	200	1.23	Non complying	Non complying
	21.07.2023	06.07.2023	2151 dt. 17.07.2023		16	76	6.8	26	200	1.93	Non complying	Non complying
	21.08.2023	03.08.2023	2422 dt. 16.08.2023		15	76	6.89	25	400	3.88	Non complying	Non complying
	19.09.2023	06.09.2023	2786 dt. 14.09.2023		16	80	7.2	28	200	1.93	Non complying	Non complying
	03.11.2023	07.10.2023	3139 dt. 27.10.2023		15	72	7.4	39	400	2.72	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	23.11.2023	07.11.2023	3465 dt. 16.11.2023		14	68	7.36	29	400	1.78	Non complying	Non complying
	22.12.2023	08.12.2023	3823 dt. 20.12.2023		16	108	7.3	64	400	1.46	Non complying	Non complying
		03.01.2024	4142 dt. 12.01.2024		18	116	6.4	27	400	1.67	Non complying	Non complying
		21.02.2024	4673 dt. 12.03.2024		23	120	7.05	29	800	2.28	Non complying	Non complying
		02.04.2024	24 dt. 10.04.2024		11.6	64	7.36	25	800	0.3	Non complying	Non complying
		02.05.2024	179 dt. 09.05.2024		27	164	7.16	51	2400	2.61	Non complying	Non complying
		12.06.2024	335 dt. 21.06.2024		19	84	6.98	37		2.86	Non complying	Non complying
		12.07.24	640 dt. 24.07.2024		14	80	7.29	32	ND		Non complying	Non complying
		02.08.24	773 dt. 12.08.2024		13	68	7.1	26	ND		Non complying	Non complying
		2.09.2024	1013 dt. 10.09.2024		5.8	36	6.96	13		1.73	Complying	Complying
		08.10.24	1206 dt. 15.10.2024		15	76	7.4	29	ND		Non complying	Non complying
		05.11.24	1385 dt. 12.11.2024		12	68	6.84	25	ND		Non complying	Non complying
		02.12.24	1561 dt. 13.12.2024		12.5	60	7.5	23	ND		Non complying	Non complying
		08.01.25	1815 dt. 16.01.2025		26	152	7.3	88	ND		Non complying	Non complying
34	(HSR-STP-009) 5 MLD STP Dhani Kushal , Bhiwani Road, Hansi , Hisar by PHED in 15.4.2014	29.01.2021	1229-1230 dt. 05.02.2021		22	112	7.3	38	32000		Complying	Non complying
		22.02.2021	1339-1340 dt. 02.03.2021		27	104	7.9	45	28000		Complying	Non complying
		15.03.2021	1471-1472 dt. 24.03.2021	2	21	88	7.6	38	7200		Complying	Non complying
		02.04.2021	9-10 dt. 12.04.2021	173	20	128	7.8	46	4500		Complying	Non complying
		20.05.2021	203-204 dt. 29.05.2021		24	112	7.9	42	6500	9.4	Complying	Non complying
		04.06.2021	300-301 dt. 11.06.2021		23	104	8	38	7200	9.1	Complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks	
	03.07.2021	483-484 dt. 12.07.2021		36	160	8.2	48	5200	9.6	Non complying	Non complying	
	03.08.2021	763-764 dt. 11.08.2021		24	112	8	32	8200	8.2	Complying	Non complying	
	06.09.2021	928-929 dt. 13.09.2021	4.1	38	208	7.8	70	62000		Non complying	Non complying	
	01.10.2021	1122-1123 dt. 12.10.2021	3.6	27	168	7.7	54	1200		Non complying	Non complying	
	27.12.2021	17.11.2021	1435-1436 dt. 03.12.2021	2.9	25	144	7.6	48	720		Non complying	Non complying
	28.12.2021	13.12.2021	1572-1573 dt. 22.12.2021	2.4	22	136	7.7	42	680		Non complying	Non complying
	03.02.2022	05.01.2022	1727-1728 dt. 13.01.2022	2.4	21	120	7.8	38	720		Non complying	Non complying
	15.04.2022	01.03.2022	4372 dt. 15.03.2022	2.80 MLD	26	168	7.31	89	1200	7.3	Non complying	Non complying
	04.05.2022	04.04.2022	4864 dt. 21.04.2022	2.80 MLD	62	228	7.16	180	2100	180	Non complying	Non complying
	31.05.2022	03.05.2022	5275 dt. 17.05.2022		17	88	7.48	38	400	5.75	Non complying	Non complying
	06.07.2022	09.06.2022	5827 dt. 23.06.2022	2.80MLD	18	92	7.56	56	1700	56	Non complying	Non complying
	03.08.2022	01.07.2022	6040 dt. 13.07.2022	2.80 MLD	17	92	7.65	42	800	5.06	Non complying	Non complying
	25.08.2022	08.08.2022	6449 dt. 22.08.2022	2.89 MLD	18	120	7.18	87	700	4.04	Non complying	Non complying
	27.09.2022	03.09.2022	6714 dt. 13.09.2022	2.32 MLD	19	84	7.7	42		2.97	Non complying	Non complying
	25.10.2022	04.10.2022	7058 dt. 17.10.2022		48	160	7.15	127	1100	8.75	Non complying	Non complying
	02.12.2022	15.11.2022	7474 dt. 29.11.2022		72	280	7.32	110	900	2.87	Non complying	Non complying
	18.01.2023	02.01.2023	01 dt. 12.01.2023		102	364	7.23	158	1100	8.96	Non complying	Non complying
	20.02.2023	05.02.2023	365 dt. 16.02.2023		24	132	7.33	95	1100	9.86	Non complying	Non complying
	24.03.2023	10.03.2023	780 dt. 21.03.2023		17	96	7.6	57	400	2.24	Non complying	Non complying
	18.04.2023	01.04.2023	1094 dt. 13.04.2023		28	184	7.19	95	800	8.96	Non complying	Non complying
	23.05.2023	05.05.2023	1419 dt. 15.05.2023		76	272	7.66	118	700	8.72	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	22.06.2023	01.06.2023	1746 dt. 12.06.2023		27	140	7.42	85	700	ND	Non complying	Non complying
	21.07.2023	11.07.2023	2183 dt. 21.07.2023		15	76	7.42	27	400	2.52	Non complying	Non complying
	21.08.2023	03.08.2023	2419 dt. 16.08.2023		16	88	7.27	28	400	2.52	Non complying	Non complying
	21.09.2023	06.09.2023	2789 dt. 14.09.2023		15	80	7.1	24	400	2.83	Non complying	Non complying
	03.11.2023	07.10.2023	3134 dt. 27.10.2023		24	128	7.38	64	700	4.87	Non complying	Non complying
	23.11.2023	07.11.2023	3462 dt. 16.11.2023		38	144	7.48	78	700	7.85	Non complying	Non complying
	22.12.2023	08.12.2023	3824 dt. 20.12.2023		22	120	6.68	67	600	1.29	Non complying	Non complying
		02.01.2024	4112 dt. 12.01.2024		52	192	7.42	98	400	2.87	Non complying	Non complying
		21.02.2024	4668 dt. 12.03.2024		24	132	6.8	38	600	2.6	Non complying	Non complying
		02.04.2024	25 dt. 10.04.2024		13	80	7.36	31	1100	1.6	Non complying	Non complying
		02.05.2024	173 dt. 09.05.2024		24	132	7.54	70	3300	3.6	Non complying	Non complying
		11.06.2024	340 dt. 21.06.2024		108	364	6.84	132		9.37	Non complying	Non complying
		12.07.24	642 dt. 24.07.2024		145	508	6.86	226	ND		Non complying	Non complying
		02.08.24	774 dt. 12.08.2024		120	392	7.14	195	ND		Non complying	Non complying
		2.09.2024	1014 dt. 10.09.2024		102	352	6.92	195		12.08	Non complying	Non complying
		08.10.24	1202A dt. 15.10.2024		130	428	7.1	256	ND		Non complying	Non complying
		05.11.24	1383 dt. 12.11.2024		19	112	6.73	47	ND		Non complying	Non complying
		10.12.24	1643 dt. 18.12.2024		7	44	6.8	15	ND		Complying	Complying
		07.01.25	1804 dt. 15.01.2025		12	64	7.12	23	ND		Non complying	Non complying
35	(HSR-STP-010) 7.5 MLD STP Lalpura, Jind Road, Hansi , Hisar by PHED in 15.4.2014	29.01.2021	1221-1222 dt. 05.02.2021		24	112	8	28	56000		Complying	Non complying

STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/legally)	Remarks
	22.02.2021	1345-1346 dt. 02.03.2021		26	144	8	42	38000		Complying	Non complying
	15.03.2021	1475-1756 dt. 24.03.2021	2.76	22	104	7.8	26	22000		Complying	Non complying
	02.04.2021	7-8 dt. 12.04.2021	158	34	136	8	58	42000		Non complying	Non complying
	20.05.2021	205-206 dt. 29.05.2020		26	120	8.1	48	32000	8.6	Complying	Non complying
	04.06.2021	298-299 dt. 11.06.2021		24	104	8	42	25000	8.4	Complying	Non complying
	03.07.2021	485-486 dt. 12.07.2021		39	192	8.3	64	420000	10.6	Non complying	Non complying
	03.07.2021	485-486 dt. 12.07.2021		22	112	8.1	38	18000	8.1	Complying	Non complying
	03.08.2021	767-768 dt. 11.08.2021		20	96	8	28	15000	7.6	Non complying	Non complying
	16.09.2021	962-963 dt. 22.09.2021	5.6	26	168	7.9	64	56		Non complying	Non complying
	01.10.2021	1124-1125 dt. 12.10.2021	7.6	24	128	7.8	42	77		Non complying	Non complying
27.12.2021	24.11.2021	1449-1450 dt. 03.12.2021	4.8	21	112	7.9	38	120		Non complying	Non complying
28.12.2021	13.12.2021	1566-1567 dt. 22.12.2021	4.9	22	104	7.8	36	480		Non	Non
03.02.2022	05.01.2022	1736-1737 dt. 13.01.2022	3.98	20	112	8.1	38	420		Non complying	Non complying
15.04.2022	02.03.2022	4377 dt. 15.03.2022	4 MLD	25	120	7.24	56	2100	0.46	Non complying	Non complying
04.05.2022	05.04.2022	4868 dt. 21.04.2022	4.80MLD	15	76	7.52	62	600	1.32	Non	Non
31.05.2022	03.05.2022	5277 dt. 17.05.2022		13	64	7.28	29	600	2.85	Non complying	Non complying
06.07.2022	09.06.2022	5826 dt. 23.06.2022	4.0MLD	16	76	7.4	34	1400	1.31	Non	Non
03.08.2022	01.07.2022	6039 dt. 13.07.2022	4.30 MLD	16	80	8.93	37	600	2.42	Non complying	Non complying
25.08.2022	08.08.2022	6450 dt. 22.08.2022	5	14	68	7.01	32	400	3.05	Non complying	Non complying
27.09.2022	03.09.2022	6713 dt. 13.09.2022	4.27 MLD	18	76	7.52	38	400	3.24	Non complying	Non complying
25.10.2022	04.10.2022	7057 dt. 17.10.2022	5.10 MLD	62	208	7.08	132	800	7.86	Non complying	Non complying
02.12.2022	15.11.2022	7479 dt. 29.11.2022		18	92	7.32	45	500	1.93	Non complying	Non complying
18.01.2023	02.01.2023	03 dt. 12.01.2023		42	168	7	98	500	1.35	Non complying	Non complying

	STP's Name	Collection Date	Report No. & date	Flow Outlet	BOD mg/l (10)	COD mg/l (50)	PH (5.5 to 9.0)	TSS mg/l (20)	Fecal Coliform MPN/100 ml (100)	Total Nitrogen (mg/l) (10)	Remarks (actual/ legally)	Remarks
	20.02.2023	05.02.2023	369 dt. 16.02.2023		21	124	7.32	96	900	9.56	Non complying	Non complying
	24.03.2023	10.03.2023	781 dt. 21.03.2023		16	68	7.51	35	500	2.95	Non complying	Non complying
	18.04.2023	01.04.2023	1101 dt. 13.04.2023		48	172	7.14	126	500	4.95	Non complying	Non complying
	23.05.2023	05.05.2023	1418 dt. 15.05.2023		68	236	7.62	182	900	13.16	Non complying	Non complying
	22.06.2023	01.06.2023	1754 dt. 12.06.2023		27	136	7.42	88	600	4.82	Non complying	Non complying
	27.07.2023	11.07.2023	2182 dt. 21.07.2023		21	96	6.85	35	500	2.96	Non complying	Non complying
	21.08.2023	03.08.2023	2423 dt. 16.08.2023		28	136	6.85	85	700	2.64	Non complying	Non complying
	21.09.2023	06.09.2023	2789 dt. 14.09.2023		19	84	7.46	31	400	3.43	Non complying	Non complying
	03.11.2023	07.10.2023	3136 dt. 27.10.2023		16	76	7.38	37	500	3.68	Non complying	Non complying
	23.11.2023	07.11.2023	3461 dt. 16.11.2023		18	80	7.5	48	600	4.93	Non complying	Non complying
	22.12.2023	08.12.2023	3825 dt. 20.12.2023		26	124	7	76	800	2.17	Non complying	Non complying
		2.01.2024	4110 dt. 12.01.2024		50	220	7.05	186	800	3.61	Non complying	Non complying
		21.02.2024	4672 dt. 12.03.2024		27	144	7.1	56	800	ND	Non complying	Non complying
		02.04.2024	26 dt. 10.04.2024		28	144	7.9	56	2100	1.62	Non complying	Non complying
		02.05.2024	176 dt. 09.05.2024		18	112	7.72	56	2100	2.16	Non complying	Non complying
		11.06.2024	339 dt. 21.06.2024		72	248	7.12	188		13.78	Non complying	Non complying
		12.07.24	643 dt. 24.07.2024		150	488	6.65	286	ND		Non complying	Non complying
		02.08.24	775 dt. 12.08.2024		135	472	6.9	228	ND		Non complying	Non complying
		2.09.2024	1015 dt. 10.09.2024		124	388	7.14	215		12.24	Non complying	Non complying
		08.10.24	1203 dt. 15.10.2024		130	432	7.18	244	ND		Non complying	Non complying
		05.11.24	1382 dt. 12.11.2024		14	80	7.06	23	ND		Non complying	Non complying

Flow Inlet	BOD	COD	PH	TSS	Fecal Coliform MPN/100 ml	Total Nitrogen (mg/l)	Bypass	Collection date of sludge	Report No. & date	pH (6.5.7.5)	Conductivity Micro S/cm (4.0)	Arsenic mg/ Kg (10.0)	Lead mg/ Kg (100.0)	Mercury (mg/ Kg) (0.15)
	125	428	6.5	192		9.88								
	111	300	6.4	120										
	130	476	7.35	298		13.67								
	180	692	7.3	132		17.07		02.03.2021	46 - 30.03.2021	7.44	3220
	91	296	7.33	82		6								
2145 m3/h	940	3152	6.75	788		6.21								
	420	1504	7.68	268	-	17.03								
40996 m3	46	156	6.94	112	-	9.4								
41.592	90	388	7.01	145	-	13.19								
15492 m3/	44	272	8.31	60	-	13.52								
1057.6 m2	180	688	7.62	282	-	24.95								
1985.4m3/	520	1768	7.15	816	-	24.95								
1071.8m3	220	800	7.42	348	-	9.97								
93871m3	220	896	6.3	340	-	16.55								
1.1 MLD	160	624	7.42	206	-	15.38								
1262.7m3/	120	404	7.66	168	-	16.61								
44381 m^3	36	108	6.95	122	-	17.25								
2044m^3/h	88	320	7	318	-	7.48								

Sample Collected in the month of January;

Flow Inlet	BOD	COD	PH	TSS	Fecal Coliform MPN/100 ml	Total Nitrogen (mg/l)	Bypass	Collection date of sludge	Report No. & date	pH (6.5.7.5)	Conductivity Micro S/cm (4.0)	Arsenic mg/ Kg (10.0)	Lead mg/ Kg (100.0)	Mercury (mg/ Kg) (0.15)
	132	528	7.3	254	3200	22.7								
	96	392	7.63	170	2800	15.6								
	108	432	7.94	212	3100	16.3								
	120	472	8.06	240	4900	18.61								
	98	392	7.54	225	4000	18.21								
	95	384	7.63	205	4400	28								
	102	408	7.48	230	3100	22.41								
	90	344	7.56	245	4900	18.61								
	75	304	7.33	210	5300	28.02								
	85	376	7.56	270	4900	21.01								
	102	416	7.49	225	3300	25.61								
	95	384	7.55	210	4100	36.42								
	135	348	6.8	229	92000									
	125	352	6.6	259	84000									
38.8	130	344	7.4	242	160000	29.1								
84.7	140	324	7.1	316	230000	24.1								
76	155	368	7	346	290000	27.8								
77	150	352	7.2	361	310000	28.6		09.06.2021	197-198 dt. 15.06.2021	7.5	1320		1.4	

Flow Inlet	BOD	COD	PH	TSS	Fecal Coliform MPN/100 ml	Total Nitrogen (mg/l)	Bypass	Collection date of sludge	Report No. & date	pH (6.5.7.5)	Conductivity Micro S/cm (4.0)	Arsenic mg/ Kg (10.0)	Lead mg/ Kg (100.0)	Mercury (mg/ Kg) (0.15)
	118	424	6.68	176	-	13.41								
	145	496	6.82	327	-	12.47								
	140	480	7.1	287	-	13.97								
	145	496	6.8	227	-	14.28								
	135	488	6.93	176	-	12.48								
	145	496	7.24	190	-	15.9								
	130	448	7.25	147	-	10.89								
	160	568	6.56	234		15.8								
	160	568	6.17	255		17.38								
	145	504	6.67	236		8.96								
	125	420	6.7	235		11.28								
	122	412	6.78	192		12.32								
	120	384	7.26	182		8.72								
	135	460	6.82	245		11.15								
	190	620	6.57	276		12.48								
	36	140	7.51	103		9.15								
	40	152	7.27	81		4.19								
0.34	46	168	7.16	118		8.42								
	36	128	7.43	108	-	3.03								
0.28 MLD	54	180	7.42	1110	-	9.18		27.05.2021	65 dt. 25.06.2021	6.94				

Flow Inlet	BOD	COD	PH	TSS	Fecal Coliform MPN/100 ml	Total Nitrogen (mg/l)	Bypass	Collection date of sludge	Report No. & date	pH (6.5.7.5)	Conductivity Micro S/cm (4.0)	Arsenic mg/ Kg (10.0)	Lead mg/ Kg (100.0)	Mercury (mg/ Kg) (0.15)
	120	388	6.89	159	-	12.18								
	122	396	6.72	242	-	10.48								
	110	396	6.9	217	-	10.62								
	120	392	6.9	194	-	12.62								
	140	492	6.92	164	-	10.87								
	78	296	7.23	130	-	10.89								
	110	396	7.01	94	-	12.55								
	140	528	6.98	192	-	14.67								
	128	424	6.83	244		12.28								
	115	384	7	145		9.56								
	135	460	6.29	135										
	125	392	7.1	218		11.52								
	150	488	6.96	280		13.76								
	46	180	7.53	282		8.64								
	62	216	7.17	132		16.14								
	32	124	7.25	126		9.02								
	52	192	7.15	136	-	4.51								
	52	180	7.36	122	-	10.38			52 dt. 07.05.2021	6.81	2040	-	0.009	

Flow Inlet	BOD	COD	PH	TSS	Fecal Coliform MPN/100 ml	Total Nitrogen (mg/l)	Bypass	Collection date of sludge	Report No. & date	pH (6.5.7.5)	Conductivity Micro S/cm (4.0)	Arsenic mg/ Kg (10.0)	Lead mg/ Kg (100.0)	Mercury (mg/ Kg) (0.15)
	165	580	6.64	395	-	14.61								
	155	536	5.82	192	-	15.62								
	140	480	7.16	197	-	13.67								
	175	576	7.02	210	-	12.4								
	145	472	7.65	225		12.68								
	145	488	6.87	212		9.76								
	150	520	7.26	135		12.23								
	84	296	7.09	175		9.58								
	145	512	6.8	215		11.38								
	135	452	6.53	216		9.86								
	280	1000	6.56	2136		13.25								
	108	392	8.3	370	280000									
	110	312	8.1	340	310000									
	112	344	8.1	308	350000									
	110	312	8	294	380000	47.4		30.04.21	18 dt. 10.05.2021	8.2	9980			
	116	344	8.1	308	350000	45.6								
	110	312	8	394	310000	42.8								
	108	304	8.1	286	250000	48.7								
	105	312	8.3	280	210000	47.6								
Not Work	118	360	8.2	318	120000			29.09.21	81 dt. 11.10.2021	7.9	9450			

Flow Inlet	BOD	COD	PH	TSS	Fecal Coliform MPN/100 ml	Total Nitrogen (mg/l)	Bypass	Collection date of sludge	Report No. & date	pH (6.5.7.5)	Conductivity Micro S/cm (4.0)	Arsenic mg/ Kg (10.0)	Lead mg/ Kg (100.0)	Mercury (mg/ Kg) (0.15)
	155	508	7.2	268		13.27		29.10.2024	356 dt 18.11.2024	6.75	1475.0		BDL (DL = 0.3782 mg/ kg)	
	145	496	6.8	295		12.72								
	220	824	6.92	938		12.26								
	200	704	6.54	189		13.52								
	110	380	6.75	278		10.58								
	160	540	7.03	288		12.43								
	112	368	8.6	510	250000									
	114	304	8.2	328	280000									
	118	312	8.4	336	220000	48.5								
	116	304	8.3	294	180000	42.9								
	112	336	8.1	286	150000	44.2		10.06.21	23 dt. 25.06.2021	7.3	8470			
	108	304	8.2	276	210000	48.9								
	102	320	8.1	284	180000	46.8								
7	105	328	8.2	290	120000			29.09.21	73 dt. 11.10.2021	7.2	8210			
7	103	304	8.1	280	48000									
6.5	105	312	8.2	294	56000									
7.2	108	328	8	280	68000			14.12.21	99 dt. 24.12.2021	7.3	7860			

Flow Inlet	BOD	COD	PH	TSS	Fecal Coliform MPN/100 ml	Total Nitrogen (mg/l)	Bypass	Collection date of sludge	Report No. & date	pH (6.5.7.5)	Conductivity Micro S/cm (4.0)	Arsenic mg/ Kg (10.0)	Lead mg/ Kg (100.0)	Mercury (mg/ Kg) (0.15)
	145	496	7.22	276	-	11.96								
	112	408	6.94	285	-	8.96								
	210	736	6.85	216		14.29								
	125	436	6.9	257	-	14.61								
	135	480	7.02	215	-	11.46								
	135	496	6.89	180	-	12.87								
	160	556	7.12	234	-	14.67								
	160	524	7.07	198		13.42								
	110	368	6.29	178		11.29								
	120	424	7.13	134		12.26								
	135	472	6.43	216		9.96								
	145	496	7.31	396		12.25		29.10.2024	357 dt 18.11.2024	6.70	1495		BDL (DL = 0.3782 mg/ kg)	
	160	524	6.9	252		12.23								
	135	480	6.9	242		12.72								
	135	468	6.6	282		8.29								
	126	392	8.5	460	310000									
	118	336	8.3	380	250000									
	112	288	8.1	316	180000									
	108	304	8.3	298	210000	29.5								
	109	304	8.3	284	170000	24.5								
	106	312	8.2	372	150000	28.9		10.06.21	21 dt. 25.06.2021	7.4	8970			

Flow Inlet	BOD	COD	PH	TSS	Fecal Coliform MPN/100 ml	Total Nitrogen (mg/l)	Bypass	Collection date of sludge	Report No. & date	pH (6.5.7.5)	Conductivity Micro S/cm (4.0)	Arsenic mg/ Kg (10.0)	Lead mg/ Kg (100.0)	Mercury (mg/ Kg) (0.15)
	145	508	7.86	235		13.26								
	140	492	6.64	224		13.24								
	100	376	7.27	235		9.79								
	96	308	6.39	186		13.22								
	145	468	7.15	228		12.92		28.10.2024	359 dt 18.11.2024	6.64	1205.0		BDL (DL = 0.3782 mg/kg)	
	135	468	7.08	186		13.26								
	150	532	6.9	282		12.83								
	120	416	6.68	218		8.76								
	120	420	6.87	345		9.56								
	155	488	6.53	367		14.32								
	118	344	8.4	420	210000									
	98	288	8.2	310	250000									
	102	312	8.2	296	280000									
	108	336	8.4	318	220000	46.8								
	114	312	8.5	302	250000	48.2								
	116	328	8.3	296	220000	46.2		29.06.21	39 dt. 09.07.2021	7.4	3240			
	102	312	8.2	284	210000	40.8								
	109	360	8.2	290	250000	42.6								
3.2	104	336	8	278	210000			29.09.21	75 dt. 11.10.2021	7.2	3480			

Copper mg/kg (300.0)	Zinc mg/kg (1000.0)	Nickel mg/kg (50.0)	Iron mg/kg	Total Chromium mg/kg (50.0)	Hexavalent Chromium mg/kg	Cadmium mg/kg (5.0)	Total Nitrogen mg/kg minimum (0.8)	Total Phosphate mg/ kg minimum (0.4)	Total Potassium mg/ Kg minimum (0.4)	Total Organic Carbon % minimum (12.0)	Cobalt	Parameter not analysed (sludge)
	402.8	35.1		3.8	ND		0.3	4.9				

Copper mg/kg (300.0)	Zinc mg/kg (1000.0)	Nickel mg/kg (50.0)	Iron mg/kg	Total Chromium mg/kg (50.0)	Hexavalent Chromium mg/kg	Cadmium mg/kg (5.0)	Total Nitrogen mg/kg minimum (0.8)	Total Phosphate mg/ kg minimum (0.4)	Total Potassium mg/ Kg minimum (0.4)	Total Organic Carbon % minimum (12.0)	Cobalt	Parameter not analysed (sludge)
0.081	0.679	N.D	4.712	N.D	-	N.D						

Copper mg/kg (300.0)	Zinc mg/kg (1000.0)	Nickel mg/kg (50.0)	Iron mg/kg	Total Chromium mg/kg (50.0)	Hexavalent Chromium mg/kg	Cadmium mg/kg (5.0)	Total Nitrogen mg/kg minimum (0.8)	Total Phosphate mg/ kg minimum (0.4)	Total Potassium mg/ Kg minimum (0.4)	Total Organic Carbon % minimum (12.0)	Cobalt	Parameter not analysed (sludge)
BDL (DL = 0.7106 MG/KG)	175	BDL (DL = 1.216 mg/ kg)	2198	BDL (DL = 1.349 mg/kg)		BDL (DL=1.164 MG/KG)						
	45.6	28.4	70.5	ND	ND							
	48.7	25.2		BDL	BDL							
	62.6	28.5		BDL	BDL							

Copper mg/kg (300.0)	Zinc mg/kg (1000.0)	Nickel mg/kg (50.0)	Iron mg/kg	Total Chromium mg/kg (50.0)	Hexavalent Chromium mg/kg	Cadmium mg/kg (5.0)	Total Nitrogen mg/kg minimum (0.8)	Total Phosphate mg/ kg minimum (0.4)	Total Potassium mg/ Kg minimum (0.4)	Total Organic Carbon % minimum (12.0)	Cobalt	Parameter not analysed (sludge)

BDL (DL = 0.7106 mg/ kg)	142.8	BDL (DL = 1.216 MG/ KG)	2498.0	BDL (DL = 1.349 mg/kg)		BDL (DL = 1.164 mg/ kg)						
	78.4	32.6	94.6	ND	ND							

Copper mg/kg (300.0)	Zinc mg/kg (1000.0)	Nickel mg/kg (50.0)	Iron mg/kg	Total Chromium mg/kg (50.0)	Hexavalent Chromium mg/kg	Cadmium mg/kg (5.0)	Total Nitrogen mg/kg minimum (0.8)	Total Phosphate mg/ kg minimum (0.4)	Total Potassium mg/ Kg minimum (0.4)	Total Organic Carbon % minimum (12.0)	Cobalt	Parameter not analysed (sludge)
BDL (DL = 0.7106 mg/ kg)	200.20	BDL (DL = 1.216 mg/kg)	1752.0	BDL (DL= 1.349 mg/kg)		BDL (DL = 1.164 mg / kg)						
	273.8	33.4	22.6	1.9	ND							
	184.5	29.8		BDL	BDL							

